

**Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013**

For the

**Jefferson County
Wastewater Treatment Plants**

as required by the
Alabama Department of Environmental Management NPDES Program



Prepared by
Jefferson County Commission
Environmental Services Department

May 31, 2014

Municipal Water Pollution Prevention (MWPP) Annual Report Calendar Year 2013

For the

Cahaba River WWTP

as required by the
Alabama Department of Environmental Management NPDES Program



Prepared by
Jefferson County Commission
Environmental Services Department

May 31, 2014

JEFFERSON COUNTY COMMISSION



DAVID CARRINGTON - PRESIDENT
GEORGE F. BOWMAN
SANDRA LITTLE BROWN - PRESIDENT PRO TEMPORE
T. JOE KNIGHT
JAMES A. "JIMMIE" STEPHENS

May 31, 2014

Mr. Nic Caraway, Water Division
Alabama Department of Environmental Management
Water Division – Municipal Branch
P.O. Box 301463
Montgomery, AL 36130-1463

RE: Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013

Mr. Caraway:

The Jefferson County Environmental Services Department submits the above referenced report for the Cahaba River Wastewater Treatment Facility, NPDES Permit No. AL0023027. Included is information as required in ADEM Form 41701/06ml, bypass/overflow event reports, MWPP Sewage Sludge Survey, and the Plant & Collection System Personnel Inventory.

If you have any questions regarding this information, please contact me at 205.325.5979 or Celeste Brown at Jefferson County Barton Laboratory at 205.238.3859.

Sincerely,

David Denard, Director
Environmental Services Department

pc: Celeste Brown, JCESD Barton Laboratory
Daniel White, JCESD Deputy Director
Gary Nelson, Cahaba River WWTP

DAVID CARRINGTON – COMMISSIONER
ENVIRONMENTAL SERVICES

TONY PETELOS, COUNTY MANAGER

Office of

DAVID DENARD
Director of Environmental Services
Suite A-300
716 Richard Arrington, Jr. Blvd. N.
Birmingham, Alabama 35203
Telephone (205) 325-5496
Fax (205) 325-5981

**MUNICIPAL WATER POLLUTION PREVENTION (MWPP)
ANNUAL REPORT**

SUBMITTED BY:

TREATMENT FACILITY: Cahaba River WWTP NPDES #: AL0023027

MUNICIPALITY: Jefferson County Environmental Services Dept. COUNTY: Jefferson

CONTACT PERSON: David Denard

Municipal Official

Director of Environmental Services

Title

Telephone #: 205-325-5979 Fax #: 205-325-5239

Email Address: denaradd@jccal.org

CHIEF OPERATOR: Gary Nelson

Name

Telephone #: 205-987-0648 Fax #: 205-402-7427

Email Address: nelsong@jccal.org

Date: May 14, 2014

REVIEWED BY: Daniel White P.E., ESD Engineer

Consulting Engineer

Telephone #: 205 214 8610 Fax #: 205 325 5688

Date: May 14, 2014

**MWPP Annual Report
Information Source List**

The following information will be needed to complete the compliance maintenance report that covers the calendar year of 2013 (due **May 31,** 2014).

- Part 1 A. The average plant influent flow for each month (million gallons per day/MGD) during the year.
B. The average plant influent BOD (CBOD) for each month (mg/l and lb/day) in the year.
C. The plant's average design flow (MGD) and design BOD loading (lbs/day).
- Part 2 A. The monthly average permit and DMR effluent concentration for BOD (CBOD), TSS, NH3-N, and/or TKN in mg/l for the year
B. The monthly average effluent limits and DMR loading for BOD, TSS, NH3-N, and/or TKN in lbs/day for the year
- Part 3 The age of the treatment plant defined as the number of years since the last major reconstruction to increase the organic or hydraulic capacity of the plant. The last calendar year minus the year the new construction was brought on-line.
- Part 4 Bypass and overflow information. This is the number of bypass or overflow events of untreated wastewater due to heavy rain or equipment failure whether intentional or inadvertent from all collection systems tributary to the treatment facility.
- Part 5 A. Describe the characteristics and quantity of sludge generated.
B. If sludge is landspread, how many months of sludge storage does the plant have? This should include on-site and off-site storage from the treatment plant. The digester capacity may be used in the calculation.
- Part 6 A. Sludge Disposal Method
B. The number of approved land disposal sites for sludge available, and how many months or years these disposal sites will these be available for use.
- Part 7 The number of sewer extensions installed in the community last year--the design population, design flow, and design BOD for each sewer extension.
- Part 8 Operator Certification
- Part 9 Financial Status
- Part 10 Subjective Evaluation
- Part 11 Summary Sheet

State of Alabama
MWPP Annual Report
Department of Environmental Management

Instructions to the Operator-in-Charge

1. Complete all sections of the MWPP Report to the best of your ability.
2. Parts 1 through 8 contain questions for which points will be generated. These points are intended to communicate to the Department and the governing body or owner the actions necessary to prevent effluent violations. Enter the point totals from Parts 1 through 8 on Part 11: Summary Sheet.
3. Add the point totals on Part 11: Summary Sheet.
4. Submit the MWPP Report to the governing body and the consulting engineer and owner for review and approval.
5. The governing body should pass a resolution which contains the following points:
 - a. The resolution should acknowledge the governing body or owner has reviewed the MWPP Report.
 - b. The resolution should indicate what actions will be taken to prevent effluent violations.
 - c. The resolution should provide any other information the governing body or owner deems appropriate.
6. **The MWPP Report and the resolution must be submitted by May 31st to Municipal Section, Water Division, ADEM, P.O. Box 301463, Montgomery, AL 36130-1463.**

Facility Name: Cahaba River WWTP

Part 1: Influent Loading/Flows

A. List the average monthly volumetric flows and BOD₅ (CBOD₅) loadings received at your facility during the last calendar year.

| <u>Month</u> | <u>Column 1 Average Monthly Flowrate (MGD)</u> | <u>Column 2 Average Monthly BOD₅ (CBOD₅) Concentration (mg/l)</u> | <u>Column 3 Average Loading BOD₅ (CBOD₅) (lbs/day**)</u> |
|--------------------|--|---|--|
| January | 11.8 | 108 | 9612 |
| February | 12.3 | 85 | 8670 |
| March | 10.6 | 120 | 9761 |
| April | 9.5 | 117 | 9204 |
| May | 8.5 | 156 | 10600 |
| June | 8.9 | 140 | 10392 |
| July | 9.3 | 142 | 10922 |
| August | 10.0 | 107 | 8460 |
| September | 8.3 | 150 | 10398 |
| October | 5.5 | 169 | 7811 |
| November | 6.3 | 164 | 8357 |
| December | 10.0 | 110 | 8722 |
| Annual Avg. | 9.2 | 131 | 9409 |

**As reported on NPDES Discharge Monitoring Reports (DMRs) and as required by EPA's NPDES Self-Monitoring System, User Guide, March 1985.

B. List the average design flow and average design BOD₅ loading for the facility below. If you are not aware of these design quantities, contact your consulting engineer or the Alabama Department of Environmental Management.

| | <u>Average Design Flow</u> | <u>Average Design BOD₅ Loading (lbs/day)</u> |
|----------------------------|----------------------------|---|
| Design Criteria | 12.0 | 19912 |
| 90% of the Design Criteria | 10.8 | 17921 |

- C. How many times did the monthly flow (Column 1) to the WWTP exceed 90% of design flow?
 _____ (Check the appropriate point total)
 0 - 4 = 0 points 5 or more = 5 points
- D. How many times did the monthly flow (Column 1) to the WWTP exceed the design flow?
 _____ (Check the appropriate point total)
 0 = 0 points 1 - 2 = 5 points 3 - 4 = 10 points 5 or more = 15 points
- E. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed 90% of the design loading? _____ (Check the appropriate point total)
 0 - 1 = 0 points 2 - 4 = 5 points 5 or more = 10 points
- F. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed the design loading? _____ (Check the appropriate point total)
 0 = 0 points 1 = 10 points 2 = 20 points 3 = 30 points 4 = 40 points 5 or more = 50 points
- G. Enter each point value marked for C through F and enter the sum in the appropriate blank below.

C points = 0

D points = 5

E points = 0

F points = 0

TOTAL POINTS VALUE OR PART 1 5
 Enter this value on Part 11: Summary Sheet.

*To obtain equivalent BOD₅ loading for comparison with design loading for those permittees using influent CBOD₅, divide annual average CBOD₅, loading in lbs/day from Part 1, A by 0.7.

Facility Name: Cahaba River WWTP

Part 2: Effluent Quality/Plant Performance

A. List the monthly average permit limits for the facility in the blanks below and the average monthly effluent DMR BOD₅, (CBOD₅) TSS, NH₃-N and/or TKN concentration produced by the facility during the last calendar year.

(1) NPDES Permit Concentration

| Permit Limit | Months | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------|---------|--|---------------|------------------------------|---------------|
| | | Dec-April | 10.0 | 30.0 | 2.0 |
| | May-Nov | 4.0 | 30.0 | 1.0 | 2.0 |

(2) DMR Concentration

| Qtr | Month | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------------|-----------|--|---------------|------------------------------|---------------|
| 1 | January | 0.74 | 0.69 | .003 | 0.27 |
| | February | 0.73 | 0.65 | 0.0 | 0.19 |
| | March | 0.80 | 1.35 | 0.0 | 0.25 |
| 2 | April | 0.57 | 0.72 | .002 | 0.22 |
| | May | 0.55 | 1.77 | 0.0 | 0.25 |
| | June | 0.60 | 1.42 | 0.0 | 0.29 |
| 3 | July | 0.78 | 0.88 | 0.0 | 0.23 |
| | August | 0.78 | 0.82 | 0.0 | 0.22 |
| | September | 0.73 | 1.36 | 0.0 | 0.33 |
| 4 | October | 0.70 | 1.21 | 0.0 | 0.37 |
| | November | 0.72 | 0.33 | 0.0 | 0.35 |
| | December | 0.82 | 0.56 | 0.062 | 0.30 |
| Annual Avg. | | 0.71 | 0.98 | 0.01 | 0.27 |

B. List the monthly average permit limit and DMR loadings below.

(1) NPDES Permit Loading

| Permit Limit | Months | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|-----------------|---------|---|------------------|---------------------------------|------------------|
| | May-Nov | 400 | 3002 | 100 | 200 |
| Dec-April | 1000 | 3002 | 200 | 400 | |

(2) DMR Loading

| Qtr | Month | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|--------------------|-----------|---|------------------|---------------------------------|------------------|
| 1 | January | 65 | 74 | 0.33 | 27 |
| | February | 75 | 65 | 0 | 19 |
| | March | 65 | 126 | 0 | 22 |
| 2 | April | 44 | 59 | 0.22 | 18 |
| | May | 38 | 125 | 0 | 17 |
| | June | 44 | 108 | 0 | 22 |
| 3 | July | 60 | 76 | 0 | 17 |
| | August | 66 | 65 | 0 | 18 |
| | September | 51 | 95 | 0 | 23 |
| 4 | October | 32 | 54 | 0 | 17 |
| | November | 38 | 21 | 0 | 18 |
| | December | 69 | 52 | 5.59 | 25 |
| Annual Avg. | | 54 | 77 | 0.51 | 20 |

C. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

D. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

E. During the past year did the effluent TSS concentration (mg/l) or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

F. During the past year did the TSS concentration (mg/l) and/or loading (lbs/day) exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

G. During the past year did the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

H. During the past year did either the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

I. Enter each point value checked for C through H in the blanks below.

C Points = 0

D Points = 0

E Points = 0

F Points = 0

G Points = 0

H Points = 0

HIGHEST INDIVIDUAL POINT VALUE FOR PART 2 (C-H) 0 (HIGHEST POINT = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Cahaba River WWTP

Part 4: Bypassing and Overflows

- A. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to heavy rain? 0
- B. How many bypass or overflow events of untreated wastewater occurred in the last year prior to the headworks of the WWTP due to heavy rain? 0
- C. How many of the bypass or overflow events listed in Parts A and B have been corrected such that future bypass or overflow events at the same location due to heavy rain are not anticipated? 0
- D. Add together Answers A and B and subtract Answer C from that total.
A + B - C = _____ (Check the appropriate point total.)
 0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points
- E. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to equipment failure? (This includes clogged/broken lines or manholes.) 0
- F. How many bypass or overflow events of untreated wastewater occurred in the last year due to equipment failure prior to the headworks of the WWTP? (This includes clogged/broken lines or manholes.) 16
- G. How many of the bypass or overflow events listed in Parts E and F have been corrected such that future bypass or overflow events at the same location due to the same equipment failure are not anticipated? 16
- H. Add together Answers E and F and subtract Answer G from that total.
E + F - G = _____ (Check the appropriate point total.)
 0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points
- I. Add point values circled in D and H and enter the total in the blank below.

TOTAL POINT VALUE FOR PART 4 0

Enter this value on Part 11: Summary Sheet.

All bypass or overflow events that have occurred in the last year (for any reason) must be individually reported with this MWPP report.

Facility Name: Cahaba River WWTP

Part 5: Sludge Quantity and Storage

- A. Please provide information concerning sludge quantity, characteristics, and storage practices based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.

- B. How many months of sludge storage capacity does the wastewater treatment facility have available, either on-site or off-site? (i.e., How many months can the facility operate without land spreading or disposing of sludge?) 4 months

(Check the appropriate point total.)

- Greater than or equal to 4 months = 0 points
- Less than 4 months, but greater than or equal to 3 months = 10 points
- Less than 3 months, but greater than or equal to 2 months = 20 points
- Less than 2 months, but greater than or equal to 1 month = 30 points
- Less than one month = 50 points

TOTAL POINT VALUE FOR PART 5 0
Enter this value on Part 11: Summary Sheet.

Part 6: Sludge Disposal Practices and Sites

- A. Please provide the sludge disposal practices and site information based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.

- B. How many months or years does the facility have access to and approval for sufficient land disposal sites to provide proper land disposal? (Check the appropriate point total.)

- 36 or more months = 0 points
- 24 - 35 months = 10 points
- 12 - 23 months = 20 points
- 6 - 11 months = 30 points
- Less than 6 months = 50 points

TOTAL POINT VALUE FOR PART 6 20
Enter this value on Part 11: Summary Sheet.

Facility Name: Cahaba River WWTP

Part 7: New Development

Are there any major new developments (industrial, commercial, or residential) in the last calendar year or anticipated in the next 2-3 years such that either flow or BOD₅ loadings to the sewage system could significantly increase? Estimate additional loadings below.

Design Population: _____ Design Flow: _____ MGD Design BOD₅: _____ lbs/day
Equivalent (PE)

List industrial and/or residential developments.

No major new development planned.

Will the additional loading overload the plant? (Check the appropriate point total.)

No = 0 points Yes = 121 points

Enter the point total in the blank below.

TOTAL POINT VALUE FOR PART 7 ⁰ _____ (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Part 8: Operator Certification

Complete the *Plant and Collection System Personnel Inventory*, ADEM Form 441.

Do both the plant operator and collection system staffing comply with ADEM Administrative Code; Division 10, Operator Certification Program? (Check the appropriate point total.)

Yes = 0 points No = 121 points

TOTAL POINT VALUE FOR PART 8 ⁰ _____ (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Cahaba River WWTP

Part 9: Financial Status

A. Are User-Charge Revenues sufficient to cover operation and maintenance expenses? If no, how are O&M costs being financed? ***Include user charge rates.***

Revenues are sufficient. The below values are based on a 5/8" meter and 6,000 gallons water use. Jefferson

County has a three tier block rate structure for residential users for 0-3, 4-6, and 7+ ccf water use.

Residential Minimum 15.00 Plus rate 6.02; 9.36; 10.69 /1,000 gal.

Industrial Minimum 15.00 Plus rate 10.51 /1,000 gal.

Monthly residential rate based on 6,000 gallons usage \$ 56.04 (includes 15% credit for residential)

****Please complete the above information based on your user charge rates for the report year. You may attach a sample water and sewer bill for clarity.***

B. What financial resources are available to pay for the wastewater improvements and/or reconstruction needs?

In 2013, Jefferson County issued Series 2013 Sewer Warrants that fund capital improvements

through 2023 at an annual average rate of \$71.9 million over the 10-year period.

Part 10: Subjective Evaluation

A. Describe briefly the physical and structural conditions of the wastewater treatment facility.

Most of the WWTP was upgraded or newly constructed in 2005 and is in good condition. Some

equipment and processes were constructed in the 1970s, 80s, and 90s and are in fair to average condition.

Maintenance and refurbishments are planned for assets needing improvements.

B. Describe the general condition of the sewer system (sewer lines, manholes, lift stations).

The Cahaba sewer system includes roughly 1,950,000' of pipe and 23 pump stations. The system's

performance is acceptable but showed a higher incidence of SSOs than desired. SSES investigations have

been completed, and repairs, replacements, and improvements are planned for summer 2014.

C. What sewage system improvements does the community have planned for construction in the next 5 years?

Cahaba River WWTP to Valley Creek WWTP Sludge Force Main; Repairs, replacements, and

collection system rehabilitation bidding summer 2014; (4) Hoover area pump station improvements;

Cahaba River WWTP Phase I (under construction) and Phase II TMDL Improvements.

D. What is the theoretical design life of the plant, and what is the estimated remaining useful life of the wastewater treatment facility?

The useful design life of structures is 50 years and associated mechanical and electrical equipment

is between 15-25 years. Most of the WWTP was upgraded or newly constructed in 2005.

The estimated remaining useful life is 42 years.

E. What problems, if any, over the last year have threatened treatment or conveyance within the system?

The SSOs in Cahaba in 2013 were primarily caused by blockages from grease.

The County is committed to reducing preventable SSOs through improved maintenance practices

and system renewal.

F. Is the community presently involved in formal planning for treatment facility upgrading?

No.

G. How many days in the last year were there residential backups at any point in the collection system for any reason other than clogging of the lateral connection? 19

H. Does the plant have a written plan for preventive maintenance on major equipment items? If yes, describe.

Yes. O & M Manuals are used for all equipment maintenance schedules. Preventive maintenance schedules are input into

the INFOR maintenance system and PM work orders are automatically generated. All equipment PM

schedules and records are maintained in the INFOR system.

- I. Does this preventive maintenance program depict frequency of intervals, types of lubrication, and other preventive maintenance tasks necessary for each piece of equipment? (Check the appropriate response.) Yes No
- J. Are these preventive maintenance tasks, as well as equipment problems, being recorded and filed so future maintenance problems can be assessed properly? (Check the appropriate response.) Yes No
- K. Describe any major repairs or mechanical equipment replacement made in the last year and include the approximate cost for those repairs. Do not include major treatment plant construction or upgrading programs.

UV Rebuild (2 Banks) \$133,128; UVT Analyzer \$17,000; Cerlic TSS Meter \$3,400;

Dewatering Press Gearboxes \$7,299; Al Seier Expansion Joint Replace \$9,000; A/C Blower Building \$6,000;

Dewatering Press Solids Meter \$2,400; BNR 25 HP Gear Box \$25,535

- L. List any additional comments. (Attach additional sheets if necessary.)

None

Facility Name: Cahaba River WWTP

Part 11: Summary Sheet

1. Enter in the values from Parts 1 through 8 in the left column below. Add the numbers in the left column to determine the MWPP Report point total the wastewater system generated for the previous calendar year.

| <u>Actual Values</u> | <u>Maximum Possible</u> |
|-------------------------|-------------------------|
| Part 1 <u>5</u> points | 80 points |
| Part 2 <u>0</u> points | 121 points |
| Part 3 <u>16</u> points | 40 points |
| Part 4 <u>0</u> points | 200 points |
| Part 5 <u>0</u> points | 50 points |
| Part 6 <u>20</u> points | 50 points |
| Part 7 <u>0</u> points | 121 points |
| Part 8 <u>0</u> points | 121 points |
| Total <u>41</u> points | 783 points |

2. Check the facility type that best describes the plant's treatment and disposal of wastewater.

- Mechanical plant with surface water discharge
- Aerated Lagoon or stabilization pond with surface water discharge
- Mechanical plant using land disposal of liquid wastes
- Aerated Lagoon or stabilization pond using land disposal of liquid wastes

3. Check the range that describes the action needed to address problems identified in the report.

- 0 - 70 pts. Actions as Appropriate*
- 71 - 120 pts. Departmental Recommendation Range*
- 121 - 783 Municipality Action Range*

***Other actions may be required by NPDES outside the scope of this report.**

4. Complete the *Municipal Water Pollution Prevention Resolution Form*, ADEM Form 418.

5. In Question 1, do any of the actual point values in the left column equal the maximum possible points in the right column? (Check the appropriate response) Yes No


If yes, provide a written explanation for this situation in the space below.

Cahaba River Wastewater Treatment Plant
ATTACHMENT 2 – Raw Sewage Bypass and

SUMMARY



CAHABA RIVER BASIN 2013 DISCHARGES



NOTE: OVERFLOWS SHOWN ARE OVER 10,000 GALLONS.

JEFFERSON COUNTY
ENVIRONMENTAL SERVICES
PLOTTED: 2-11-14



Summary of Unpermitted Discharges - Cahaba River

January 01, 2013 through December 31, 2013

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|------------------------------------|-------------------|--|-----------------|--------------|-----------------------------------|---------------|-----------------------|------------------|------------------------------|
| C01050 | 1/30/13 | 2650 Gresham Drive | Cahaba | Ground Absorbed | 312 | Manhole | Grease/ Rags | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01076 | 4/26/13 | 220 Summitt Blvd | Cahaba | Storm Drain | 4,698 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01077 | 4/30/13 | 2650 Gresham Dr | Cahaba | Little Shades Creek | 172 | Manhole | Grease/ Rags/ Rocks | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01086 | 8/9/13 | 2250 Sumpter St/ 2317 Dartmouth Dr | Cahaba | Ground Absorbed/ Storm Drain/ Huckleberry Branch | 36,052 | Manhole | Construction Damage/ Roots/ Rocks | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Construction crews working at Shades Mountain Elementary knocked the ring and lid off of the manhole causing sewer lines to be filled with gravel.</i> | | | | | | | | | | | |
| C01103 | 12/29/13 | 3701 Chestnut Ridge Place | Cahaba | Ground Absorbed | 1,080 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04325 | 1/14/13 | 105 Summitt Blvd (Summit PS) | Cahaba | Ground Absorbed | 340 | Pump Station | P.S. Equipment Failure | Moderate Rain | Pump Station Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: #2 pump cable was caught in the pump causing the main breaker to trip disabling both pumps. The breaker was reset which restored station and stopped overflow.</i> | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|----------------------|-------------------|---------------------------------|-----------------|----------|------------------------|---------------|----------------------|------------------|------------------------------|
| M04336 | 1/24/13 | 2240 Rocky Ridge Rd | Cahaba | Ground Absorbed | 1,048 | Manhole | Roots/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04370 | 3/11/13 | 2844 Regal Circle | Cahaba | Drainage Ditch/ Storm Drain | 112 | Manhole | Grease | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04374 | 3/18/13 | 2219 Avanti Lane | Cahaba | Hurricane Creek | 756 | Manhole | Debris/ Rags | Light Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04396 | 4/15/13 | 4830 Pinedale Way | Cahaba | Storm Drain | 678 | Cleanout | Roots | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04442 | 9/5/13 | 1760 Napier Dr | Cahaba | Ground Absorbed | 120 | Manhole | Grease/ Roots/ Rags | No Rain | Blockage Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04455 | 10/16/13 | 3224 Mockingbird Ln | Cahaba | Ground Absorbed | | Cleanout | Plug in the Line | No Rain | By-pass Pump Started | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Volume was not determinable.</i> | | | | | | | | | | | |
| M04470 | 11/26/13 | 3416 Water Oak Drive | Cahaba | Drainage Ditch/ Shades Creek | 4,550 | Cleanout | Debris | Heavy Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04478 | 11/29/13 | 2000 Montreat Pkwy | Cahaba | Storm Drain | 50 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|---------------|---------------|-------------------|-------------------|----------------------|-----------------|---------|---------------|---------------|------------------|------------------|------------------------------|
| M04481 | 12/3/13 | 1628 Stonewall Dr | Cahaba | Storm Drain | 3,625 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04499 | 12/21/13 | 3234 Tyrol Lane | Cahaba | Storm Drain | 250 | Manhole | Grease/ Roots | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |

Cahaba River Wastewater Treatment Plant

ATTACHMENT 3 – MWPP Sewage Sludge

SURVEY



2013 MWPP SEWAGE SLUDGE SURVEY

Facility Background Information:

1. Facility Information

Permit Number: AL0023027Name: Cahaba River Wastewater Treatment PlantStreet Address: 3900 Veona Daniels RoadCounty: Jefferson

2. Facility Contact

Name: Gary NelsonTitle: Plant ManagerTelephone: (205) 987-0648Permittee Name: Jefferson County CommissionMailing Address: Suite A-300, 716 Richard Arrington, Jr. Blvd. N.Birmingham, AL 35203

Facility Flow Information

1. Facility Wastewater Treatment Capacity

Avg. Daily Flow for 2012: 9.2 MGDFacility Design Capacity: 12.0 MGD

2. Estimated Septage Quantity Handled (Residuals Removed from Septic Tank Systems)

Average Domestic Septage: N/A gallons per monthAverage Commercial Septage: N/A gallons per month

3. Method of Septage Processing

 Mixed with Influent Wastewater for Treatment Mixed with Sewage Sludge N/A

4. Estimated Percentage Contributing Wastewater Flow

Residential: 90 %Industrial: %Other: 10 %Describe: Commercial

5. List type of wastewater treatment process(es) utilized at this facility:

Screening, Grit Removal, 5-Stage BNR Process, Clarification, Sand Filtration,
UV Disinfection

6. Estimated sewage sludge wasting rate at this facility:

or 105,816 lb/day dry weight
gallons per day

7. Estimated untreated sludge received from off site:

or N/A lb/day dry weight
gallons per day

8. Estimated percent solids of combined sewage sludge prior to treatment:

1.0 %

9. List the sewage sludge treatment processes used in preparing sludge for final use or disposal:

| | Sludge Quantity (untreated pounds per day) |
|---|---|
| Thickening | |
| Aerobic Digestion | |
| Mechanical Dewatering (Belt Filter Press) | |
| | |

10. Estimate the total volume of sludge generated:

1,207
 (dry U.S. tons per year)

Sludge Disposal Methods

1. Which of the following describes the current method of sewage sludge disposal for this facility:

| | Current Practices | | Quantity (dry U.S. tons/year) | Proposed Practices | |
|--|-------------------------------------|----|----------------------------------|-------------------------|----|
| | Approved by ADEM Yes | No | | Approved by ADEM Yes | No |
| a. <input checked="" type="checkbox"/> Land Application, Bulk Shipped | | | 1,207 | | |
| <input checked="" type="checkbox"/> Agriculture | <input checked="" type="checkbox"/> | | | | |
| <input type="checkbox"/> Forest | | | | | |
| <input type="checkbox"/> Public Contact | | | | | |
| <input type="checkbox"/> Lawn/Home Garden | | | | | |
| b. <input type="checkbox"/> Land Application, Bagged/Other Container | | | | | |
| <input type="checkbox"/> Agriculture | | | | | |
| <input type="checkbox"/> Forest | | | | | |
| <input type="checkbox"/> Public Contact | | | | | |
| <input type="checkbox"/> Lawn/Home Garden | | | | | |
| c. <input type="checkbox"/> Incineration | | | | | |
| d. <input type="checkbox"/> Subtitle D Landfill (Disposal Only) | | | | | |
| e. <input type="checkbox"/> Lined Treatment Lagoon or Stabilization Pond | | | | | |
| f. <input type="checkbox"/> Unlined Lagoon or Stabilization Pond | | | | | |
| g. <input type="checkbox"/> Other (Please Describe) | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

2. If "f" was selected above and sludge is stored for 2 or more years, enter the distance between the surface disposal site and the property line: N/A feet

Pollutant Concentrations:

1A. Enter the total concentrations of the following analytes using existing data. Do not enter TCLP results.
Flat Top/Bessie Mines Land Reclamation Site

| Analyte | Concentration (mg/kg or ppm) | Sample Type | Sample Date | Detection Level of Analysis (PQL), mg/kg |
|-------------------------|------------------------------|-------------|-------------|--|
| Arsenic | <PQL | GRAB | * | 11.0 |
| Cadmium | <PQL | GRAB | * | 5.0 |
| Chromium | 19.3 | GRAB | * | 6.0 |
| Copper | 426.7 | GRAB | * | 5.0 |
| Lead | <PQL | GRAB | * | 12.0 |
| Mercury | 1.2 | GRAB | * | 0.03 |
| Molybdenum | 8.1 | GRAB | * | 6.0 |
| Nickel | 20.0 | GRAB | * | 6.0 |
| Selenium | <PQL | GRAB | * | 12.0 |
| Zinc | 781.7 | GRAB | * | 8.0 |
| Ammonium-Nitrogen | N/A | N/A | * | N/A (.05) |
| Nitrate-Nitrogen | N/A | N/A | * | N/A (.05) |
| Total Kjeldahl Nitrogen | 49,333 | GRAB | * | 0.09 |

2. Enter the estimated or determined percent solids of the sewage sludge when sampled for the above analysis: 12 %

Treatment Provided for Sewage Sludge at the Facility

1. Which class of pathogen reduction does the sewage sludge meet at the facility? (As defined in 40 CFR Part 503)

- Class A
 - Alternative A1 - Time and Temperature
 - Alternative A2 - Alkaline Treatment
 - Alternative A3 - Analysis and Operation
 - Alternative A4 - Analysis Only
 - Alternative A5 - Processes to Further Reduce Pathogens (PFRP)
 - Heat Drying
 - Pasteurization
 - Composting
 - Thermophilic Aerobic Digestion
 - Gamma Ray Irradiation
 - Heat Treatment
 - Beta Ray Irradiation
 - Alternative A6 - PFRP Equivalent
- Class B
 - Alternative B1 - Fecal Coliform Count
 - Alternative B2 - Process to Significantly Reduce Pathogens (PSRP)
 - Aerobic Digestion
 - Air Drying
 - Anaerobic Digestion
 - Composting
 - Lime Stabilization
 - Alternative B3 - PSRP Equivalent
- Neither or Unknown

Vector Attraction Control

- Option 1 - Minimum 38% Reduction in Volatile Solids
- Option 2 - Anaerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 3 - Aerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 4 - Specific Oxygen Uptake Rate (SOUR) for Aerobically Digested Sludge
- Option 5 - Aerobic Processes plus Elevated Temperature
- Option 6 - Raised pH to 12 and Retained at 11.5
- Option 7 - 75% Solids with no Unstabilized Solids
- Option 8 - 90% Solids with Unstabilized Solids
- Option 9 - Injection Below Land Surface
- Option 10 - Incorporation into Soil within 6 or 8 Hours
- Option 11 - Covering Active Sewage Sludge Unit Daily
- None of the Above

Groundwater Monitoring

1. If disposal practice is surface disposal or land application, is groundwater monitoring required or performed at the site?

- Yes
- No

(If yes, please submit a copy of the groundwater monitoring reports along with this survey. Also please provide the approximate depth to groundwater and the groundwater monitoring procedures used to obtain the data.)

Land Application of Sewage Sludge

Answer the following questions if sewage sludge is applied to land.

1. If sewage sludge is land applied in bulk form, what type of crop or other vegetation is grown on this site?

Tifton Bermuda Grass, Ryegrass

2. If sewage sludge is land applied in bulk form, what is the nitrogen requirement for this crop or vegetation?

600 lb/acre/year (Reclamation Site)

3. If sewage sludge is land applied in bulk form, briefly describe the nature of any complaints filed from neighbors?

Note: Permittees that submitted the "Annual Report Review Form" for sludge to the EPA may submit a copy with the MWPP in lieu of this Attachment.

Cahaba River Wastewater Treatment Plant
ATTACHMENT 4 – Plant and Collection System
Personnel Inventory



PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Cahaba River WWTP

PLANT GRADE: IV

PERMIT NUMBER: AL0023027

PLANT SUPERINTENDENT: Gary Nelson

TEL. # (205) 987-0648

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|------------------|----------------------------|--------------|------------|
| 1. | Gary Nelson | IV | C003933 | 2/28/2016 |
| 2. | Jeremy Creel | IV | C001691 | 11/30/2015 |
| 3. | Derrick Brooks | IV | C001433 | 8/31/2016 |
| 4. | Tommy Carney | IV | C004047 | 9/30/2016 |
| 5. | Zada Nygren | IV | C003372 | 6/30/2015 |
| 6. | Bill Morrow | IV | C003750 | 12/31/2014 |
| 7. | Andrew Hudson | IV | C000779 | 11/30/2015 |
| 8. | Joe Willoughby | IV | C002615 | 9/30/2015 |
| 9. | Tommie Bradford | IV | C001269 | 8/31/2015 |
| 10. | Jonathan Gardner | IV | C007020 | 3/31/2015 |

COLLECTION SYSTEM OPERATORS:

| | | | |
|----|--|--|--|
| 1. | | | |
| 2. | | | |
| 3. | | | |
| 4. | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | 80 | 2 |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | 320 | 8 |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | 80 | 2 |
| OTHER PLANT WORKERS | 200 | 5 |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | |
|-----|---|
| 1ST | 9 |
| 2ND | 4 |
| 3RD | 4 |

| | |
|------------|------|
| START TIME | 700 |
| | 1500 |
| | 2300 |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | X | X | X | X | X | X | X |
| 2ND | X | X | X | X | X | X | X |
| 3RD | X | X | X | X | X | X | X |

ADEM USE ONLY

- DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
- DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|-----|----|
| | |
| | |

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Cahaba River WWTP

PLANT GRADE: IV

PERMIT NUMBER: AL0023027

PLANT SUPERINTENDENT: Gary Nelson

TEL. # (205) 987-0648

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|--------------------|----------------------------|--------------|-----------|
| 1. | Eddie Crumley | | | |
| 2. | Rodney Franklin | | | |
| 3. | Richard Hall | | | |
| 4. | Willie McClain | | | |
| 5. | Ernest Minniefield | | | |
| 6. | | | | |
| 7. | | | | |
| 8. | | | | |
| 9. | | | | |
| 10. | | | | |

COLLECTION SYSTEM OPERATORS:

| | | | |
|----|--|--|--|
| 1. | | | |
| 2. | | | |
| 3. | | | |
| 4. | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | | |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | | |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | 40 | 5 |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | |
|-----|--|
| 1ST | |
| 2ND | |
| 3RD | |

| | |
|------------|--|
| START TIME | |
| | |
| | |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | | | | | | | |
| 2ND | | | | | | | |
| 3RD | | | | | | | |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|-----|----|
| | |
| | |

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Sewer Line Maintenance

PLANT GRADE: IV

PERMIT NUMBER: _____

PLANT SUPERINTENDENT: _____

TEL. # (205) 540-7585

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|----------------|----------------------------|--------------|------------|
| 1. | Brian Champion | I (c) | C002094 | 6/30/2015 |
| 2. | Don Goodwin | I (c) | C005423 | 6/30/2015 |
| 3. | Lavon Evans | I (c) | C004631 | 12/31/2014 |
| 4. | Brian Rohling | I (c) | C005418 | 6/30/2015 |
| 5. | | | | |
| 6. | | | | |
| 7. | | | | |
| 8. | | | | |
| 9. | | | | |
| 10. | | | | |

COLLECTION SYSTEM OPERATORS:

| | | | | |
|----|--|--|--|--|
| 1. | | | | |
| 2. | | | | |
| 3. | | | | |
| 4. | | | | |

MANAGEMENT/SUPERVISOR

OPERATOR(S):

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | | |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | | |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | |
|-----|--|
| 1ST | |
| 2ND | |
| 3RD | |

| | |
|------------|--|
| START TIME | |
| | |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | | | | | | | |
| 2ND | | | | | | | |
| 3RD | | | | | | | |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| | YES | NO |
|----|-----|----|
| 1. | | |
| 2. | | |

Municipal Water Pollution Prevention (MWPP) Annual Report Calendar Year 2013

For the

Five Mile Creek WWTP

as required by the
Alabama Department of Environmental Management NPDES Program



Prepared by
Jefferson County Commission
Environmental Services Department

May 31, 2014

JEFFERSON COUNTY COMMISSION



DAVID CARRINGTON - PRESIDENT
GEORGE F. BOWMAN
SANDRA LITTLE BROWN - PRESIDENT PRO TEMPORE
T. JOE KNIGHT
JAMES A. "JIMMIE" STEPHENS

May 31, 2014

Mr. Nic Caraway, Water Division
Alabama Department of Environmental Management
Water Division – Municipal Branch
P.O. Box 301463
Montgomery, AL 36130-1463

RE: Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013

Mr. Caraway:

The Jefferson County Environmental Services Department submits the above referenced report for the Five Mile Creek Wastewater Treatment Facility, NPDES Permit No. AL0026913. Included is information as required in ADEM Form 41701/06ml, bypass/overflow event reports, MWPP Sewage Sludge Survey, and the Plant & Collection System Personnel Inventory.

If you have any questions regarding this information, please contact me at 205.325.5979 or Celeste Brown at Jefferson County Barton Laboratory at 205.238.3859.

Sincerely,

David Denard, Director
Environmental Services Department

pc: Celeste Brown, JCESD Barton Laboratory
Daniel White, JCESD Deputy Director
Lynn Jones, Five Mile Creek WWTP

DAVID CARRINGTON – COMMISSIONER
ENVIRONMENTAL SERVICES

TONY PETELOS, COUNTY MANAGER

Office of

DAVID DENARD
Director of Environmental Services
Suite A-300
716 Richard Arrington, Jr. Blvd. N.
Birmingham, Alabama 35203
Telephone (205) 325-5496
Fax (205) 325-5981

**MUNICIPAL WATER POLLUTION PREVENTION (MWPP)
ANNUAL REPORT**

SUBMITTED BY:

TREATMENT FACILITY: Five Mile Creek WWTP **NPDES #:** AL0026913

MUNICIPALITY: Jefferson County Commission **COUNTY:** Jefferson

CONTACT PERSON: David Denard

Municipal Official

Director of Environmental Services

Title

Telephone #: 205 - 325 - 5979 **Fax #:** 205 - 325 - 5239

Email Address: denardd@jccal.org

CHIEF OPERATOR: Lynn D. Jones, Plant Manager

Name

Telephone #: 205 - 841 - 5939 **Fax #:** 205 - 841 - 7698

Email Address: jonesly@jccal.org

Date: May 14, 2014

REVIEWED BY: Daniel White P.E., ESD Engineer

Consulting Engineer

Telephone #: 205 - 214 - 8610 **Fax #:** 205 - 325 - 5981

Date: May 14, 2014

**MWPP Annual Report
Information Source List**

The following information will be needed to complete the compliance maintenance report that covers the calendar year of 2013 (due **May 31,** 2014).

- Part 1
 - A. The average plant influent flow for each month (million gallons per day/MGD) during the year.
 - B. The average plant influent BOD (CBOD) for each month (mg/l and lb/day) in the year.
 - C. The plant's average design flow (MGD) and design BOD loading (lbs/day).

- Part 2
 - A. The monthly average permit and DMR effluent concentration for BOD (CBOD), TSS, NH3-N, and/or TKN in mg/l for the year
 - B. The monthly average effluent limits and DMR loading for BOD, TSS, NH3-N, and/or TKN in lbs/day for the year

- Part 3 The age of the treatment plant defined as the number of years since the last major reconstruction to increase the organic or hydraulic capacity of the plant. The last calendar year minus the year the new construction was brought on-line.

- Part 4 Bypass and overflow information. This is the number of bypass or overflow events of untreated wastewater due to heavy rain or equipment failure whether intentional or inadvertent from all collection systems tributary to the treatment facility.

- Part 5
 - A. Describe the characteristics and quantity of sludge generated.
 - B. If sludge is landspread, how many months of sludge storage does the plant have? This should include on-site and off-site storage from the treatment plant. The digester capacity may be used in the calculation.

- Part 6
 - A. Sludge Disposal Method
 - B. The number of approved land disposal sites for sludge available, and how many months or years these disposal sites will these be available for use.

- Part 7 The number of sewer extensions installed in the community last year--the design population, design flow, and design BOD for each sewer extension.

- Part 8 Operator Certification

- Part 9 Financial Status

- Part 10 Subjective Evaluation

- Part 11 Summary Sheet

State of Alabama
MWPP Annual Report
Department of Environmental Management

Instructions to the Operator-in-Charge

1. Complete all sections of the MWPP Report to the best of your ability.
2. Parts 1 through 8 contain questions for which points will be generated. These points are intended to communicate to the Department and the governing body or owner the actions necessary to prevent effluent violations. Enter the point totals from Parts 1 through 8 on Part 11: Summary Sheet.
3. Add the point totals on Part 11: Summary Sheet.
4. Submit the MWPP Report to the governing body and the consulting engineer and owner for review and approval.
5. The governing body should pass a resolution which contains the following points:
 - a. The resolution should acknowledge the governing body or owner has reviewed the MWPP Report.
 - b. The resolution should indicate what actions will be taken to prevent effluent violations.
 - c. The resolution should provide any other information the governing body or owner deems appropriate.
6. **The MWPP Report and the resolution must be submitted by May 31st to Municipal Section, Water Division, ADEM, P.O. Box 301463, Montgomery, AL 36130-1463.**

Facility Name: Five Mile Creek WWTP

Part 1: Influent Loading/Flows

A. List the average monthly volumetric flows and BOD₅ (CBOD₅) loadings received at your facility during the last calendar year.

| <u>Month</u> | <u>Column 1 Average Monthly Flowrate (MGD)</u> | <u>Column 2 Average Monthly BOD₅ (CBOD₅) Concentration (mg/l)</u> | <u>Column 3 Average Loading BOD₅ (CBOD₅) (lbs/day**)</u> |
|--------------------|--|---|--|
| January | 23 | 54 | 9274 |
| February | 23 | 60 | 10298 |
| March | 18 | 59 | 7885 |
| April | 17 | 60 | 8385 |
| May | 19 | 58 | 7760 |
| June | 14 | 95 | 11581 |
| July | 14 | 70 | 6823 |
| August | 14 | 65 | 7404 |
| September | 8.9 | 78 | 5597 |
| October | 7.3 | 84 | 5180 |
| November | 9.6 | 94 | 7184 |
| December | 17 | 60 | 8052 |
| Annual Avg. | 15 | 70 | 7952 |

**As reported on NPDES Discharge Monitoring Reports (DMRs) and as required by EPA's NPDES Self-Monitoring System, User Guide, March 1985.

B. List the average design flow and average design BOD₅ loading for the facility below. If you are not aware of these design quantities, contact your consulting engineer or the Alabama Department of Environmental Management.

| | <u>Average Design Flow</u> | <u>Average Design BOD₅ Loading (lbs/day)</u> |
|----------------------------|----------------------------|---|
| Design Criteria | 30MGD | 50,040 |
| 90% of the Design Criteria | 27 | 31,525 |

- C. How many times did the monthly flow (Column 1) to the WWTP exceed 90% of design flow?
 _____ (Check the appropriate point total)
 0 - 4 = 0 points 5 or more = 5 points
- D. How many times did the monthly flow (Column 1) to the WWTP exceed the design flow?
 _____ (Check the appropriate point total)
 0 = 0 points 1 - 2 = 5 points 3 - 4 = 10 points 5 or more = 15 points
- E. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed 90% of the design loading? _____ (Check the appropriate point total)
 0 - 1 = 0 points 2 - 4 = 5 points 5 or more = 10 points
- F. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed the design loading? _____ (Check the appropriate point total)
 0 = 0 points 1 = 10 points 2 = 20 points 3 = 30 points 4 = 40 points 5 or more = 50 points
- G. Enter each point value marked for C through F and enter the sum in the appropriate blank below.

C points = 0

D points = 0

E points = 0

F points = 0

TOTAL POINTS VALUE OR PART 1 0

Enter this value on Part 11: Summary Sheet.

*To obtain equivalent BOD₅ loading for comparison with design loading for those permittees using influent CBOD₅, divide annual average CBOD₅, loading in lbs/day from Part 1, A by 0.7.

Facility Name: Five Mile Creek WWTP

Part 2: Effluent Quality/Plant Performance

A. List the monthly average permit limits for the facility in the blanks below and the average monthly effluent DMR BOD₅, (CBOD₅) TSS, NH₃-N and/or TKN concentration produced by the facility during the last calendar year.

(1) NPDES Permit Concentration

| Permit Limit | Months | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------|--------------|--|---------------|------------------------------|---------------|
| | | May - Nov. | 6.0 | 30.0 | 2.0 |
| | Dec. - April | 7.0 | 30.0 | 2.5 | 5.0 |

(2) DMR Concentration

| Qtr | Month | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|-----|--------------------|--|---------------|------------------------------|---------------|
| 1 | January | 1.4 | 1.8 | 0.081 | 0.60 |
| | February | 0.95 | 1.9 | 0.035 | 0.35 |
| | March | 0.95 | 0.93 | 0.007 | 0.31 |
| 2 | April | 0.76 | 1.3 | 0.003 | 0.35 |
| | May | 0.72 | 1.3 | 0.008 | 0.36 |
| | June | 1.4 | 1.8 | 0.954 | 2.21 |
| 3 | July | 0.88 | 0.65 | 0.057 | 0.30 |
| | August | 0.69 | 0.34 | 0.003 | 0.27 |
| | September | 0.76 | 0.49 | 0.036 | 0.38 |
| 4 | October | 0.61 | 0.37 | 0.043 | 0.40 |
| | November | 0.63 | 0.60 | 0.022 | 0.37 |
| | December | 0.55 | 1.1 | 0.060 | 0.30 |
| | Annual Avg. | 0.86 | 1.0 | 0.11 | 0.52 |

B. List the monthly average permit limit and DMR loadings below.

(1) NPDES Permit Loading

| Permit Limit | Months | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|-----------------|------------|---|------------------|---------------------------------|------------------|
| | May - Nov. | 1501 | 7506 | 500 | 1000 |
| Dec. - April | 1751 | 7506 | 625 | 1251 | |

(2) DMR Loading

| Qtr | Month | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|--------------------|-----------|---|------------------|---------------------------------|------------------|
| 1 | January | 306 | 554 | 23 | 138 |
| | February | 179 | 352 | 6.6 | 64 |
| | March | 142 | 191 | 1.2 | 48 |
| 2 | April | 105 | 164 | 0.36 | 49 |
| | May | 109 | 256 | 0.79 | 52 |
| | June | 169 | 270 | 109 | 250 |
| 3 | July | 99 | 83 | 6.6 | 31 |
| | August | 79 | 35 | 0.22 | 31 |
| | September | 56 | 41 | 2.6 | 28 |
| 4 | October | 37 | 23 | 2.6 | 25 |
| | November | 54 | 57 | 2.4 | 31 |
| | December | 87 | 217 | 9.5 | 46 |
| Annual Avg. | | 119 | 187 | 14 | 66 |

C. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

D. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

E. During the past year did the effluent TSS concentration (mg/l) or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

F. During the past year did the TSS concentration (mg/l) and/or loading (lbs/day) exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

G. During the past year did the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

H. During the past year did either the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

I. Enter each point value checked for C through H in the blanks below.

C Points = 0

D Points = 0

E Points = 0

F Points = 0

G Points = 0

H Points = 0

HIGHEST INDIVIDUAL POINT VALUE FOR PART 2 (C-H) 0 (HIGHEST POINT = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Five Mile Creek WWTP

Part 4: Bypassing and Overflows

- A. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to heavy rain? 0
- B. How many bypass or overflow events of untreated wastewater occurred in the last year prior to the headworks of the WWTP due to heavy rain? 8
- C. How many of the bypass or overflow events listed in Parts A and B have been corrected such that future bypass or overflow events at the same location due to heavy rain are not anticipated? 2
- D. Add together Answers A and B and subtract Answer C from that total.
A + B - C = _____ (Check the appropriate point total.)
 0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
 7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points
- E. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to equipment failure? (This includes clogged/broken lines or manholes.) 0
- F. How many bypass or overflow events of untreated wastewater occurred in the last year due to equipment failure prior to the headworks of the WWTP? (This includes clogged/broken lines or manholes.) 17
- G. How many of the bypass or overflow events listed in Parts E and F have been corrected such that future bypass or overflow events at the same location due to the same equipment failure are not anticipated? 17
- H. Add together Answers E and F and subtract Answer G from that total.
E + F - G = _____ (Check the appropriate point total.)
 0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
 7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points
- I. Add point values circled in D and H and enter the total in the blank below.

TOTAL POINT VALUE FOR PART 4 30
Enter this value on Part 11: Summary Sheet.

All bypass or overflow events that have occurred in the last year (for any reason) must be individually reported with this MWPP report.

Facility Name: Five Mile Creek WWTP

Part 5: Sludge Quantity and Storage

- A. Please provide information concerning sludge quantity, characteristics, and storage practices based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.

- B. How many months of sludge storage capacity does the wastewater treatment facility have available, either on-site or off-site? (i.e., How many months can the facility operate without land spreading or disposing of sludge?) 4 months

(Check the appropriate point total.)

- Greater than or equal to 4 months = 0 points
- Less than 4 months, but greater than or equal to 3 months = 10 points
- Less than 3 months, but greater than or equal to 2 months = 20 points
- Less than 2 months, but greater than or equal to 1 month = 30 points
- Less than one month = 50 points

TOTAL POINT VALUE FOR PART 5 0
Enter this value on Part 11: Summary Sheet.

Part 6: Sludge Disposal Practices and Sites

- A. Please provide the sludge disposal practices and site information based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.

- B. How many months or years does the facility have access to and approval for sufficient land disposal sites to provide proper land disposal? (Check the appropriate point total.)

- 36 or more months = 0 points
- 24 - 35 months = 10 points
- 12 - 23 months = 20 points
- 6 - 11 months = 30 points
- Less than 6 months = 50 points

TOTAL POINT VALUE FOR PART 6 20
Enter this value on Part 11: Summary Sheet.

Facility Name: Five Mile Creek WWTP

Part 7: New Development

Are there any major new developments (industrial, commercial, or residential) in the last calendar year or anticipated in the next 2-3 years such that either flow or BOD₅ loadings to the sewage system could significantly increase? Estimate additional loadings below.

Design Population: _____ Design Flow: _____ MGD Design BOD₅: _____ lbs/day
Equivalent (PE)

List industrial and/or residential developments.

No major new developments planned.

Will the additional loading overload the plant? (Check the appropriate point total.)

No = 0 points Yes = 121 points

Enter the point total in the blank below.

TOTAL POINT VALUE FOR PART 7 0 (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Part 8: Operator Certification

Complete the *Plant and Collection System Personnel Inventory*, ADEM Form 441.

Do both the plant operator and collection system staffing comply with ADEM Administrative Code; Division 10, Operator Certification Program? (Check the appropriate point total.)

Yes = 0 points No = 121 points

TOTAL POINT VALUE FOR PART 8 0 (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Five Mile Creek WWTP

Part 9: Financial Status

A. Are User-Charge Revenues sufficient to cover operation and maintenance expenses? If no, how are O&M costs being financed? ***Include user charge rates.***

Revenues are sufficient. The below values are based on a 5/8" meter and 6,000 gallons water use. Jefferson

County has a three tier block rate structure for residential users for 0-3, 4-6, and 7+ ccf water use.

Residential Minimum 15.00 Plus rate 6.02; 9.36; 10.69 /1,000 gal.

Industrial Minimum 15.00 Plus rate 10.51 /1,000 gal.

Monthly residential rate based on 6,000 gallons usage \$ 56.04 (includes 15% credit for residential)

****Please complete the above information based on your user charge rates for the report year. You may attach a sample water and sewer bill for clarity.***

B. What financial resources are available to pay for the wastewater improvements and/or reconstruction needs?

In 2013, Jefferson County issued Series 2013 Sewer Warrants that fund capital improvements

through 2023 at an annual average rate of \$71.9 million over the 10-year period.

Part 10: Subjective Evaluation

A. Describe briefly the physical and structural conditions of the wastewater treatment facility.

Most of the WWTP was upgraded or newly constructed in 2008 and is in good condition. Some

equipment and processes were constructed in the 1970s, 80s, and 90s and are in fair to average condition.

Maintenance and refurbishments are planned for assets needing improvements.

B. Describe the general condition of the sewer system (sewer lines, manholes, lift stations).

The Five Mile sewer system includes roughly 2,250,000' of pipe and 30 pump stations. The system's

performance is below the expectations of the County. SSES investigations and repairs and replacements

are planned.

C. What sewage system improvements does the community have planned for construction in the next 5 years?

Sewer condition assessment and sewer line repair, replacement, and renewal projects.

Backup power generators are planned for Dean Drive and Don Berri Apartment pump stations.

Pump replacements are planned for Newfound #1 and Newfound #2 pump stations.

D. What is the theoretical design life of the plant, and what is the estimated remaining useful life of the wastewater treatment facility?

Calculated remaining useful life of the structures is 45 years (50 years - 5 years age of facility).

Calculated remaining useful life of the equipment is 20 years (25 years - 5 years of equipment).

Based on EPA's 2002 Clean Water and Drinking Water Infrastructure Gap Analysis Report.

E. What problems, if any, over the last year have threatened treatment or conveyance within the system?

See attached Form 421 for May 2013 concerning an operator error that caused a SSO.

Extended rainfall between January 13-15 produced three large SSOs in the collection system.

F. Is the community presently involved in formal planning for treatment facility upgrading?

No.

G. How many days in the last year were there residential backups at any point in the collection system for any reason other than clogging of the lateral connection? 16

H. Does the plant have a written plan for preventive maintenance on major equipment items? If yes, describe.

Yes. Our INFOR maintenance program generates work orders for scheduled preventive maintenance. This is backed up

by written records of scheduled service provided for each piece of equipment by our maintenance shop.

C. What sewage system improvements does the community have planned for construction in the next 5 years?

Sewer condition assessment and sewer line repair, replacement, and renewal projects.

Improvements to Newfound, Cunningham, and Penefield pump stations.

D. What is the theoretical design life of the plant, and what is the estimated remaining useful life of the wastewater treatment facility?

Calculated remaining useful life of the structures is 45 years (50 years - 5 years age of facility).

Calculated remaining useful life of the equipment is 20 years (25 years - 5 years of equipment).

Based on EPA's 2002 Clean Water and Drinking Water Infrastructure Gap Analysis Report.

E. What problems, if any, over the last year have threatened treatment or conveyance within the system?

See attached Form 421 for May 2013 concerning an operator error that caused a SSO.

Extended rainfall between January 13-15 produced three large SSOs in the collection system.

F. Is the community presently involved in formal planning for treatment facility upgrading?

No.

G. How many days in the last year were there residential backups at any point in the collection system for any reason other than clogging of the lateral connection? 16

H. Does the plant have a written plan for preventive maintenance on major equipment items? If yes, describe.

Yes. Our INFOR maintenance program generates work orders for scheduled preventive maintenance. This is backed up

by written records of scheduled service provided for each piece of equipment by our maintenance shop.

ALABAMA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
 WATER DIVISION – INDUSTRIAL AND MUNICIPAL SECTIONS
NONCOMPLIANCE NOTIFICATION FORM

PERMITTEE NAME: Five Mile Creek WWTP PERMIT NO: AL0026913

FACILITY LOCATION: 3410 Happy Hollow Lane Fultondale, AL 35068

DMR REPORTING PERIOD: May 2013

1. DESCRIPTION OF DISCHARGE: (Include outfall number (s)): Signs of a previous overflow was discovered, Monday, May 6, 2013, at Junction Box 23 (2000-024) on the sewer main to Five Mile Creek WWTP. On further inspection manhole 2000-012 also showed signs of a previous overflow. After discovery, a SSO advisory was made for Five Mile Creek. The SSO event is assumed to have occurred for 45 minutes on Saturday, May 4, 2013 sometime between 11:00 am and 12:00 pm with an assumed height of 1 inch based on observations and actions by the WWTP staff. The combined estimated volume of the SSOs is calculated to be approximately 45,000 gallons. The actual height of the SSO for use in the volume calculation is unknown and is indeterminable since it was not observed. The actual volume of the SSO may have been more or less than estimated and reported in this document.

2. DESCRIPTION OF NON-COMPLIANCE: (Attach additional pages if necessary):

| Outfall Number (s) | NONCOMPLIANCE PARAMETER(S) | Result Reported (Include units) | Permit Limit (Include units) |
|---|----------------------------|--|------------------------------|
| | SSO | | |
| | | | |
| | | | |
| LIST MONITORING / REPORTING VIOLATIONS (If applicable) | | | |
| Outfall Number (s) | NONCOMPLIANCE PARAMETER(S) | Monitoring / Reporting Violation (Provide description) | |
| | N/A | | |
| | | | |

3. CAUSE OF NON-COMPLIANCE (Attach additional pages if necessary): After investigation of the treatment plant's weekend operations it is believed that a sudden change in operations on May 4, 2013 around 11:00am caused an SSO prior to the headworks. The operators on duty, Tony Sutton and Mark Cruce, fearing what they considered a drastic increase in flow that could cause damage to the facility temporarily closed the influent gate for a few minutes from its set position of 25% to 5% of its open capacity to allow the Influent Pump wet well level to lower before flooding. The operators then opened a valve that allowed the water in the trunk sewer to flow into the plant's peak flow basins. The influent gate was then raised to higher position. About 12:00 pm both operators knowing that the gate being lowered to 5% open could cause a SSO on the sewer main, drove to the entrance gate where they could visibly see if the junction box (located across Coalburg Road) had or was overflowing. They both saw no sewage overflowing from the box.

The actions of the operators on Saturday were in direct conflict with written instructions for high flow events and training and instruction provided to the operational staff. The operators over reacted to increasing flow and lowered the gate to a level that was unnecessary and overprotective of the WWTP.

4. PERIOD OF NONCOMPLIANCE: (Include exact date(s) and time(s) or, if not corrected, the anticipated time the noncompliance is expected to continue): There is not an exact time to apply to this event. An approximation based on the statements by the operators and their visual inspection of the overflow area was used. The influent gate was recorded as being closed on May 4, 2013, between 11:00am and 12:00pm, from 25% to 15%. The operator Mark Cruce stated that the gate was initially closed to 5% and was opened minutes after closing when the threat to flooding had subsided. They then continued to open it until it was 15% by 12:00, noon. They also, between 11:00am and 12:00pm, opened the effluent valve allowing flow in the trunk line to flow into the aerated holding basins. They drove to the entrance gate to see if the box was overflowing. It was not overflowing. For the purpose of volume estimation calculations, the estimated time of the over flow is considered 45 minutes.

5. DESCRIPTION OF STEPS TAKEN AND/OR BEING TAKEN TO REDUCE OR ELIMINATE THE NONCOMPLYING DISCHARGE AND TO PREVENT ITS RECURRENCE (attach additional pages if necessary): Both operators will undergo a performance appraisal that could lead to disciplinary actions for not following written procedures for operation. There would not have been an SSO if the written procedures had been followed.

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Lynn D. Jones, Plant Manager Five Mile Creek
NAME AND TITLE OF RESPONSIBLE OFFICIAL (type or print)

 05/09/2013
SIGNATURE OF RESPONSIBLE OFFICIAL / DATE SIGNED

ADEM Form 421 11/06 m2

I. Does this preventive maintenance program depict frequency of intervals, types of lubrication, and other preventive maintenance tasks necessary for each piece of equipment? (Check the appropriate response.) Yes No

J. Are these preventive maintenance tasks, as well as equipment problems, being recorded and filed so future maintenance problems can be assessed properly? (Check the appropriate response.) Yes No

K. Describe any major repairs or mechanical equipment replacement made in the last year and include the approximate cost for those repairs. Do not include major treatment plant construction or upgrading programs.

One 50 HP ECO-JET I aerator replacement in the aerated holding basin for \$13,737.00.

L. List any additional comments. (Attach additional sheets if necessary.)

Facility Name: Five Mile Creek WWTP

Part 11: Summary Sheet

1. Enter in the values from Parts 1 through 8 in the left column below. Add the numbers in the left column to determine the MWPP Report point total the wastewater system generated for the previous calendar year.

| <u>Actual Values</u> | <u>Maximum Possible</u> |
|-------------------------|-------------------------|
| Part 1 <u>0</u> points | 80 points |
| Part 2 <u>0</u> points | 121 points |
| Part 3 <u>10</u> points | 40 points |
| Part 4 <u>30</u> points | 200 points |
| Part 5 <u>0</u> points | 50 points |
| Part 6 <u>20</u> points | 50 points |
| Part 7 <u>0</u> points | 121 points |
| Part 8 <u>0</u> points | 121 points |
| Total <u>60</u> points | 783 points |

2. Check the facility type that best describes the plant's treatment and disposal of wastewater.

- Mechanical plant with surface water discharge
- Aerated Lagoon or stabilization pond with surface water discharge
- Mechanical plant using land disposal of liquid wastes
- Aerated Lagoon or stabilization pond using land disposal of liquid wastes

3. Check the range that describes the action needed to address problems identified in the report.

- 0 - 70 pts. Actions as Appropriate*
- 71 - 120 pts. Departmental Recommendation Range*
- 121 - 783 Municipality Action Range*

***Other actions may be required by NPDES outside the scope of this report.**

4. Complete the *Municipal Water Pollution Prevention Resolution Form*, ADEM Form 418.

5. In Question 1, do any of the actual point values in the left column equal the maximum possible points in the right column? (Check the appropriate response) Yes No

If yes, provide a written explanation for this situation in the space below.


Five Mile Creek Wastewater Treatment Plant

ATTACHMENT 2 – Raw Sewage Bypass and

SUMMARY



FIVE MILE CREEK BASIN 2013 DISCHARGES



NOTE: OVERFLOWS SHOWN ARE OVER 10,000 GALLONS.

JEFFERSON COUNTY
ENVIRONMENTAL SERVICES
PLOTTED: 2-11-14



Summary of Unpermitted Discharges - Five Mile Creek

January 01, 2013 through December 31, 2013

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-----------|---------------|--|---|---|-----------------|-----------------------|---------------------|------------|------------------|------------------|------------------------------|
| C01037 | 1/14/13 | 1220 Sweetwater Cir | Five Mile - Upstream of Barton Branch | Drainage Ditch/ Feeder Creek to Five Mile Creek | 483,075 | Manhole | Surcharge from Rain | Light Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| C01038 | 1/15/13 | 1908 & 1919 East Lawson Drive | Five Mile - Upstream of Barton Branch | Five Mile Creek | 4,173,248 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| C01040 | 1/15/13 | 532 Decatur Hwy | Five Mile - Downstream of Barton Branch (Remainder of System) | Drainage Ditch | 200,535 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| C01041 | 1/15/13 | 3410 Happy Hollow Lane/ 3330 Coalburg Rd | Five Mile - Downstream of Barton Branch (Remainder of System) | Five Mile Creek | 1,020,000 | Manhole/ Junction Box | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| C01048 | 1/28/13 | 536 Decatur Hwy | Five Mile - Downstream of Barton Branch (Remainder of System) | Ground Absorbed/ Drainage Ditch | 182 | Manhole | Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|----------------------------|---|----------------------------------|-----------------|-------------|---------------------|---------------|------------------------------|------------------|------------------------------|
| C01065 | 2/26/13 | 1908 & 1919 East Lawson Dr | Five Mile - Upstream of Barton Branch | Five Mile Creek | 217,665 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01066 | 2/26/13 | 1220 Sweetwater Cir | Five Mile - Upstream of Barton Branch | Feeder Creek to Five Mile Creek | 8,500 | Manhole | Surcharge from Rain | Moderate Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01069 | 3/8/13 | 989 Huffman Road | Five Mile - Upstream of Barton Branch | Drainage Ditch/ Storm Drain | | Combo Truck | Vacuum Truck | No Rain | Washed Street Down | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Debris body was not latched all the way on the vacuum truck allowing sewage to leak out.</i> | | | | | | | | | | | |
| C01074 | 3/29/13 | 2110 Willow Glenn Drive | Five Mile - Upstream of Barton Branch | Drainage Ditch | 43,342 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01079 | 5/6/13 | 3330/ 3331 Coalburg Rd | Five Mile - Downstream of Barton Branch (Remainder of System) | Five Mile Creek | 45,000 | Manhole | Operator Error | Heavy Rain | Operations Corrected at WWTP | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01080 | 5/18/13 | 1908 & 1919 East Lawson Dr | Five Mile - Upstream of Barton Branch | Five Mile Creek | 584,508 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01081 | 6/10/13 | 1919 East Lawson Drive | Five Mile - Upstream of Barton Branch | Ground Absorbed/ Five Mile Creek | 236,052 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|---|---------------|---------------------------|---|------------------------------------|-----------------|---------|---------------------|------------|------------------|------------------|------------------------------|
| C01083 | 6/13/13 | 1664 Lake Dr NE | Five Mile - Upstream of Barton Branch | Ground Absorbed/ Drainage Ditch | 71 | Manhole | Roots | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01087 | 8/19/13 | 1910 Center Point Parkway | Five Mile - Upstream of Barton Branch | Storm Drain | 440 | Manhole | Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01088 | 8/24/13 | 1800 Center Point Parkway | Five Mile - Upstream of Barton Branch | Ground Absorbed | 360 | Manhole | Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01098 | 10/2/13 | 1734 Brewster Rd | Five Mile - Upstream of Barton Branch | Drainage Ditch | 8,000 | Manhole | Grease/ Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04315 | 1/8/13 | 5012 41st Way N | Five Mile - Downstream of Barton Branch (Remainder of System) | Ground Absorbed | | Pipe | Gravity Main Break | No Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: While jetwashing sanitary sewer line, sewage sprayed from hole in ground where gravity main pipe was broken. Volume not determinable.</i> | | | | | | | | | | | |
| M04387 | 4/5/13 | 4010 49th Crt N | Five Mile - Downstream of Barton Branch (Remainder of System) | Storm Drain | 169 | Manhole | Grease | Light Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04412 | 5/5/13 | 1432 Bobolink Lane | Five Mile - Upstream of Barton Branch | Ground Absorbed | 86 | Manhole | Grease/ Roots/ Rags | Light Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|---------------------|---|--|-----------------|----------|----------------------|---------------|----------------------------|------------------|------------------------------|
| M04419 | 5/22/13 | 1113 Elm Ave | Five Mile - Downstream of Barton Branch (Remainder of System) | Ground Absorbed | 500 | Pipe | Gravity Main Break | No Rain | Blockage Removed/ Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Power company</i> | | | | | | | | | | | |
| M04422 | 5/30/13 | 377 Sunbrook Ave | Five Mile - Upstream of Barton Branch | Ground Absorbed | 55 | Cleanout | Grease/ Roots/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04424 | 6/6/13 | 805 Jeffery Circle | Five Mile - Upstream of Barton Branch | Ground Absorbed/ Feeder Creek to Five Mile Creek | | Cleanout | Grease/ Debris/ Rags | Light Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Volume was not determinable. Cleanout not overflowing upon crew arrival, but there was evidence.</i> | | | | | | | | | | | |
| M04432 | 7/11/13 | 400 Old Farm Dr | Five Mile - Upstream of Barton Branch | Ground Absorbed | 2,700 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04479 | 12/1/13 | 1139 Ware Blvd | Five Mile - Upstream of Barton Branch | Ground Absorbed | 96 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04480 | 12/2/13 | 1205 Five Mile Road | Five Mile - Upstream of Barton Branch | Drainage Ditch/ Feeder to Five Mile Creek | 312 | Manhole | Grease/ Rags | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04490 | 12/13/13 | 9817 Maple Ln | Five Mile - Upstream of Barton Branch | Storm Drain | 180 | Manhole | Grease/ Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| <i>Event No.</i> | <i>Date Reported</i> | <i>Location</i> | <i>Collection System</i> | <i>Ultimate Destination</i> | <i>Est. Vol. (gal)</i> | <i>Source</i> | <i>Cause</i> | <i>Weather</i> | <i>Action Taken</i> | <i>Person Reporting</i> | <i>Title</i> |
|------------------|----------------------|------------------|---|-----------------------------|------------------------|---------------|---------------|----------------|---------------------|-------------------------|------------------------------------|
| M04500 | 12/26/13 | 517 Montrose Cir | Five Mile - Upstream of Barton Branch | Drainage Ditch | 666 | Manhole | Grease/ Roots | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |

Notes:

Five Mile Creek Wastewater Treatment Plant

ATTACHMENT 3 – MWPP Sewage Sludge

SURVEY



MWPP SEWAGE SLUDGE SURVEY

Facility Background Information:

| | | |
|-------------------------|---|------------------|
| 1. Facility Information | Permit Number: | <u>AL0026913</u> |
| Name: | <u>Five Mile Creek WWTP</u> | |
| Street Address: | <u>3410 Happy Hollow Lane Fultondale, Alabama 35068</u> | |
| County: | <u>Jefferson County</u> | |
| 2. Facility Contact | | |
| Name: | <u>Lynn D. Jones</u> | |
| Title: | <u>Plant Manager</u> | |
| Telephone: | <u>205 - 841 - 5939</u> | |
| Permittee Name: | <u>Jefferson County Commission</u> | |
| Mailing Address: | <u>Environmental Services Department Suite A-300</u> | |
| | <u>716 Richard Arrington Jr. Blvd. N. Birmingham, Alabama 35203</u> | |

Facility Flow Information

| | | | |
|--|--|-------------------|-----------------------------|
| 1. Facility Wastewater Treatment Capacity | | | |
| Avg. Daily Flow for 2000 : <u>2013</u> | <u>15.3</u> | MGD | |
| Facility Design Capacity: | <u>30.0</u> | MGD | |
| 2. Estimated Septage Quantity Handled (Residuals Removed from Septic Tank Systems) | | | |
| Average Domestic Septage: | <u>N/A</u> | gallons per month | |
| Average Commercial Septage: | <u>N/A</u> | gallons per month | |
| 3. Method of Septage Processing | | | |
| | <u>Mixed with Influent Wastewater for Treatment</u> | | |
| | <u>Mixed with Sewage Sludge</u> | | |
| | <u>N/A</u> | | |
| 4. Estimated Percentage Contributing Wastewater Flow | | | |
| Residential: | <u>93</u> | % | |
| Industrial: | <u>2</u> | % | |
| Other: | <u>5</u> | % | Describe: <u>COMMERCIAL</u> |
| 5. List type of wastewater treatment process(es) utilized at this facility: | | | |
| | <u>Screening, grit removal, aeration with activated sludge, clarification, sandfiltration,</u> | | |
| | <u>UV disinfection</u> | | |
| 6. Estimated sewage sludge wasting rate at this facility: | | | |
| | <u>41019</u> | lb/day dry weight | |
| | or _____ | gallons per day | |
| 7. Estimated untreated sludge received from off site: | | | |
| | <u>N/A</u> | lb/day dry weight | |
| | or _____ | gallons per day | |
| 8. Estimated percent solids of combined sewage sludge prior to treatment: | | | |
| | <u>4.1</u> | % | |

9. List the sewage sludge treatment processes used in preparing sludge for final use or disposal:

| | Sludge Quantity (untreated pounds per day) |
|--------------------------|---|
| Aerobic Digestion | _____ |
| Thickening | _____ |
| Drying Beds (air drying) | _____ |
| _____ | _____ |

10. Estimate the total volume of sludge generated:

1021
_____ (dry U.S. tons per year)

Sludge Disposal Methods

1. Which of the following describes the current method of sewage sludge disposal for this facility:

| | Current Practices | | Quantity (dry U.S. tons/year) | Proposed Practices | |
|---|-------------------|----|----------------------------------|--------------------|----|
| | Approved by ADEM | | | Approved by ADEM | |
| | Yes | No | | Yes | No |
| a. Land Application, Bulk Shipped | | | 1021 | | |
| X Agriculture | | | _____ | X | |
| Forest | | | _____ | | |
| Public Contact | | | _____ | | |
| Lawn/Home Garden | | | _____ | | |
| b. Land Application, Bagged/Other Container | | | _____ | | |
| Agriculture | | | _____ | | |
| Forest | | | _____ | | |
| Public Contact | | | _____ | | |
| Lawn/Home Garden | | | _____ | | |
| c. Incineration | | | _____ | | |
| d. Subtitle D Landfill (Disposal Only) | | | _____ | | |
| e. Lined Treatment Lagoon or Stabilization Pond | | | _____ | | |
| f. Unlined Lagoon or Stabilization Pond | | | _____ | | |
| g. Other (Please Describe) | | | _____ | | |
| _____ | | | _____ | | |
| _____ | | | _____ | | |

2. If "f" was selected above and sludge is stored for 2 or more years, enter the distance between the surface disposal site and the property line: _____ feet

Pollutant Concentrations

1. Enter the total concentrations of the following analytes using existing data. Do not enter TCLP results.

| Analyte | Concentration (mg/kg or ppm) | Sample Type | Sample Date | Detection Level of Analysis |
|-------------------------|------------------------------|-------------|-------------|-----------------------------|
| Arsenic | <PQL | grab | * | 11.0 |
| Cadmium | <PQL | grab | * | 8.0 |
| Chromium | 60.8 | grab | * | 8.0 |
| Copper | 371.7 | grab | * | 8.0 |
| Lead | 37.7 | grab | * | 15.0 |
| Mercury | 1.7 | grab | * | 0.6 |
| Molybdenum | <PQL | grab | * | 5.0 |
| Nickel | 49.0 | grab | * | 6.0 |
| Selenium | <PQL | grab | * | 15.0 |
| Zinc | 3,016.7 | grab | * | 18.0 |
| Ammonium-Nitrogen | N/A | N/A | N/A | N/A |
| Nitrate-Nitrogen | N/A | N/A | N/A | N/A |
| Total Kjeldahl Nitrogen | 39,333 | grab | * | 1.8 |

2. Enter the estimated or determined percent solids of the sewage sludge when sampled for the above analysis: 84 %

Treatment Provided for Sewage Sludge at the Facility

1. Which class of pathogen reduction does the sewage sludge meet at the facility? (As defined in 40 CFR Part 503)

Class A

Alternative A1 - Time and Temperature

Alternative A2 - Alkaline Treatment

Alternative A3 - Analysis and Operation

Alternative A4 - Analysis Only

Alternative A5 - Processes to Further Reduce Pathogens (PFRP)

Heat Drying

Thermophilic Aerobic Digestion

Heat Treatment

Pasteurization

Gamma Ray Irradiation

Beta Ray Irradiation

Composting

Alternative A6 - PFRP Equivalent

X Class B

X Alternative B1 - Fecal Coliform Count

X Alternative B2 - Process to Significantly Reduce Pathogens (PSRP)

X Aerobic Digestion

X Air Drying

Anaerobic Digestion

Composting

Lime Stabilization

Alternative B3 - PSRP Equivalent

Neither or Unknown

Vector Attraction Control

- Option 1 - Minimum 38% Reduction in Volatile Solids
- Option 2 - Anaerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 3 - Aerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 4 - Specific Oxygen Uptake Rate (SOUR) for Aerobically Digested Sludge
- Option 5 - Aerobic Processes plus Elevated Temperature
- Option 6 - Raised pH to 12 and Retained at 11.5
- Option 7 - 75% Solids with no Unstabilized Solids
- Option 8 - 90% Solids with Unstabilized Solids
- Option 9 - Injection Below Land Surface
- Option 10 - Incorporation into Soil within 6 or 8 Hours
- Option 11 - Covering Active Sewage Sludge Unit Daily
- None of the Above

Groundwater Monitoring

1. If disposal practice is surface disposal or land application, is groundwater monitoring required or performed at the site?

- Yes (If yes, please submit a copy of the groundwater monitoring reports along with this survey. Also please provide the approximate depth to groundwater and the groundwater monitoring procedures used to obtain the data.)
- No

Land Application of Sewage Sludge

Answer the following questions if sewage sludge is applied to land.

1. If sewage sludge is land applied in bulk form, what type of crop or other vegetation is grown on this site?

Tifton Bermuda Grass and Rye Grass.

2. If sewage sludge is land applied in bulk form, what is the nitrogen requirement for this crop or vegetation?

The nitrogen requirement is 600lbs / acre / year.

3. If sewage sludge is land applied in bulk form, briefly describe the nature of any complaints filed from neighbors?

No complaints have been filed.

Note: Permittees that submitted the "Annual Report Review Form" for sludge to the EPA may submit a copy with the MWPP in lieu of this Attachment.

Five Mile Creek Wastewater Treatment Plant
ATTACHMENT 4 – Plant and Collection System
Personnel Inventory



PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Five Mile Creek WWTP PLANT GRADE: IV
 PERMIT NUMBER: AL0026913
 PLANT MANAGER: Lynn Jones TEL. # (205) 841-5939
 SYSTEM MANAGER David Denard TEL. # (205) 325-5806

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|----|--------------------|----------------------------|--------------|------------|
| 1 | Lynn Jones | Plant Manager | C003327 | 9/30/2014 |
| 2 | Robert Tyler | Shift Supervisor | C003008 | 11/30/2015 |
| 3 | Randy Maxwell | Shift Supervisor | C003076 | 11/30/2015 |
| 4 | Terry Joe MaHaffey | Shift Supervisor | C003135 | 8/31/2016 |
| 5 | Tony Sutton | Shift Supervisor | C002294 | 11/30/2015 |
| 6 | Mark Cruce | Operator II | C001682 | 3/31/2015 |
| 7 | Adam Smith | Operator II | C002236 | 4/30/2016 |
| 8 | Daniel Tesseneer | Operator II | C006050 | 6/30/2014 |
| 9 | Ellis Brown | Operator I | | |
| 10 | Sam Shears | Operator I | | |
| 11 | Todd Smitherman | Operator I | | |
| 12 | Michael Wright | Operator I | | |

| | MAN HRS./WK NUMBER | |
|-----------------------|--------------------|---|
| Avg Daily | 40 | 7 |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | 40 | 8 |
| MANAGEMENT/SUPERVISOR | 40 | 5 |
| OPERATOR(S): | 40 | 3 |
| TRAINEE(S) | 40 | 4 |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | |
|---------|---|
| 1ST | 5 |
| 2ND | 2 |
| 3rd | 2 |
| weekend | 2 |

| START TIME | |
|------------|---------|
| M -F | Sat-Sun |
| 7:00a.m. | 7:00am |
| 3:00p.m. | 7:00pm |
| 11:00p.m. | 7:00am |

OTHER PLANT WORKERS

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | X | X | X | X | X | X | X |
| 2ND | X | X | X | X | X | X | X |
| 3RD | X | X | X | X | X | X | X |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | |
|-----|--|
| | |
| NO | |

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Sewer Line Maintenance

PLANT GRADE: IV

PERMIT NUMBER: _____

PLANT SUPERINTENDENT: _____

TEL. # (205) 540-7585

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|----------------|----------------------------|--------------|------------|
| 1. | Brian Champion | I (c) | C002094 | 6/30/2015 |
| 2. | Don Goodwin | I (c) | C005423 | 6/30/2015 |
| 3. | Lavon Evans | I (c) | C004631 | 12/31/2014 |
| 4. | Brian Rohling | I (c) | C005418 | 6/30/2015 |
| 5. | | | | |
| 6. | | | | |
| 7. | | | | |
| 8. | | | | |
| 9. | | | | |
| 10. | | | | |

COLLECTION SYSTEM OPERATORS:

| | | | | |
|----|--|--|--|--|
| 1. | | | | |
| 2. | | | | |
| 3. | | | | |
| 4. | | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | | |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | | |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | | |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

1ST

2ND

3RD

START TIME

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | | | | | | | |
| 2ND | | | | | | | |
| 3RD | | | | | | | |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|--------------------------|--------------------------|
| <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> |

Municipal Water Pollution Prevention (MWPP) Annual Report Calendar Year 2013

For the

Leeds WWTP

as required by the
Alabama Department of Environmental Management NPDES Program



Prepared by
Jefferson County Commission
Environmental Services Department

May 31, 2014

JEFFERSON COUNTY COMMISSION



DAVID CARRINGTON - PRESIDENT
GEORGE F. BOWMAN
SANDRA LITTLE BROWN - PRESIDENT PRO TEMPORE
T. JOE KNIGHT
JAMES A. "JIMMIE" STEPHENS

May 31, 2014

Mr. Nic Caraway, Water Division
Alabama Department of Environmental Management
Water Division – Municipal Branch
P.O. Box 301463
Montgomery, AL 36130-1463

RE: Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013

Mr. Caraway:

The Jefferson County Environmental Services Department submits the above referenced report for the Leeds Wastewater Treatment Facility, NPDES Permit No. AL0067067. Included is information as required in ADEM Form 41701/06ml, bypass/overflow event reports, MWPP Sewage Sludge Survey, and the Plant & Collection System Personnel Inventory.

If you have any questions regarding this information, please contact me at 205.325.5979 or Celeste Brown of Jefferson County Barton Laboratory at 205.238.3859.

Sincerely,

David Denard, Director
Environmental Services Department

pc: Celeste Brown, JCESD Barton Laboratory
Daniel White, JCESD Deputy Director
David Willoughby, Leeds WWTP

DAVID CARRINGTON – COMMISSIONER
ENVIRONMENTAL SERVICES

TONY PETELOS, COUNTY MANAGER

Office of

DAVID DENARD
Director of Environmental Services
Suite A-300
716 Richard Arrington, Jr. Blvd. N.
Birmingham, Alabama 35203
Telephone (205) 325-5496
Fax (205) 325-5981

**MUNICIPAL WATER POLLUTION PREVENTION (MWPP)
ANNUAL REPORT**

SUBMITTED BY:

TREATMENT FACILITY: Leeds WWTP NPDES #: AL0067067

MUNICIPALITY: Jefferson County COUNTY: Jefferson

CONTACT PERSON: David Denard

Municipal Official

Director of Environmental Services

Title

Telephone #: (205) 325-5979 Fax #: (205) 325-5981

Email Address: denardd@jccal.org

CHIEF OPERATOR: David Willoughby

Name

Telephone #: (205) 699-8495 Fax #: (205) 699-0640

Email Address: willoughbyd@jccal.org

Date: May 14, 2014

REVIEWED BY: Daniel White P.E., ESD Engineer

Consulting Engineer

Telephone #: 205-214-8610 Fax #: 205-325-5688

Date: May 14, 2014

**MWPP Annual Report
Information Source List**

The following information will be needed to complete the compliance maintenance report that covers the calendar year of 2013 (due **May 31,** 2014).

- Part 1 A. The average plant influent flow for each month (million gallons per day/MGD) during the year.
B. The average plant influent BOD (CBOD) for each month (mg/l and lb/day) in the year.
C. The plant's average design flow (MGD) and design BOD loading (lbs/day).
- Part 2 A. The monthly average permit and DMR effluent concentration for BOD (CBOD), TSS, NH3-N, and/or TKN in mg/l for the year
B. The monthly average effluent limits and DMR loading for BOD, TSS, NH3-N, and/or TKN in lbs/day for the year
- Part 3 The age of the treatment plant defined as the number of years since the last major reconstruction to increase the organic or hydraulic capacity of the plant. The last calendar year minus the year the new construction was brought on-line.
- Part 4 Bypass and overflow information. This is the number of bypass or overflow events of untreated wastewater due to heavy rain or equipment failure whether intentional or inadvertent from all collection systems tributary to the treatment facility.
- Part 5 A. Describe the characteristics and quantity of sludge generated.
B. If sludge is landspread, how many months of sludge storage does the plant have? This should include on-site and off-site storage from the treatment plant. The digester capacity may be used in the calculation.
- Part 6 A. Sludge Disposal Method
B. The number of approved land disposal sites for sludge available, and how many months or years these disposal sites will these be available for use.
- Part 7 The number of sewer extensions installed in the community last year--the design population, design flow, and design BOD for each sewer extension.
- Part 8 Operator Certification
- Part 9 Financial Status
- Part 10 Subjective Evaluation
- Part 11 Summary Sheet

State of Alabama
MWPP Annual Report
Department of Environmental Management

Instructions to the Operator-in-Charge

1. Complete all sections of the MWPP Report to the best of your ability.
2. Parts 1 through 8 contain questions for which points will be generated. These points are intended to communicate to the Department and the governing body or owner the actions necessary to prevent effluent violations. Enter the point totals from Parts 1 through 8 on Part 11: Summary Sheet.
3. Add the point totals on Part 11: Summary Sheet.
4. Submit the MWPP Report to the governing body and the consulting engineer and owner for review and approval.
5. The governing body should pass a resolution which contains the following points:
 - a. The resolution should acknowledge the governing body or owner has reviewed the MWPP Report.
 - b. The resolution should indicate what actions will be taken to prevent effluent violations.
 - c. The resolution should provide any other information the governing body or owner deems appropriate.
6. **The MWPP Report and the resolution must be submitted by May 31st to Municipal Section, Water Division, ADEM, P.O. Box 301463, Montgomery, AL 36130-1463.**

Facility Name: Leeds WWTP

Part 1: Influent Loading/Flows

A. List the average monthly volumetric flows and BOD₅ (CBOD₅) loadings received at your facility during the last calendar year.

| <u>Month</u> | <u>Column 1 Average Monthly Flowrate (MGD)</u> | <u>Column 2 Average Monthly BOD₅ (CBOD₅) Concentration (mg/l)</u> | <u>Column 3 Average Loading BOD₅ (CBOD₅) (lbs/day**)</u> |
|--------------------|--|---|--|
| January | 2.1 | 67 | 1100 |
| February | 2.1 | 98 | 1477 |
| March | 1.5 | 72 | 757 |
| April | 1.3 | 79 | 825 |
| May | 1.5 | 66 | 679 |
| June | 0.70 | 87 | 522 |
| July | 0.76 | 76 | 451 |
| August | 1.1 | 75 | 521 |
| September | 0.57 | 110 | 470 |
| October | 0.49 | 114 | 459 |
| November | 0.52 | 125 | 528 |
| December | 1.4 | 62 | 703 |
| Annual Avg. | 1.2 | 86 | 708 |

**As reported on NPDES Discharge Monitoring Reports (DMRs) and as required by EPA's NPDES Self-Monitoring System, User Guide, March 1985.

B. List the average design flow and average design BOD₅ loading for the facility below. If you are not aware of these design quantities, contact your consulting engineer or the Alabama Department of Environmental Management.

| | <u>Average Design Flow</u> | <u>Average Design BOD₅ Loading (lbs/day)</u> |
|----------------------------|----------------------------|---|
| Design Criteria | 5.0 | 8340 |
| 90% of the Design Criteria | 4.5 | 7506 |

- C. How many times did the monthly flow (Column 1) to the WWTP exceed 90% of design flow?
 _____ the appropriate point total)
 0 - 4 = 0 points 5 or more = 5 points
- D. How many times did the monthly flow (Column 1) to the WWTP exceed the design flow?
 _____ the appropriate point total)
 0 = 0 points 1 - 2 = 5 points 3 - 4 = 10 points 5 or more = 15 points
- E. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed 90% of the design loading? _____ the appropriate point total)
 0 - 1 = 0 points 2 - 4 = 5 points 5 or more = 10 points
- F. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed the design loading? _____ the appropriate point total)
 0 = 0 points 1 = 10 points 2 = 20 points 3 = 30 points 4 = 40 points 5 or more = 50 points
- G. Enter each point value marked for C through F and enter the sum in the appropriate blank below.

C points = 0

D points = 0

E points = 0

F points = 0

TOTAL POINTS VALUE OR PART 1 0

Enter this value on Part 11: Summary Sheet.

*To obtain equivalent BOD₅ loading for comparison with design loading for those permittees using influent CBOD₅, divide annual average CBOD₅, loading in lbs/day from Part 1, A by 0.7.

Facility Name: Leeds WWTP

Part 2: Effluent Quality/Plant Performance

A. List the monthly average permit limits for the facility in the blanks below and the average monthly effluent DMR BOD₅, (CBOD₅) TSS, NH₃-N and/or TKN concentration produced by the facility during the last calendar year.

(1) NPDES Permit Concentration

| Permit Limit | Months | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------|---------|--|---------------|------------------------------|---------------|
| | | May-Nov | 4.0 | 24 | 2.0 |
| | Dec-Apr | 10.0 | 24 | 3.0 | 8.0 |

(2) DMR Concentration

| Qtr | Month | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------------|-----------|--|---------------|------------------------------|---------------|
| 1 | January | 0.53 | 0.77 | 0.00 | 0.40 |
| | February | 0.39 | 0.58 | 0.011 | 0.29 |
| | March | 1.10 | 0.64 | 0.00 | 0.35 |
| 2 | April | 0.30 | 0.74 | 0.00 | 0.24 |
| | May | 0.20 | 1.8 | 0.00 | 0.23 |
| | June | 0.32 | 0.98 | 0.00 | 0.36 |
| 3 | July | 0.43 | 0.95 | 0.00 | 0.11 |
| | August | 0.23 | 0.57 | 0.00 | 0.22 |
| | September | 0.25 | 0.58 | 0.00 | 0.31 |
| 4 | October | 0.49 | 0.80 | 0.00 | 0.25 |
| | November | 0.54 | 1.62 | 0.011 | 0.28 |
| | December | 0.41 | 0.34 | 0.00 | 0.26 |
| Annual Avg. | | 0.43 | 0.87 | 0.002 | 0.28 |

B. List the monthly average permit limit and DMR loadings below.

(1) NPDES Permit Loading

| Permit Limit | Months | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|--------------|---------|---|------------------|---------------------------------|------------------|
| | May-Nov | 66.7 | 400 | 33.3 | 66.7 |
| Dec-Apr | 166 | 400 | 50.0 | 133 | |

(2) DMR Loading

| Qtr | Month | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|--------------------|-----------|---|------------------|---------------------------------|------------------|
| 1 | January | 8.0 | 20.9 | 0.00 | 7.5 |
| | February | 6.8 | 11.1 | 0.20 | 4.9 |
| | March | 10.1 | 8.0 | 0.00 | 3.7 |
| 2 | April | 3.2 | 7.9 | 0.00 | 2.5 |
| | May | 2.0 | 12.8 | 0.00 | 3.0 |
| | June | 2.0 | 6.2 | 0.00 | 2.3 |
| 3 | July | 2.9 | 7.8 | 0.00 | .72 |
| | August | 1.9 | 5.8 | 0.00 | 1.9 |
| | September | 1.14 | 2.7 | 0.00 | 1.4 |
| 4 | October | 1.8 | 3.3 | 0.00 | 1.0 |
| | November | 2.8 | 7.4 | 0.03 | 1.4 |
| | December | 5.9 | 3.9 | 0.00 | 3.7 |
| Annual Avg. | | 4.1 | 8.1 | 0.02 | 2.8 |

C. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

D. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

E. During the past year did the effluent TSS concentration (mg/l) or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

F. During the past year did the TSS concentration (mg/l) and/or loading (lbs/day) exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

G. During the past year did the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

H. During the past year did either the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

I. Enter each point value checked for C through H in the blanks below.

C Points = 0

D Points = 0

E Points = 0

F Points = 0

G Points = 0

H Points = 0

HIGHEST INDIVIDUAL POINT VALUE FOR PART 2 (C-H) 0 (HIGHEST POINT = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Leeds WWTP

Part 3: Age of the Wastewater Treatment Facility

A. What year was the wastewater treatment plant constructed or last reconstructed? 1995

Subtract the above answer from the report year to determine age:

$$\text{Age} = (\text{Last Calendar year}) - (\text{Answer to A})$$

$$\text{Age } \underline{18} = (\underline{2013}) - (\underline{1995})$$

Enter Age in Part C below.

B. Check the type of treatment facility employed.

| | Factor |
|---|--------|
| <u> x </u> Mechanical Treatment Plant | 2.0 |
| <u> </u> Aerated Lagoon | 1.5 |
| <u> </u> Stabilization Pond | 1.0 |
| <u> </u> Other (Specify: _____) | 1.0 |

C. Multiply the factor listed next to the type of the facility your community employs by the age of your facility to determine the total point value for Part 3:

$$\frac{\underline{2.0}}{\text{(Factor)}} \times \frac{\underline{18}}{\text{(Age)}} = \underline{36} \text{ TOTAL POINT VALUE FOR PART 3}$$

Enter the above value on Part 11: Summary Sheet. If the total point value exceeds 40, enter 40 on Part 11: Summary Sheet.

Facility Name: Leeds WWTP

Part 4: Bypassing and Overflows

- A. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to heavy rain? 0
- B. How many bypass or overflow events of untreated wastewater occurred in the last year prior to the headworks of the WWTP due to heavy rain? 0
- C. How many of the bypass or overflow events listed in Parts A and B have been corrected such that future bypass or overflow events at the same location due to heavy rain are not anticipated? 0
- D. Add together Answers A and B and subtract Answer C from that total.
A + B - C = _____ (Check the appropriate point total.)
- | | | | | | | | | | | | |
|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | |
| 0 = 0 points | 1 = 5 points | 2 = 10 points | 3 = 15 points | 4 = 20 points | 5 = 25 points | 6 = 30 points | 7 = 35 points | 8 = 40 points | 9 = 45 points | 10 = 50 points | 11 or more = 100 points |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
- E. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to equipment failure? (This includes clogged/broken lines or manholes.) 0
- F. How many bypass or overflow events of untreated wastewater occurred in the last year due to equipment failure prior to the headworks of the WWTP? (This includes clogged/broken lines or manholes.) 2
- G. How many of the bypass or overflow events listed in Parts E and F have been corrected such that future bypass or overflow events at the same location due to the same equipment failure are not anticipated? 2
- H. Add together Answers E and F and subtract Answer G from that total.
E + F - G = _____ (Check the appropriate point total.)
- | | | | | | | | | | | | |
|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | |
| 0 = 0 points | 1 = 5 points | 2 = 10 points | 3 = 15 points | 4 = 20 points | 5 = 25 points | 6 = 30 points | 7 = 35 points | 8 = 40 points | 9 = 45 points | 10 = 50 points | 11 or more = 100 points |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
- I. Add point values circled in D and H and enter the total in the blank below.

TOTAL POINT VALUE FOR PART 4 0
Enter this value on Part 11: Summary Sheet.

All bypass or overflow events that have occurred in the last year (for any reason) must be individually reported with this MWPP report.

Facility Name: Leeds WWTP

Part 5: Sludge Quantity and Storage

- A. Please provide information concerning sludge quantity, characteristics, and storage practices based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months of sludge storage capacity does the wastewater treatment facility have available, either on-site or off-site? (i.e., How many months can the facility operate without land spreading or disposing of sludge?) 4

(Check the appropriate point total.)

- | | | |
|---|-------------|-------------------------------------|
| Greater than or equal to 4 months | = 0 points | <input checked="" type="checkbox"/> |
| Less than 4 months, but greater than or equal to 3 months | = 10 points | <input type="checkbox"/> |
| Less than 3 months, but greater than or equal to 2 months | = 20 points | <input type="checkbox"/> |
| Less than 2 months, but greater than or equal to 1 month | = 30 points | <input type="checkbox"/> |
| Less than one month | = 50 points | <input type="checkbox"/> |

TOTAL POINT VALUE FOR PART 5 0

Enter this value on Part 11: Summary Sheet.

Part 6: Sludge Disposal Practices and Sites

- A. Please provide the sludge disposal practices and site information based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months or years does the facility have access to and approval for sufficient land disposal sites to provide proper land disposal? (Check the appropriate point total.)

- | | | |
|--------------------|-------------|-------------------------------------|
| 36 or more months | = 0 points | <input type="checkbox"/> |
| 24 - 35 months | = 10 points | <input type="checkbox"/> |
| 12 - 23 months | = 20 points | <input checked="" type="checkbox"/> |
| 6 - 11 months | = 30 points | <input type="checkbox"/> |
| Less than 6 months | = 50 points | <input type="checkbox"/> |

TOTAL POINT VALUE FOR PART 6 20

Enter this value on Part 11: Summary Sheet.

Facility Name: Leeds WWTP

Part 7: New Development

Are there any major new developments (industrial, commercial, or residential) in the last calendar year or anticipated in the next 2-3 years such that either flow or BOD₅ loadings to the sewage system could significantly increase? Estimate additional loadings below.

Design Population: _____
Equivalent (PE)

Design Flow: _____ MGD

Design BOD₅: _____ lbs/day

List industrial and/or residential developments.

The Environmental Services Department has not received any applicable sewer availability requests that would significantly impact the sewer system, but ESD is aware of long-term development concepts that could affect the collection system and potentially the WWTP in the next 5 to 10 years.

Will the additional loading overload the plant? (Check the appropriate point total.)

No = 0 points Yes = 121 points

Enter the point total in the blank below.

TOTAL POINT VALUE FOR PART 7 0 (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Part 8: Operator Certification

Complete the *Plant and Collection System Personnel Inventory*, ADEM Form 441.

Do both the plant operator and collection system staffing comply with ADEM Administrative Code; Division 10, Operator Certification Program? (Check the appropriate point total.)

Yes = 0 points No = 121 points

TOTAL POINT VALUE FOR PART 8 0 (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Leeds WWTP

Part 9: Financial Status

- A. Are User-Charge Revenues sufficient to cover operation and maintenance expenses? If no, how are O&M costs being financed? ***Include user charge rates.***

Revenues are sufficient. The below values are based on a 5/8" meter and 6,000 gallons water use. Jefferson

County has a three tier block rate structure for residential users for 0-3, 4-6, and 7+ ccf water use.

Residential Minimum \$15.00 Plus rate 6.02;9.36;10.69 /1,000 gal.

Industrial Minimum \$15.00 Plus rate \$10.51 /1,000 gal.

Monthly residential rate based on 6,000 gallons usage \$ 56.04 (includes 15% credit for residential

****Please complete the above information based on your user charge rates for the report year. You may attach a sample water and sewer bill for clarity.***

- B. What financial resources are available to pay for the wastewater improvements and/or reconstruction needs?

In 2013, Jefferson County issued Series 2013 Sewer Warrants that fund capital improvements

through 2023 at an annual average rate of \$71.9 million over the 10-year period.

Part 10: Subjective Evaluation

- A. Describe briefly the physical and structural conditions of the wastewater treatment facility.

The physical and structural condition of the WWTP is good.

- B. Describe the general condition of the sewer system (sewer lines, manholes, lift stations).

The Leeds system includes roughly 275,000' of pipe and 8 pump stations. The system's rate of

SSO's/100 miles of sewer met the department's goal. There are no known capacity deficiencies.

The general condition of the system is good.

C. What sewage system improvements does the community have planned for construction in the next 5 years?

Sewer line repairs and replacements. Generators at Coosa Ave. and Parkway pump stations.

The Coosa Ave. pump station, force main and gravity sewer will likely need a capacity expansion.

Replacement of the WWTP SCADA system. Replacement of the WWTP UV system.

D. What is the theoretical design life of the plant, and what is the estimated remaining useful life of the wastewater treatment facility?

Calculated remaining useful life of the structures is 32 years (50 years - 18 years age of facility).

Remaining useful life of equipment is 7 years (25 years - 18 years age of equipment).

*Based on EPA's 2002 Clean Water and Drinking Water Infrastructure Gap Analysis Report.

E. What problems, if any, over the last year have threatened treatment or conveyance within the system?

There were two blockages in sewer lines that resulted in SSOs.

F. Is the community presently involved in formal planning for treatment facility upgrading?

No.

G. How many days in the last year were there residential backups at any point in the collection system for any reason other than clogging of the lateral connection? 6

H. Does the plant have a written plan for preventive maintenance on major equipment items? If yes, describe.

Yes. Preventive maintenance schedules are entered into the INFOR asset management program. Work orders

are generated from the system, and completed tasks are recorded.

I. Does this preventive maintenance program depict frequency of intervals, types of lubrication, and other preventive maintenance tasks necessary for each piece of equipment? (Check the appropriate response.) Yes No

J. Are these preventive maintenance tasks, as well as equipment problems, being recorded and filed so future maintenance problems can be assessed properly? (Check the appropriate response.) Yes No

K. Describe any major repairs or mechanical equipment replacement made in the last year and include the approximate cost for those repairs. Do not include major treatment plant construction or upgrading programs.

Replaced one backwash pump on sand filter #1 at an approximate cost of \$4,050.

Repaired plant water wash-down pump at an approximate cost of \$7,300

L. List any additional comments. (Attach additional sheets if necessary.)

Facility Name: Leeds WWTP

Part 11: Summary Sheet

1. Enter in the values from Parts 1 through 8 in the left column below. Add the numbers in the left column to determine the MWPP Report point total the wastewater system generated for the previous calendar year.

| <u>Actual Values</u> | <u>Maximum Possible</u> |
|-------------------------|-------------------------|
| Part 1 <u>0</u> points | 80 points |
| Part 2 <u>0</u> points | 121 points |
| Part 3 <u>36</u> points | 40 points |
| Part 4 <u>0</u> points | 200 points |
| Part 5 <u>0</u> points | 50 points |
| Part 6 <u>20</u> points | 50 points |
| Part 7 <u>0</u> points | 121 points |
| Part 8 <u>0</u> points | 121 points |
| Total <u>56</u> points | 783 points |

2. Check the facility type that best describes the plant's treatment and disposal of wastewater.

- Mechanical plant with surface water discharge
 Aerated Lagoon or stabilization pond with surface water discharge
 Mechanical plant using land disposal of liquid wastes
 Aerated Lagoon or stabilization pond using land disposal of liquid wastes

3. Check the range that describes the action needed to address problems identified in the report.

- 0 - 70 pts. Actions as Appropriate*
 71 - 120 pts. Departmental Recommendation Range*
 121 - 783 Municipality Action Range*

***Other actions may be required by NPDES outside the scope of this report.**

4. Complete the *Municipal Water Pollution Prevention Resolution Form*, ADEM Form 418.

5. In Question 1, do any of the actual point values in the left column equal the maximum possible points in the right column? (Check the appropriate response) Yes No


If yes, provide a written explanation for this situation in the space below.

Leeds Wastewater Treatment Plant
ATTACHMENT 2 – Raw Sewage Bypass and

SUMMARY



LEEDS BASIN 2013 DISCHARGES



NOTE: OVERFLOWS SHOWN ARE OVER 10,000 GALLONS
NONE REPORTED FOR LEEDS BASIN.

JEFFERSON COUNTY
ENVIRONMENTAL SERVICES
PLOTTED: 2-11-14



Summary of Unpermitted Discharges - Leeds

January 01, 2013 through December 31, 2013

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-----------|---------------|-----------------------|-------------------|------------------------------------|-----------------|---------|-----------------------------------|---------|------------------|-------------------|------------------------------------|
| T00041 | 2/4/13 | 7237 President Street | Leeds | Ground Absorbed/ Drainage Ditch | 695 | Manhole | Grease/ Jetwashing Activity | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| T00048 | 11/14/13 | 8517 Hampton St | Leeds | Storm Drain | | Pipe | Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |

Notes: Volume was not determinable.

Leeds Wastewater Treatment Plant
ATTACHMENT 3 – MWPP Sewage Sludge

SURVEY



MWPP SEWAGE SLUDGE SURVEY

Facility Background Information:

1. Facility Information Permit Number: AL0067067

Name: LEEDS WWTP

Street Address: 800 HELEN STREET

County: JEFFERSON

2. Facility Contact

Name: David Willoughby

Title: PLANT SUPERINTENDENT

Telephone: (205) 699-8495

Permittee Name: JEFFERSON COUNTY COMMISSION (Leeds WWTP)

Mailing Address: SUITE A-300, 716 RICHARD ARRINGTON, JR. BLVD. N.

Facility Flow Information

1. Facility Wastewater Treatment Capacity

Avg. Daily Flow for 2013: 1.17 MGD

Facility Design Capacity: 5.0 MGD

2. Estimated Septage Quantity Handled (Residuals Removed from Septic Tank Systems)

Average Domestic Septage: N/A gallons per month

Average Commercial Septage: N/A gallons per month

3. Method of Septage Processing

Mixed with Influent Wastewater for Treatment

Mixed with Sewage Sludge

N/A

4. Estimated Percentage Contributing Wastewater Flow

Residential: 92 %

Industrial: 3 %

Other: 5 % Describe: COMMERCIAL

5. List type of wastewater treatment process(es) utilized at this facility:

COMMINUTOR, GRIT REMOVAL, EXTENDED AERATION WITH ACTIVATED

6. Estimated sewage sludge wasting rate at this facility: _____ lb/day dry weight
or 11,400 gallons per day

7. Estimated untreated sludge received from off site: _____ lb/day dry weight
or N/A gallons per day

8. Estimated percent solids of combined sewage sludge prior to treatment: 1.86 %

9. List the sewage sludge treatment processes used in preparing sludge for final use or disposal:

| | Sludge Quantity (untreated pounds per day) |
|-------------------------|---|
| Aerobic Digestion | --- |
| Drying Beds(Air Drying) | --- |
| | |
| | |

10. Estimate the total volume of sludge generated: 372

(dry U.S. tons per year)

Sludge Disposal Methods

1. Which of the following describes the current method of sewage sludge disposal for this facility:

| | Current Practices | | | Proposed Practices | |
|--|--------------------------|--------------------------|----------------------|--------------------------|--------------------------|
| | Approved by ADEM | | Quantity | Approved by ADEM | |
| | Yes | No | (dry U.S. tons/year) | Yes | No |
| a. <input checked="" type="checkbox"/> Land Application, Bulk Shipped | | | 373 | | |
| <input checked="" type="checkbox"/> Agriculture | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Forest | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Public Contact | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Lawn/Home Garden | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| b. <input type="checkbox"/> Land Application, Bagged/Other Container | | | | | |
| <input type="checkbox"/> Agriculture | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Forest | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Public Contact | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Lawn/Home Garden | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| c. <input type="checkbox"/> Incineration | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| d. <input type="checkbox"/> Subtitle D Landfill (Disposal Only) | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| e. <input type="checkbox"/> Lined Treatment Lagoon or Stabilization Pond | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| f. <input type="checkbox"/> Unlined Lagoon or Stabilization Pond | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| g. <input type="checkbox"/> Other (Please Describe) | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | | | |
| | | | | | |
| | | | | | |

2. If "f" was selected above and sludge is stored for 2 or more years, enter the distance between the surface disposal site and the property line: _____ feet

Pollutant Concentrations

1. Enter the total concentrations of the following analytes using existing data. Do not enter TCLP results.

| Analyte | Concentration (mg/kg or ppm) | Sample Type | Sample Date | Detection Level of Analysis |
|-------------------------|------------------------------|-------------|-------------|-----------------------------|
| Arsenic | <PQL | GRAB | * | 11.0 |
| Cadmium | <PQL | GRAB | * | 5.0 |
| Chromium | 62 | GRAB | * | 6.0 |
| Copper | 930 | GRAB | * | 5.0 |
| Lead | 28 | GRAB | * | 12.0 |
| Mercury | 2.0 | GRAB | * | 0.03 |
| Molybdenum | 16.00 | GRAB | * | 6.0 |
| Nickel | 29 | GRAB | * | 6.0 |
| Selenium | <PQL | GRAB | * | 12.0 |
| Zinc | 780 | GRAB | * | 8.0 |
| Ammonium-Nitrogen | N/A | N/A | * | N/A |
| Nitrate-Nitrogen | N/A | N/A | * | N/A |
| Total Kjeldahl Nitrogen | 27,750 | GRAB | * | 0.09 |

2. Enter the estimated or determined percent solids of the sewage sludge when sampled for the above analysis: 84 %

Treatment Provided for Sewage Sludge at the Facility

1. Which class of pathogen reduction does the sewage sludge meet at the facility? (As defined in 40 CFR Part 503)

Class A

Alternative A1 - Time and Temperature

Alternative A2 - Alkaline Treatment

Alternative A3 - Analysis and Operation

Alternative A4 - Analysis Only

Alternative A5 - Processes to Further Reduce Pathogens (PFRP)

Heat Drying

Thermophilic Aerobic Digestion

Heat Treatment

Pasteurization

Gamma Ray Irradiation

Beta Ray Irradiation

Composting

Alternative A6 - PFRP Equivalent

Class B

Alternative B1 - Fecal Coliform Count

Alternative B2 - Process to Significantly Reduce Pathogens (PSRP)

Aerobic Digestion

Air Drying

Anaerobic Digestion

Composting

Lime Stabilization

Alternative B3 - PSRP Equivalent

Neither or Unknown

Vector Attraction Control

Option 1 - Minimum 38% Reduction in Volatile Solids

- Option 2 - Anaerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 3 - Aerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 4 - Specific Oxygen Uptake Rate (SOUR) for Aerobically Digested Sludge
- Option 5 - Aerobic Processes plus Elevated Temperature
- Option 6 - Raised pH to 12 and Retained at 11.5
- Option 7 - 75% Solids with no Unstabilized Solids
- Option 8 - 90% Solids with Unstabilized Solids
- Option 9 - Injection Below Land Surface
- Option 10 - Incorporation into Soil within 6 or 8 Hours
- Option 11 - Covering Active Sewage Sludge Unit Daily
- None of the Above

Groundwater Monitoring

1. If disposal practice is surface disposal or land application, is groundwater monitoring required or performed at the site?

- Yes (If yes, please submit a copy of the groundwater monitoring reports along with this survey. Also please provide the approximate depth to groundwater and the groundwater monitoring procedures used to obtain the data.)
- No

Land Application of Sewage Sludge

Answer the following questions if sewage sludge is applied to land.

1. If sewage sludge is land applied in bulk form, what type of crop or other vegetation is grown on this site?

Tifton Bermuda Grass, Ryegrass

2. If sewage sludge is land applied in bulk form, what is the nitrogen requirement for this crop or vegetation?
600 lb/acre/year(Reclamation)

3. If sewage sludge is land applied in bulk form, briefly describe the nature of any complaints filed from neighbors?

No recent complaints have been filed.

Note: Permittees that submitted the "Annual Report Review Form" for sludge to the EPA may submit a copy with the MWPP in lieu of this Attachment.

Leeds Wastewater Treatment Plant
ATTACHMENT 4 – Plant and Collection System
Personnel Inventory



PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Leeds (Norman R. Skinner) WWTP

PLANT GRADE: III

PERMIT NUMBER: AL0067067

PLANT SUPERINTENDENT: David Willoughby

TEL. # (205) 699-8495

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5806

PLANT OPERATORS:

| NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----------------------|-------------------------|--------------|------------|
| 1. Ben Cato | IV | C001942 | 11/30/2015 |
| 2. Doris Gill | IV | C000444 | 11/30/2015 |
| 3. David Willoughby | IV | C002616 | 11/30/2015 |
| 4. Wanda June McCarty | IV | C003209 | 7/31/2015 |
| 5. Hermon Ramsey | IV | C003658 | 8/31/2015 |
| 6. Anthony Weldon | IV | C002650 | 11/30/2013 |
| 7. Willie G. Harmon | | | |
| 8. Eric T. Lawler | | | |
| 9. | | | |
| 10. | | | |

COLLECTION SYSTEM OPERATORS:

| | | | |
|----|--|--|--|
| 1. | | | |
| 2. | | | |
| 3. | | | |
| 4. | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | 40 | 1 |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | 200 | 5 |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | 80 | 2 |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | |
|-----|---|
| 1ST | 5 |
| 2ND | |
| 3RD | |

| | |
|------------|-----|
| START TIME | 700 |
| | |
| | |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | x | x | x | x | x | x | x |
| 2ND | | | | | | | |
| 3RD | | | | | | | |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|-----|----|
| | |
| | |

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Sewer Line Maintenance

PLANT GRADE: IV

PERMIT NUMBER: _____

PLANT SUPERINTENDENT: _____

TEL. # (205) 540-7585

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|----------------|----------------------------|--------------|------------|
| 1. | Brian Champion | I (c) | C002094 | 6/30/2015 |
| 2. | Don Goodwin | I (c) | C005423 | 6/30/2015 |
| 3. | Lavon Evans | I (c) | C004631 | 12/31/2014 |
| 4. | Brian Rohling | I (c) | C005418 | 6/30/2015 |
| 5. | | | | |
| 6. | | | | |
| 7. | | | | |
| 8. | | | | |
| 9. | | | | |
| 10. | | | | |

COLLECTION SYSTEM OPERATORS:

| | | | | |
|----|--|--|--|--|
| 1. | | | | |
| 2. | | | | |
| 3. | | | | |
| 4. | | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | | |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | | |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | | |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | | | |
|-----|--|------------|--|
| 1ST | | START TIME | |
| 2ND | | | |
| 3RD | | | |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | | | | | | | |
| 2ND | | | | | | | |
| 3RD | | | | | | | |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| | YES | NO |
|----|-----|----|
| 1. | | |
| 2. | | |

**Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013**

For the

Prudes Creek WWTP

as required by the
Alabama Department of Environmental Management NPDES Program



Prepared by
Jefferson County Commission
Environmental Services Department

May 31, 2014

JEFFERSON COUNTY COMMISSION



DAVID CARRINGTON - PRESIDENT
GEORGE F. BOWMAN
SANDRA LITTLE BROWN - PRESIDENT PRO TEMPORE
T. JOE KNIGHT
JAMES A. "JIMMIE" STEPHENS

May 31, 2014

Mr. Nic Caraway
Alabama Department of Environmental Management
Water Division – Municipal Branch
P.O. Box 301463
Montgomery, AL 36130-1463

RE: Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013

Mr. Caraway:

The Jefferson County Environmental Services Department submits the above referenced report for the Prudes Creek Wastewater Treatment Facility, NPDES Permit No. AL0056120. Included is information as required in ADEM Form 41701/06ml, bypass/overflow event reports, MWPP Sewage Sludge Survey, and the Plant & Collection System Personnel Inventory.

If you have any questions regarding this information, please contact me at 205.325.5979 or Celeste Brown at Jefferson County Barton Laboratory at 205.238.3859.

Sincerely,

David Denard, Director
Environmental Services Department

pc: Celeste Brown, JCESD Barton Laboratory
Daniel White, JCESD Deputy Director
Lynn Jones, Prudes Creek WWTP

DAVID CARRINGTON – COMMISSIONER
ENVIRONMENTAL SERVICES

TONY PETELOS, COUNTY MANAGER

Office of

DAVID DENARD
Director of Environmental Services
Suite A-300
716 Richard Arrington, Jr. Blvd. N.
Birmingham, Alabama 35203
Telephone (205) 325-5496
Fax (205) 325-5981

**MUNICIPAL WATER POLLUTION PREVENTION (MWPP)
ANNUAL REPORT**

SUBMITTED BY:

TREATMENT FACILITY: Prudes Creek WWTP NPDES #: AL0056120

MUNICIPALITY: Jefferson County Commission COUNTY: Jefferson

CONTACT PERSON: David Denard

Municipal Official

Director of Environmental Services

Title

Telephone #: 205 - 325-5979 Fax #: 205 - 325-5981

Email Address: denardd@jcal.org

CHIEF OPERATOR: Lynn D. Jones, Plant Manager

Name

Telephone #: 205 - 841 - 5939 Fax #: 205 - 841 - 7698

Email Address: jonesly@jccal.org

Date: May 14, 2014

REVIEWED BY: Daniel White P.E., ESD Engineer

Consulting Engineer

Telephone #: 205 - 214 - 8610 Fax #: 205 - 325 - 5981

Date: May 14, 2014

**MWPP Annual Report
Information Source List**

The following information will be needed to complete the compliance maintenance report that covers the calendar year of 2013 (due **May 31**, 2014).

- Part 1 A. The average plant influent flow for each month (million gallons per day/MGD) during the year.
B. The average plant influent BOD (CBOD) for each month (mg/l and lb/day) in the year.
C. The plant's average design flow (MGD) and design BOD loading (lbs/day).
- Part 2 A. The monthly average permit and DMR effluent concentration for BOD (CBOD), TSS, NH3-N, and/or TKN in mg/l for the year
B. The monthly average effluent limits and DMR loading for BOD, TSS, NH3-N, and/or TKN in lbs/day for the year
- Part 3 The age of the treatment plant defined as the number of years since the last major reconstruction to increase the organic or hydraulic capacity of the plant. The last calendar year minus the year the new construction was brought on-line.
- Part 4 Bypass and overflow information. This is the number of bypass or overflow events of untreated wastewater due to heavy rain or equipment failure whether intentional or inadvertent from all collection systems tributary to the treatment facility.
- Part 5 A. Describe the characteristics and quantity of sludge generated.
B. If sludge is landspread, how many months of sludge storage does the plant have? This should include on-site and off-site storage from the treatment plant. The digester capacity may be used in the calculation.
- Part 6 A. Sludge Disposal Method
B. The number of approved land disposal sites for sludge available, and how many months or years these disposal sites will these be available for use.
- Part 7 The number of sewer extensions installed in the community last year--the design population, design flow, and design BOD for each sewer extension.
- Part 8 Operator Certification
- Part 9 Financial Status
- Part 10 Subjective Evaluation
- Part 11 Summary Sheet

State of Alabama
MWPP Annual Report
Department of Environmental Management

Instructions to the Operator-in-Charge

1. Complete all sections of the MWPP Report to the best of your ability.
2. Parts 1 through 8 contain questions for which points will be generated. These points are intended to communicate to the Department and the governing body or owner the actions necessary to prevent effluent violations. Enter the point totals from Parts 1 through 8 on Part 11: Summary Sheet.
3. Add the point totals on Part 11: Summary Sheet.
4. Submit the MWPP Report to the governing body and the consulting engineer and owner for review and approval.
5. The governing body should pass a resolution which contains the following points:
 - a. The resolution should acknowledge the governing body or owner has reviewed the MWPP Report.
 - b. The resolution should indicate what actions will be taken to prevent effluent violations.
 - c. The resolution should provide any other information the governing body or owner deems appropriate.
6. **The MWPP Report and the resolution must be submitted by May 31st to Municipal Section, Water Division, ADEM, P.O. Box 301463, Montgomery, AL 36130-1463.**

Facility Name: Prudes Creek WWTP

Part 1: Influent Loading/Flows

A. List the average monthly volumetric flows and BOD₅ (CBOD₅) loadings received at your facility during the last calendar year.

| <u>Month</u> | <u>Column 1 Average Monthly Flowrate (MGD)</u> | <u>Column 2 Average Monthly BOD₅ (CBOD₅) Concentration (mg/l)</u> | <u>Column 3 Average Loading BOD₅ (CBOD₅) (lbs/day**)</u> |
|--------------------|--|---|--|
| January | 0.68 | 24 | 135 |
| February | 0.62 | 34 | 168 |
| March | 0.55 | 33 | 143 |
| April | 0.54 | 51 | 185 |
| May | 0.45 | 47 | 139 |
| June | 0.34 | 50 | 131 |
| July | 0.37 | 48 | 121 |
| August | 0.33 | 42 | 116 |
| September | 0.25 | 67 | 133 |
| October | 0.24 | 73 | 147 |
| November | 0.29 | 84 | 223 |
| December | 0.63 | 30 | 121 |
| Annual Avg. | 0.44 | 49 | 147 |

**As reported on NPDES Discharge Monitoring Reports (DMRs) and as required by EPA's NPDES Self-Monitoring System, User Guide, March 1985.

B. List the average design flow and average design BOD₅ loading for the facility below. If you are not aware of these design quantities, contact your consulting engineer or the Alabama Department of Environmental Management.

| | <u>Average Design Flow</u> | <u>Average Design BOD₅ Loading (lbs/day)</u> |
|----------------------------|----------------------------|---|
| Design Criteria | 0.9 | 2144 |
| 90% of the Design Criteria | 0.81 | 1930 |

C. How many times did the monthly flow (Column 1) to the WWTP exceed 90% of design flow?
_____ (Check the appropriate point total)

0 - 4 = 0 points 5 or more = 5 points

D. How many times did the monthly flow (Column 1) to the WWTP exceed the design flow?
_____ (Check the appropriate point total)

0 = 0 points 1 - 2 = 5 points 3 - 4 = 10 points 5 or more = 15 points

E. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed 90% of the design loading? _____ (Check the appropriate point total)

0 - 1 = 0 points 2 - 4 = 5 points 5 or more = 10 points

F. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed the design loading? _____ (Check the appropriate point total)

0 = 0 points 1 = 10 points 2 = 20 points 3 = 30 points 4 = 40 points 5 or more = 50 points

G. Enter each point value marked for C through F and enter the sum in the appropriate blank below.

C points = 0

D points = 0

E points = 0

F points = 0

TOTAL POINTS VALUE OR PART 1 0

Enter this value on Part 11: Summary Sheet.

*To obtain equivalent BOD₅ loading for comparison with design loading for those permittees using influent CBOD₅, divide annual average CBOD₅, loading in lbs/day from Part 1, A by 0.7.

Facility Name: Prudes Creek WWTP

Part 2: Effluent Quality/Plant Performance

A. List the monthly average permit limits for the facility in the blanks below and the average monthly effluent DMR BOD₅, (CBOD₅) TSS, NH₃-N and/or TKN concentration produced by the facility during the last calendar year.

(1) NPDES Permit Concentration

| Permit Limit | Months | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------|------------|--|---------------|------------------------------|---------------|
| | | April - Oct. | 8.0 | 30.0 | 2.5 |
| | Nov. - May | 25.0 | 30.0 | 10.0 | 20.0 |

(2) DMR Concentration

| Qtr | Month | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|-----|--------------------|--|---------------|------------------------------|---------------|
| 1 | January | 0.80 | 0.98 | 0.24 | 0.60 |
| | February | 0.73 | 0.50 | 0.01 | 0.26 |
| | March | 0.75 | 0.54 | 0.14 | 0.53 |
| 2 | April | 0.68 | 0.94 | 0.17 | 0.64 |
| | May | 0.43 | 0.68 | 0.03 | 0.27 |
| | June | 2.2 | 2.2 | 0.24 | 0.74 |
| 3 | July | 1.5 | 3.1 | 0.06 | 0.34 |
| | August | 0.68 | 0.67 | 0.01 | 0.31 |
| | September | 0.72 | 0.94 | 0.11 | 0.42 |
| 4 | October | 0.88 | 0.67 | 0.04 | 0.38 |
| | November | 0.89 | 1.5 | 0.01 | 0.32 |
| | December | 1.0 | 0.71 | 0.18 | 0.47 |
| | Annual Avg. | 0.94 | 1.1 | 0.10 | 0.44 |

B. List the monthly average permit limit and DMR loadings below.

(1) NPDES Permit Loading

| Permit Limit | Months | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|--------------|--------------|---|------------------|---------------------------------|------------------|
| | April - Oct. | 60.0 | 225 | 18.7 | 37.5 |
| Nov. - May | 187 | 225 | 75.0 | 150 | |

(2) DMR Loading

| Qtr | Month | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|--------------------|-----------|---|------------------|---------------------------------|------------------|
| 1 | January | 4.6 | 8.9 | 1.4 | 3.5 |
| | February | 3.6 | 2.6 | 0.07 | 1.1 |
| | March | 3.3 | 1.9 | 0.75 | 2.8 |
| 2 | April | 2.6 | 3.4 | 0.53 | 2.2 |
| | May | 1.6 | 2.2 | 0.21 | 1.1 |
| | June | 6.3 | 6.8 | 0.83 | 2.5 |
| 3 | July | 5.2 | 8.9 | 0.26 | 1.3 |
| | August | 1.8 | 1.7 | 0.02 | 0.92 |
| | September | 1.4 | 1.9 | 0.25 | 0.85 |
| 4 | October | 1.8 | 1.4 | 0.08 | 0.77 |
| | November | 2.1 | 6.5 | 0.03 | 0.81 |
| | December | 5.4 | 3.4 | 0.98 | 2.3 |
| Annual Avg. | | 3.3 | 4.1 | 0.45 | 1.7 |

C. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

D. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

E. During the past year did the effluent TSS concentration (mg/l) or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

F. During the past year did the TSS concentration (mg/l) and/or loading (lbs/day) exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

G. During the past year did the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

H. During the past year did either the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

I. Enter each point value checked for C through H in the blanks below.

C Points = 0

D Points = 0

E Points = 0

F Points = 0

G Points = 0

H Points = 0

HIGHEST INDIVIDUAL POINT VALUE FOR PART 2 (C-H) 0 (HIGHEST POINT = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Prudes Creek WWTP

Part 4: Bypassing and Overflows

- A. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to heavy rain? 0
- B. How many bypass or overflow events of untreated wastewater occurred in the last year prior to the headworks of the WWTP due to heavy rain? 0
- C. How many of the bypass or overflow events listed in Parts A and B have been corrected such that future bypass or overflow events at the same location due to heavy rain are not anticipated? 0
- D. Add together Answers A and B and subtract Answer C from that total.
A + B - C = _____ (Check the appropriate point total.)
 0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
 7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points
- E. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to equipment failure? (This includes clogged/broken lines or manholes.) 0
- F. How many bypass or overflow events of untreated wastewater occurred in the last year due to equipment failure prior to the headworks of the WWTP? (This includes clogged/broken lines or manholes.) 0
- G. How many of the bypass or overflow events listed in Parts E and F have been corrected such that future bypass or overflow events at the same location due to the same equipment failure are not anticipated? 0
- H. Add together Answers E and F and subtract Answer G from that total.
E + F - G = _____ (Check the appropriate point total.)
 0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
 7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points
- I. Add point values circled in D and H and enter the total in the blank below.

TOTAL POINT VALUE FOR PART 4 0
Enter this value on Part 11: Summary Sheet.

All bypass or overflow events that have occurred in the last year (for any reason) must be individually reported with this MWPP report.

Facility Name: Prudes Creek WWTP

Part 5: Sludge Quantity and Storage

- A. Please provide information concerning sludge quantity, characteristics, and storage practices based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months of sludge storage capacity does the wastewater treatment facility have available, either on-site or off-site? (i.e., How many months can the facility operate without land spreading or disposing of sludge?) _____

(Check the appropriate point total.)

- | | | |
|---|-------------|-------------------------------------|
| Greater than or equal to 4 months | = 0 points | <input checked="" type="checkbox"/> |
| Less than 4 months, but greater than or equal to 3 months | = 10 points | <input type="checkbox"/> |
| Less than 3 months, but greater than or equal to 2 months | = 20 points | <input type="checkbox"/> |
| Less than 2 months, but greater than or equal to 1 month | = 30 points | <input type="checkbox"/> |
| Less than one month | = 50 points | <input type="checkbox"/> |

TOTAL POINT VALUE FOR PART 5 0

Enter this value on Part 11: Summary Sheet.

Part 6: Sludge Disposal Practices and Sites

- A. Please provide the sludge disposal practices and site information based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months or years does the facility have access to and approval for sufficient land disposal sites to provide proper land disposal? (Check the appropriate point total.)

- | | | |
|--------------------|-------------|-------------------------------------|
| 36 or more months | = 0 points | <input type="checkbox"/> |
| 24 - 35 months | = 10 points | <input type="checkbox"/> |
| 12 - 23 months | = 20 points | <input checked="" type="checkbox"/> |
| 6 - 11 months | = 30 points | <input type="checkbox"/> |
| Less than 6 months | = 50 points | <input type="checkbox"/> |

TOTAL POINT VALUE FOR PART 6 20

Enter this value on Part 11: Summary Sheet.

Facility Name: Prudes Creek WWTP

Part 7: New Development

Are there any major new developments (industrial, commercial, or residential) in the last calendar year or anticipated in the next 2-3 years such that either flow or BOD₅ loadings to the sewage system could significantly increase? Estimate additional loadings below.

Design Population: _____ Design Flow: _____ MGD Design BOD₅: _____ lbs/day
Equivalent (PE)

List industrial and/or residential developments.

No major new developments planned.

Will the additional loading overload the plant? (Check the appropriate point total.)

No = 0 points Yes = 121 points

Enter the point total in the blank below.

TOTAL POINT VALUE FOR PART 7 ⁰ _____ (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Part 8: Operator Certification

Complete the *Plant and Collection System Personnel Inventory*, ADEM Form 441.

Do both the plant operator and collection system staffing comply with ADEM Administrative Code; Division 10, Operator Certification Program? (Check the appropriate point total.)

Yes = 0 points No = 121 points

TOTAL POINT VALUE FOR PART 8 ⁰ _____ (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Prudes Creek WWTP

Part 9: Financial Status

A. Are User-Charge Revenues sufficient to cover operation and maintenance expenses? If no, how are O&M costs being financed? ***Include user charge rates.***

Revenues are sufficient. The below values are based on a 5/8" meter and 6,000 gallons water use. Jefferson

County has a three tier block rate structure for residential users for 0-3, 4-6, and 7+ ccf water use.

Residential Minimum 15.00 Plus rate 6.02; 9.36; 10.69 /1,000 gal.

Industrial Minimum 15.00 Plus rate 10.51 /1,000 gal.

Monthly residential rate based on 6,000 gallons usage \$ 56.04 (includes 15% credit for residential)

****Please complete the above information based on your user charge rates for the report year. You may attach a sample water and sewer bill for clarity.***

B. What financial resources are available to pay for the wastewater improvements and/or reconstruction needs?

In 2013, Jefferson County issued Series 2013 Sewer Warrants that fund capital improvements

through 2023 at an annual average rate of \$71.9 million over the 10-year period.

Part 10: Subjective Evaluation

A. Describe briefly the physical and structural conditions of the wastewater treatment facility.

Most of the WWTP was upgraded or newly constructed in 2006 and is in good condition. Some

equipment and processes were constructed in the 80s and 90s and are in fair to average condition.

B. Describe the general condition of the sewer system (sewer lines, manholes, lift stations).

The Prudes system includes roughly 164,000' of pipe and 8 pump stations. The system's performance in

2013 was exceptional.

C. What sewage system improvements does the community have planned for construction in the next 5 years?

Routine maintenance and system renewal are budgeted within the capital improvement plan.

Sewer line repairs and replacements are continual activities planned for the collection systems.

D. What is the theoretical design life of the plant, and what is the estimated remaining useful life of the wastewater treatment facility?

Calculated remaining useful life of the structures is 50 years - years age of facility.

Remaining useful life of equipment is 25 years - years age of equipment.

Based on EPA's 2002 Clean Water and Drinking Water Infrastructure Gap Analysis Report.

E. What problems, if any, over the last year have threatened treatment or conveyance within the system?

None

F. Is the community presently involved in formal planning for treatment facility upgrading?

No.

G. How many days in the last year were there residential backups at any point in the collection system for any reason other than clogging of the lateral connection? 0

H. Does the plant have a written plan for preventive maintenance on major equipment items? If yes, describe.

Yes. Our INFOR maintenance program generate work tickets for scheduled preventive maintenance. This is backed up

by written records of scheduled service provided for each piece of equipment by our maintenance shop.

- I. Does this preventive maintenance program depict frequency of intervals, types of lubrication, and other preventive maintenance tasks necessary for each piece of equipment? (Check the appropriate response.) Yes No
- J. Are these preventive maintenance tasks, as well as equipment problems, being recorded and filed so future maintenance problems can be assessed properly? (Check the appropriate response.) Yes No
- K. Describe any major repairs or mechanical equipment replacement made in the last year and include the approximate cost for those repairs. Do not include major treatment plant construction or upgrading programs.

In our continuing automation efforts at Prudes Creek 2 LIMITORQUE actuators were purchased at a cost of 8996.00.

\$7338.43 was the cost of UV repairs.

- L. List any additional comments. (Attach additional sheets if necessary.)

Facility Name: Prudes Creek WWTP

Part 11: Summary Sheet

1. Enter in the values from Parts 1 through 8 in the left column below. Add the numbers in the left column to determine the MWPP Report point total the wastewater system generated for the previous calendar year.

| <u>Actual Values</u> | <u>Maximum Possible</u> |
|-------------------------|-------------------------|
| Part 1 <u>0</u> points | 80 points |
| Part 2 <u>0</u> points | 121 points |
| Part 3 <u>14</u> points | 40 points |
| Part 4 <u>0</u> points | 200 points |
| Part 5 <u>0</u> points | 50 points |
| Part 6 <u>20</u> points | 50 points |
| Part 7 <u>0</u> points | 121 points |
| Part 8 <u>0</u> points | 121 points |
| Total <u>34</u> points | 783 points |

2. Check the facility type that best describes the plant's treatment and disposal of wastewater.

- Mechanical plant with surface water discharge
- Aerated Lagoon or stabilization pond with surface water discharge
- Mechanical plant using land disposal of liquid wastes
- Aerated Lagoon or stabilization pond using land disposal of liquid wastes

3. Check the range that describes the action needed to address problems identified in the report.

- 0 - 70 pts. Actions as Appropriate*
- 71 - 120 pts. Departmental Recommendation Range*
- 121 - 783 Municipality Action Range*

***Other actions may be required by NPDES outside the scope of this report.**

4. Complete the *Municipal Water Pollution Prevention Resolution Form*, ADEM Form 418.


5. In Question 1, do any of the actual point values in the left column equal the maximum possible points in the right column? (Check the appropriate response) Yes No

If yes, provide a written explanation for this situation in the space below.

Prudes Creek Wastewater Treatment Plant
ATTACHMENT 2 – Raw Sewage Bypass and
SUMMARY



PRUDES CREEK BASIN 2013 DISCHARGES



NOTE: OVERFLOWS SHOWN ARE OVER 10,000 GALLONS
NONE REPORTED FOR PRUDES CREEK BASIN.



Summary of Unpermitted Discharges - Prudes Creek

January 01, 2013 through December 31, 2013

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Cause | Weather | Action Taken | Person Reporting | Title |
|-----------|---------------|----------|-------------------|----------------------|-----------------|-------|---------|--------------|------------------|-------|
|-----------|---------------|----------|-------------------|----------------------|-----------------|-------|---------|--------------|------------------|-------|

Notes:

No Unpermitted Discharges for 2013

Prudes Creek Wastewater Treatment Plant

ATTACHMENT 3 – MWPP Sewage Sludge

SURVEY



MWPP SEWAGE SLUDGE SURVEY

Facility Background Information:

1. Facility Information

Permit Number: AL0026913

Name: Prudes Creek WWTP
Street Address: 500 Water Trail Graysville, AL 35073
County: Jefferson County

2. Facility Contact

Name: Lynn D. Jones
Title: Plant Manager
Telephone: 205 - 841 - 5939
Permittee Name: Jefferson County Commission
Mailing Address: Environmental Services Department Suite A-300
716 Richard Arrington Jr. Blvd. N. Birmingham, Alabama 35203

Facility Flow Information

1. Facility Wastewater Treatment Capacity

Avg. Daily Flow for ~~2000~~ 2013 0.44 MGD
Facility Design Capacity: 0.9 MGD

2. Estimated Septage Quantity Handled (Residuals Removed from Septic Tank Systems)

Average Domestic Septage: N/A gallons per month
Average Commercial Septage: N/A gallons per month

3. Method of Septage Processing

Mixed with Influent Wastewater for Treatment
Mixed with Sewage Sludge
N/A

4. Estimated Percentage Contributing Wastewater Flow

Residential: 98 %
Industrial: %
Other: 2 % Describe: COMMERCIAL

5. List type of wastewater treatment process(es) utilized at this facility:

Screening, grit removal, aeration with activated sludge, clarification, sandfiltration,
UV disinfection

6. Estimated sewage sludge wasting rate at this facility:

or 46 lb/day dry weight
gallons per day

7. Estimated untreated sludge received from off site:

or N/A lb/day dry weight
gallons per day

8. Estimated percent solids of combined sewage sludge prior to treatment:

2.4 %

9. List the sewage sludge treatment processes used in preparing sludge for final use or disposal:

| | Sludge Quantity (untreated pounds per day) |
|--------------------------|---|
| Aerobic Digestion | |
| Thickening | |
| Drying Beds (air drying) | |
| | |

10. Estimate the total volume of sludge generated:

122.5
 (dry U.S. tons per year)

Sludge Disposal Methods

1. Which of the following describes the current method of sewage sludge disposal for this facility:

| | Current Practices | | | Proposed Practices | |
|---|-------------------|----|----------------------------------|--------------------|----|
| | Approved by ADEM | | Quantity (dry U.S. tons/year) | Approved by ADEM | |
| | Yes | No | | Yes | No |
| a. Land Application, Bulk Shipped | | | 122.5 | | X |
| X Agriculture | | | | | |
| Forest | | | | | |
| Public Contact | | | | | |
| Lawn/Home Garden | | | | | |
| b. Land Application, Bagged/Other Container | | | | | |
| Agriculture | | | | | |
| Forest | | | | | |
| Public Contact | | | | | |
| Lawn/Home Garden | | | | | |
| c. Incineration | | | | | |
| d. Subtitle D Landfill (Disposal Only) | | | | | |
| e. Lined Treatment Lagoon or Stabilization Pond | | | | | |
| f. Unlined Lagoon or Stabilization Pond | | | | | |
| g. Other (Please Describe) | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

2. If "f" was selected above and sludge is stored for 2 or more years, enter the distance between the surface disposal site and the property line: _____ feet

Pollutant Concentrations

1. Enter the total concentrations of the following analytes using existing data. Do not enter TCLP results.

| Analyte | Concentration (mg/kg or ppm) | Sample Type | Sample Date | Detection Level of Analysis |
|-------------------------|------------------------------|-------------|-------------|-----------------------------|
| Arsenic | <PQL | grab | * | 11.0 |
| Cadmium | <PQL | grab | * | 8 |
| Chromium | 36.3 | grab | * | 8.0 |
| Copper | 210 | grab | * | 8.0 |
| Lead | 38.8 | grab | * | 15.0 |
| Mercury | 4.8 | grab | * | 0.6 |
| Molybdenum | <PQL | grab | * | 5.0 |
| Nickel | 23.3 | grab | * | 6.0 |
| Selenium | <PQL | grab | * | 15.0 |
| Zinc | 1,150 | grab | * | 18.0 |
| Ammonium-Nitrogen | - | N/A | N/A | N/A |
| Nitrate-Nitrogen | - | N/A | N/A | N/A |
| Total Kjeldahl Nitrogen | 20,875 | grab | * | 1.8 |

2. Enter the estimated or determined percent solids of the sewage sludge when sampled for the above analysis: 48 %

Treatment Provided for Sewage Sludge at the Facility

1. Which class of pathogen reduction does the sewage sludge meet at the facility? (As defined in 40 CFR Part 503)

Class A

Alternative A1 - Time and Temperature

Alternative A2 - Alkaline Treatment

Alternative A3 - Analysis and Operation

Alternative A4 - Analysis Only

Alternative A5 - Processes to Further Reduce Pathogens (PFRP)

Heat Drying

Thermophilic Aerobic Digestion

Heat Treatment

Pasteurization

Gamma Ray Irradiation

Beta Ray Irradiation

Composting

Alternative A6 - PFRP Equivalent

Class B

Alternative B1 - Fecal Coliform Count

Alternative B2 - Process to Significantly Reduce Pathogens (PSRP)

Aerobic Digestion

Air Drying

Anaerobic Digestion

Composting

Lime Stabilization

Alternative B3 - PSRP Equivalent

Neither or Unknown

Vector Attraction Control

- Option 1 - Minimum 38% Reduction in Volatile Solids
- Option 2 - Anaerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 3 - Aerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 4 - Specific Oxygen Uptake Rate (SOUR) for Aerobically Digested Sludge
- Option 5 - Aerobic Processes plus Elevated Temperature
- Option 6 - Raised pH to 12 and Retained at 11.5
- Option 7 - 75% Solids with no Unstabilized Solids
- Option 8 - 90% Solids with Unstabilized Solids
- Option 9 - Injection Below Land Surface
- X Option 10 - Incorporation into Soil within 6 or 8 Hours
- Option 11 - Covering Active Sewage Sludge Unit Daily
- None of the Above

Groundwater Monitoring

1. If disposal practice is surface disposal or land application, is groundwater monitoring required or performed at the site?

- Yes (If yes, please submit a copy of the groundwater monitoring reports along with this survey. Also please provide the approximate depth to groundwater and the groundwater monitoring procedures used to obtain the data.)
X No

Land Application of Sewage Sludge

Answer the following questions if sewage sludge is applied to land.

1. If sewage sludge is land applied in bulk form, what type of crop or other vegetation is grown on this site?

Tifton Bermuda grass and Rye Grass.

2. If sewage sludge is land applied in bulk form, what is the nitrogen requirement for this crop or vegetation?
The nitrogen requirement is 600lbs / acre /year.

3. If sewage sludge is land applied in bulk form, briefly describe the nature of any complaints filed from neighbors?

No complaints received.

Note: Permittees that submitted the "Annual Report Review Form" for sludge to the EPA may submit a copy with the MWPP in lieu of this Attachment.

Prudes Creek Wastewater Treatment Plant
ATTACHMENT 4 – Plant and Collection System
Personnel Inventory



PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Five Mile Creek WWTP PLANT GRADE: IV
 PERMIT NUMBER: AL0026913
 PLANT MANAGER: Lynn Jones TEL. # (205) 841-5939
 SYSTEM MANAGER David Denard TEL. # (205) 325-5806

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|----|--------------------|----------------------------|--------------|------------|
| 1 | Lynn Jones | Plant Manager | C003327 | 9/30/2014 |
| 2 | Robert Tyler | Shift Supervisor | C003008 | 11/30/2015 |
| 3 | Randy Maxwell | Shift Supervisor | C003076 | 11/30/2015 |
| 4 | Terry Joe MaHaffey | Shift Supervisor | C003135 | 8/31/2016 |
| 5 | Tony Sutton | Shift Supervisor | C002294 | 11/30/2015 |
| 6 | Mark Cruce | Operator II | C001682 | 3/31/2015 |
| 7 | Adam Smith | Operator II | C002236 | 4/30/2016 |
| 8 | Daniel Tesseneer | Operator II | C006050 | 6/30/2014 |
| 9 | Ellis Brown | Operator I | | |
| 10 | Sam Shears | Operator I | | |
| 11 | Todd Smitherman | Operator I | | |
| 12 | Michael Wright | Operator I | | |

| | MAN HRS./WK NUMBER | |
|-----------------------|--------------------|---|
| Avg Daily | 40 | 7 |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | 40 | 8 |
| MANAGEMENT/SUPERVISOR | 40 | 5 |
| OPERATOR(S): | 40 | 3 |
| TRAINEE(S) | 40 | 4 |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | |
|---------|---|
| 1ST | 5 |
| 2ND | 2 |
| 3rd | 2 |
| weekend | 2 |

| START TIME | |
|------------|---------|
| M -F | Sat-Sun |
| 7:00a.m. | 7:00am |
| 3:00p.m. | 7:00pm |
| 11:00p.m. | 7:00am |

OTHER PLANT WORKERS

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | X | X | X | X | X | X | X |
| 2ND | X | X | X | X | X | X | X |
| 3RD | X | X | X | X | X | X | X |

ADEM USE ONLY

- DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
- DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES |
|-----|
| |
| |

NO

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

Continued

FACILITY NAME: Prudes Creek WWTP PLANT GRADE: IV
 PERMIT NUMBER: AL0026913
 PLANT SUPERINTENDENT: Lynn Jones TEL. # (205) 841-5939
 SYSTEM MANAGER: David Denard TEL. # (205) 325-5806

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|----|------------------|----------------------------|--------------|-----------|
| 15 | Garren Hubbert | Trainee | | |
| 16 | Johnny McDonough | Trainee | | |
| 17 | Billy Joe Poe | Trainee | | |
| 18 | Samuel Shears | Trainee | | |
| 19 | Todd Smitherman | Trainee | | |
| 20 | Daniel Tesseneer | Trainee | | |
| 21 | Michael Wright | Trainee | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

| | MAN HRS./WK | NUMBER |
|------------------------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | | |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | | |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | | | |
|-----|--|------------|--|
| 1ST | | START TIME | |
| 2ND | | | |
| 3RD | | | |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | | | | | | | |
| 2ND | | | | | | | |
| 3RD | | | | | | | |

ADEM USE ONLY

- DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
- DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|-----|----|
| | |

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Sewer Line Maintenance

PLANT GRADE: IV

PERMIT NUMBER: _____

PLANT SUPERINTENDENT: _____

TEL. # (205) 540-7585

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|----------------|----------------------------|--------------|------------|
| 1. | Brian Champion | I (c) | C002094 | 6/30/2015 |
| 2. | Don Goodwin | I (c) | C005423 | 6/30/2015 |
| 3. | Lavon Evans | I (c) | C004631 | 12/31/2014 |
| 4. | Brian Rohling | I (c) | C005418 | 6/30/2015 |
| 5. | | | | |
| 6. | | | | |
| 7. | | | | |
| 8. | | | | |
| 9. | | | | |
| 10. | | | | |

COLLECTION SYSTEM OPERATORS:

| | | | |
|----|--|--|--|
| 1. | | | |
| 2. | | | |
| 3. | | | |
| 4. | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | | |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | | |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | | |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

1ST

2ND

3RD

START TIME

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | | | | | | | |
| 2ND | | | | | | | |
| 3RD | | | | | | | |

ADEM USE ONLY

- DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
- DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|--------------------------|--------------------------|
| <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> |

Municipal Water Pollution Prevention (MWPP) Annual Report Calendar Year 2013

For the

Trussville WWTP

as required by the
Alabama Department of Environmental Management NPDES Program



Prepared by
Jefferson County Commission
Environmental Services Department

May 31, 2014

JEFFERSON COUNTY COMMISSION



DAVID CARRINGTON - PRESIDENT
GEORGE F. BOWMAN
SANDRA LITTLE BROWN - PRESIDENT PRO TEMPORE
T. JOE KNIGHT
JAMES A. "JIMMIE" STEPHENS

DAVID CARRINGTON – COMMISSIONER
ENVIRONMENTAL SERVICES

TONY PETELOS, COUNTY MANAGER

Office of

DAVID DENARD
Director of Environmental Services
Suite A-300
716 Richard Arrington, Jr. Blvd. N.
Birmingham, Alabama 35203
Telephone (205) 325-5496
Fax (205) 325-5981

May 31, 2014

Mr. Nic Caraway
Alabama Department of Environmental Management
Water Division – Municipal Branch
P.O. Box 301463
Montgomery, AL 36130-1463

RE: Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013

Mr. Caraway:

The Jefferson County Environmental Services Department submits the above referenced report for the Trussville Wastewater Treatment Facility, NPDES Permit No. AL0022934. Included is information as required in ADEM Form 41701/06ml, bypass/overflow event reports, MWPP Sewage Sludge Survey, and the Plant & Collection System Personnel Inventory.

If you have any questions regarding this information, please contact me at 205.325.5979 or Celeste Brown at Jefferson County Barton Laboratory at 205.238.3859.

Sincerely,

David Denard, Director
Environmental Services Department

pc: Celeste Brown, JCESD Barton Laboratory
Daniel White, JCESD Deputy Director
David Willoughby, Trussville WWTP

**MUNICIPAL WATER POLLUTION PREVENTION (MWPP)
ANNUAL REPORT**

SUBMITTED BY:

TREATMENT FACILITY: Trussville WWTP **NPDES #:** AL 0022934

MUNICIPALITY: Jefferson County **COUNTY:** Jefferson

CONTACT PERSON: David Denard

Municipal Official

Director of Environmental Services

Title

Telephone #: (205) 325-5979 **Fax #:** (205) 325-5981

Email Address: denardd@jccal.org

CHIEF OPERATOR: David Willoughby

Name

Telephone #: (205) 655-3617 **Fax #:** (205) 655-9240

Email Address: willoughbyd@jccal.org

Date: May 14, 2014

REVIEWED BY: Daniel White P.E., ESD Engineer

Consulting Engineer

Telephone #: 205 214 8610 **Fax #:** 205 325 5688

Date: May 14, 2014

**MWPP Annual Report
Information Source List**

The following information will be needed to complete the compliance maintenance report that covers the calendar year of 2013 (due **May 31**, 2014).

- Part 1 A. The average plant influent flow for each month (million gallons per day/MGD) during the year.
B. The average plant influent BOD (CBOD) for each month (mg/l and lb/day) in the year.
C. The plant's average design flow (MGD) and design BOD loading (lbs/day).
- Part 2 A. The monthly average permit and DMR effluent concentration for BOD (CBOD), TSS, NH3-N, and/or TKN in mg/l for the year
B. The monthly average effluent limits and DMR loading for BOD, TSS, NH3-N, and/or TKN in lbs/day for the year
- Part 3 The age of the treatment plant defined as the number of years since the last major reconstruction to increase the organic or hydraulic capacity of the plant. The last calendar year minus the year the new construction was brought on-line.
- Part 4 Bypass and overflow information. This is the number of bypass or overflow events of untreated wastewater due to heavy rain or equipment failure whether intentional or inadvertent from all collection systems tributary to the treatment facility.
- Part 5 A. Describe the characteristics and quantity of sludge generated.
B. If sludge is landspread, how many months of sludge storage does the plant have? This should include on-site and off-site storage from the treatment plant. The digester capacity may be used in the calculation.
- Part 6 A. Sludge Disposal Method
B. The number of approved land disposal sites for sludge available, and how many months or years these disposal sites will these be available for use.
- Part 7 The number of sewer extensions installed in the community last year--the design population, design flow, and design BOD for each sewer extension.
- Part 8 Operator Certification
- Part 9 Financial Status
- Part 10 Subjective Evaluation
- Part 11 Summary Sheet

State of Alabama
MWPP Annual Report
Department of Environmental Management

Instructions to the Operator-in-Charge

1. Complete all sections of the MWPP Report to the best of your ability.
2. Parts 1 through 8 contain questions for which points will be generated. These points are intended to communicate to the Department and the governing body or owner the actions necessary to prevent effluent violations. Enter the point totals from Parts 1 through 8 on Part 11: Summary Sheet.
3. Add the point totals on Part 11: Summary Sheet.
4. Submit the MWPP Report to the governing body and the consulting engineer and owner for review and approval.
5. The governing body should pass a resolution which contains the following points:
 - a. The resolution should acknowledge the governing body or owner has reviewed the MWPP Report.
 - b. The resolution should indicate what actions will be taken to prevent effluent violations.
 - c. The resolution should provide any other information the governing body or owner deems appropriate.
6. **The MWPP Report and the resolution must be submitted by May 31st to Municipal Section, Water Division, ADEM, P.O. Box 301463, Montgomery, AL 36130-1463.**

Facility Name: Trussville WWTP

Part 1: Influent Loading/Flows

- A. List the average monthly volumetric flows and BOD₅ (CBOD₅) loadings received at your facility during the last calendar year.

| <u>Month</u> | <u>Column 1 Average Monthly Flowrate (MGD)</u> | <u>Column 2 Average Monthly BOD₅ (CBOD₅) Concentration (mg/l)</u> | <u>Column 3 Average Loading BOD₅ (CBOD₅) (lbs/day)**</u> |
|--------------------|--|---|--|
| January | 3.51 | 80 | 2229 |
| February | 3.47 | 81 | 2231 |
| March | 2.62 | 93 | 2025 |
| April | 2.66 | 86 | 1748 |
| May | 2.87 | 80 | 1651 |
| June | 2.33 | 86 | 1561 |
| July | 2.23 | 108 | 1809 |
| August | 2.54 | 86 | 1618 |
| September | 1.75 | 111 | 1633 |
| October | 1.51 | 146 | 1825 |
| November | 1.69 | 141 | 1883 |
| December | 2.83 | 72 | 1769 |
| Annual Avg. | 2.50 | 98 | 1832 |

**As reported on NPDES Discharge Monitoring Reports (DMRs) and as required by EPA's NPDES Self-Monitoring System, User Guide, March 1985.

- B. List the average design flow and average design BOD₅ loading for the facility below. If you are not aware of these design quantities, contact your consulting engineer or the Alabama Department of Environmental Management.

| | <u>Average Design Flow</u> | <u>Average Design BOD₅ Loading (lbs/day)</u> |
|----------------------------|----------------------------|---|
| Design Criteria | 4.0 | 10014 |
| 90% of the Design Criteria | 3.6 | 9012 |

C. How many times did the monthly flow (Column 1) to the WWTP exceed 90% of design flow?
_____ (Check the appropriate point total)

0 - 4 = 0 points 5 or more = 5 points

D. How many times did the monthly flow (Column 1) to the WWTP exceed the design flow?
_____ (Check the appropriate point total)

0 = 0 points 1 - 2 = 5 points 3 - 4 = 10 points 5 or more = 15 points

E. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed 90% of the design loading? _____ (Check the appropriate point total)

0 - 1 = 0 points 2 - 4 = 5 points 5 or more = 10 points

F. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed the design loading? _____ (Check the appropriate point total)

0 = 0 points 1 = 10 points 2 = 20 points 3 = 30 points 4 = 40 points 5 or more = 50 points

G. Enter each point value marked for C through F and enter the sum in the appropriate blank below.

C points = 0

D points = 0

E points = 0

F points = 0

TOTAL POINTS VALUE OR PART 1 0

Enter this value on Part 11: Summary Sheet.

*To obtain equivalent BOD₅ loading for comparison with design loading for those permittees using influent CBOD₅, divide annual average CBOD₅, loading in lbs/day from Part 1, A by 0.7.

Facility Name: Trussville WWTP

Part 2: Effluent Quality/Plant Performance

A. List the monthly average permit limits for the facility in the blanks below and the average monthly effluent DMR BOD₅, (CBOD₅) TSS, NH₃-N and/or TKN concentration produced by the facility during the last calendar year.

(1) NPDES Permit Concentration

| Permit Limit | Months | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------|---------|--|---------------|------------------------------|---------------|
| | | May-Nov | 3.0 | 30.0 | 1.0 |
| | Dec-Apr | 10.0 | 30.0 | 1.0 | 3.0 |

(2) DMR Concentration

| Qtr | Month | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------------|-----------|--|---------------|------------------------------|---------------|
| 1 | January | 0.60 | 0.85 | 0.21 | 0.50 |
| | February | 0.71 | 0.83 | 0.06 | 0.21 |
| | March | 1.6 | 1.3 | 0.02 | 0.21 |
| 2 | April | 0.37 | 1.2 | 0.0 | 0.21 |
| | May | 0.28 | 1.6 | 0.0 | 0.29 |
| | June | 0.57 | 1.4 | 0.0 | 0.27 |
| 3 | July | 0.54 | 1.2 | 0.02 | 0.27 |
| | August | 0.31 | 1.6 | 0.004 | 0.25 |
| | September | 0.38 | 1.7 | 0.005 | 0.34 |
| 4 | October | 0.56 | 2.5 | 0.0 | 0.41 |
| | November | 0.51 | 5.4 | 0.02 | 0.63 |
| | December | 0.64 | 4.9 | 0.04 | 0.57 |
| Annual Avg. | | 0.59 | 2.0 | 0.03 | 0.35 |

B. List the monthly average permit limit and DMR loadings below.

(1) NPDES Permit Loading

| Permit Limit | Months | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|-----------------|---------|---|------------------|---------------------------------|------------------|
| | May-Nov | 100 | 1000 | 33.3 | 66.7 |
| Dec-Apr | 333 | 1000 | 33.3 | 100 | |

(2) DMR Loading

| Qtr | Month | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|--------------------|-----------|---|------------------|---------------------------------|------------------|
| 1 | January | 17 | 39 | 13 | 25 |
| | February | 20 | 26 | 2.6 | 7.0 |
| | March | 29 | 31 | 0.83 | 5.0 |
| 2 | April | 7.6 | 25 | 0.00 | 4.1 |
| | May | 5.1 | 31 | 0.00 | 6.3 |
| | June | 13 | 26 | 0.00 | 5.5 |
| 3 | July | 10.9 | 28 | 0.48 | 5.6 |
| | August | 6.0 | 32 | 0.06 | 5.1 |
| | September | 5.7 | 26 | 0.10 | 5.1 |
| 4 | October | 7.0 | 31 | 0.00 | 5.0 |
| | November | 8.0 | 75 | 0.54 | 9.3 |
| | December | 19 | 141 | 1.7 | 16 |
| Annual Avg. | | 12 | 43 | 1.6 | 8.2 |

C. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

D. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

E. During the past year did the effluent TSS concentration (mg/l) or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

F. During the past year did the TSS concentration (mg/l) and/or loading (lbs/day) exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

G. During the past year did the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

H. During the past year did either the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

I. Enter each point value checked for C through H in the blanks below.

C Points = 0

D Points = 0

E Points = 0

F Points = 0

G Points = 0

H Points = 0

HIGHEST INDIVIDUAL POINT VALUE FOR PART 2 (C-H) 0 (HIGHEST POINT = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Trussville WWTP

Part 4: Bypassing and Overflows

- A. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to heavy rain? 0
- B. How many bypass or overflow events of untreated wastewater occurred in the last year prior to the headworks of the WWTP due to heavy rain? 0
- C. How many of the bypass or overflow events listed in Parts A and B have been corrected such that future bypass or overflow events at the same location due to heavy rain are not anticipated? 0
- D. Add together Answers A and B and subtract Answer C from that total.
A + B - C = _____ (Check the appropriate point total.)
 0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
 7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points
- E. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to equipment failure? (This includes clogged/broken lines or manholes.) 0
- F. How many bypass or overflow events of untreated wastewater occurred in the last year due to equipment failure prior to the headworks of the WWTP? (This includes clogged/broken lines or manholes.) 4
- G. How many of the bypass or overflow events listed in Parts E and F have been corrected such that future bypass or overflow events at the same location due to the same equipment failure are not anticipated? 4
- H. Add together Answers E and F and subtract Answer G from that total.
E + F - G = _____ (Check the appropriate point total.)
 0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
 7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points
- I. Add point values circled in D and H and enter the total in the blank below.

TOTAL POINT VALUE FOR PART 4 0

Enter this value on Part 11: Summary Sheet.

All bypass or overflow events that have occurred in the last year (for any reason) must be individually reported with this MWPP report.

Facility Name: Trussville WWTP

Part 5: Sludge Quantity and Storage

- A. Please provide information concerning sludge quantity, characteristics, and storage practices based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months of sludge storage capacity does the wastewater treatment facility have available, either on-site or off-site? (i.e., How many months can the facility operate without land spreading or disposing of sludge?) 4

(Check the appropriate point total.)

- | | | |
|---|-------------|-------------------------------------|
| Greater than or equal to 4 months | = 0 points | <input checked="" type="checkbox"/> |
| Less than 4 months, but greater than or equal to 3 months | = 10 points | <input type="checkbox"/> |
| Less than 3 months, but greater than or equal to 2 months | = 20 points | <input type="checkbox"/> |
| Less than 2 months, but greater than or equal to 1 month | = 30 points | <input type="checkbox"/> |
| Less than one month | = 50 points | <input type="checkbox"/> |

TOTAL POINT VALUE FOR PART 5 0

Enter this value on Part 11: Summary Sheet.

Part 6: Sludge Disposal Practices and Sites

- A. Please provide the sludge disposal practices and site information based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months or years does the facility have access to and approval for sufficient land disposal sites to provide proper land disposal? (Check the appropriate point total.)

- | | | |
|--------------------|-------------|-------------------------------------|
| 36 or more months | = 0 points | <input type="checkbox"/> |
| 24 - 35 months | = 10 points | <input type="checkbox"/> |
| 12 - 23 months | = 20 points | <input checked="" type="checkbox"/> |
| 6 - 11 months | = 30 points | <input type="checkbox"/> |
| Less than 6 months | = 50 points | <input type="checkbox"/> |

TOTAL POINT VALUE FOR PART 6 20

Enter this value on Part 11: Summary Sheet.

Facility Name: Trussville WWTP

Part 7: New Development

Are there any major new developments (industrial, commercial, or residential) in the last calendar year or anticipated in the next 2-3 years such that either flow or BOD₅ loadings to the sewage system could significantly increase? Estimate additional loadings below.

Design Population: _____
Equivalent (PE)

Design Flow: _____ MGD

Design BOD₅: _____ lbs/day

List industrial and/or residential developments.

No major new development

Will the additional loading overload the plant? (Check the appropriate point total.)

No = 0 points Yes = 121 points

Enter the point total in the blank below.

TOTAL POINT VALUE FOR PART 7 0 (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Part 8: Operator Certification

Complete the *Plant and Collection System Personnel Inventory*, ADEM Form 441.

Do both the plant operator and collection system staffing comply with ADEM Administrative Code; Division 10, Operator Certification Program? (Check the appropriate point total.)

Yes = 0 points No = 121 points

TOTAL POINT VALUE FOR PART 8 0 (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Trussville WWTP

Part 9: Financial Status

A. Are User-Charge Revenues sufficient to cover operation and maintenance expenses? If no, how are O&M costs being financed? ***Include user charge rates.***

Revenues are sufficient. The below values are based on a 5/8" meter and 6,000 gallons water use. Jefferson

County has a three tier block rate structure for residential users for 0-3, 4-6, and 7+ ccf water use.

Residential Minimum \$15.00 Plus rate \$6.02; 9.36; 10.69 /1,000 gal.

Industrial Minimum \$15.00 Plus rate \$10.51 /1,000 gal.

Monthly residential rate based on 6,000 gallons usage \$ 56.04 (includes 15% credit for residential)

****Please complete the above information based on your user charge rates for the report year. You may attach a sample water and sewer bill for clarity.***

B. What financial resources are available to pay for the wastewater improvements and/or reconstruction needs?

In 2013, Jefferson County issued Series 2013 Sewer Warrants that fund capital improvements

through 2023 at an annual average rate of \$71.9 million over the 10-year period.

Part 10: Subjective Evaluation

A. Describe briefly the physical and structural conditions of the wastewater treatment facility.

All structures are in good condition.

B. Describe the general condition of the sewer system (sewer lines, manholes, lift stations).

The Trussville system includes roughly 460,000' of pipe and 8 pumping stations. The system's rate of

SSO's/100 miles of sewer is slightly above the department's goal. There are no known capacity deficiencies.

The general condition of the system is good.

C. What sewage system improvements does the community have planned for construction in the next 5 years?

Completion of Phase I TMDL currently in construction; Phase II TMDL Improvements;

Improvements to Wisteria Trace and Cedar Creek pump stations.

D. What is the theoretical design life of the plant, and what is the estimated remaining useful life of the wastewater treatment facility?

Calculated remaining useful life of the structures is 35 years (50 years - 15 years age of facility).

Calculated remaining useful life of the equipment is 10 years (25 years - 15 years of equipment).

Based on EPA's 2002 Clean Water and Drinking Water Infrastructure Gap Analysis Report.

E. What problems, if any, over the last year have threatened treatment or conveyance within the system?

None

F. Is the community presently involved in formal planning for treatment facility upgrading?

No.

G. How many days in the last year were there residential backups at any point in the collection system for any reason other than clogging of the lateral connection? 6

H. Does the plant have a written plan for preventive maintenance on major equipment items? If yes, describe.

Yes. O & M Manuals are used for all equipment maintenance schedules. Preventive maintenance schedules are input into

the INFOR maintenance system and PM work orders are automatically generated. All equipment PM

schedules and records are maintained in the INFOR system.

- I. Does this preventive maintenance program depict frequency of intervals, types of lubrication, and other preventive maintenance tasks necessary for each piece of equipment? (Check the appropriate response.) Yes No
- J. Are these preventive maintenance tasks, as well as equipment problems, being recorded and filed so future maintenance problems can be assessed properly? (Check the appropriate response.) Yes No
- K. Describe any major repairs or mechanical equipment replacement made in the last year and include the approximate cost for those repairs. Do not include major treatment plant construction or upgrading programs.

- L. List any additional comments. (Attach additional sheets if necessary.)

Facility Name: Trussville WWTP

Part 11: Summary Sheet

1. Enter in the values from Parts 1 through 8 in the left column below. Add the numbers in the left column to determine the MWPP Report point total the wastewater system generated for the previous calendar year.

| <u>Actual Values</u> | <u>Maximum Possible</u> |
|----------------------------|-------------------------|
| Part 1 <u> 0 </u> points | 80 points |
| Part 2 <u> 0 </u> points | 121 points |
| Part 3 <u> 30 </u> points | 40 points |
| Part 4 <u> 0 </u> points | 200 points |
| Part 5 <u> 0 </u> points | 50 points |
| Part 6 <u> 20 </u> points | 50 points |
| Part 7 <u> 0 </u> points | 121 points |
| Part 8 <u> 0 </u> points | 121 points |
| Total <u> 50 </u> points | 783 points |

2. Check the facility type that best describes the plant's treatment and disposal of wastewater.

- Mechanical plant with surface water discharge
- Aerated Lagoon or stabilization pond with surface water discharge
- Mechanical plant using land disposal of liquid wastes
- Aerated Lagoon or stabilization pond using land disposal of liquid wastes

3. Check the range that describes the action needed to address problems identified in the report.

- 0 - 70 pts. Actions as Appropriate*
- 71 - 120 pts. Departmental Recommendation Range*
- 121 - 783 Municipality Action Range*

***Other actions may be required by NPDES outside the scope of this report.**

4. Complete the *Municipal Water Pollution Prevention Resolution Form*, ADEM Form 418.

5. In Question 1, do any of the actual point values in the left column equal the maximum possible points in the right column? (Check the appropriate response) Yes No


If yes, provide a written explanation for this situation in the space below.

Trussville Wastewater Treatment Plant
ATTACHMENT 2 – Raw Sewage Bypass and

SUMMARY



TRUSSVILLE BASIN 2013 DISCHARGES



NOTE: OVERFLOWS SHOWN ARE OVER 10,000 GALLONS.

JEFFERSON COUNTY
ENVIRONMENTAL SERVICES
PLOTTED: 2-11-14



Summary of Unpermitted Discharges - Trussville

January 01, 2013 through December 31, 2013

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|----------------------|-------------------|----------------------|-----------------|---------|--------------------|---------|------------------|------------------|------------------------------|
| T00042 | 3/8/13 | 802 Chalkville Rd | Trussville | Ground Absorbed | 2 | Manhole | Grease/Roots/Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Manhole not overflowing upon crew arrival, but there was evidence on the ground.</i> | | | | | | | | | | | |
| T00043 | 4/6/13 | 527 Rockridge Ave | Trussville | Ground Absorbed | 26,652 | Pipe | Roots/Broken Pipe | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| T00044 | 4/11/13 | 111 S Chalkville Rd | Trussville | Pinchgut Creek | 200 | Manhole | Grease/Debris/Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| T00046 | 7/3/13 | 7473 Gadsden Highway | Trussville | Drainage Ditch | 6,625 | Manhole | Grease/Roots/Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |

Trussville Wastewater Treatment Plant
ATTACHMENT 3 – MWPP Sewage Sludge
SURVEY



MWPP SEWAGE SLUDGE SURVEY

Facility Background Information:

1. Facility Information Permit Number: AL0022934

Name: Trussville WWTP

Street Address: 325 City Hall Drive

County: Jefferson

2. Facility Contact

Name: David Willoughby

Title: Plant Superintendent

Telephone: (205) 655-3617

Permittee Name: Jefferson County Commission- Trussville WWTP

Mailing Address: Suite A-300, 716 Richard Arrington JR. Blvd. N.
Birmingham AL 35203

Facility Flow Information

1. Facility Wastewater Treatment Capacity

| | | |
|---------------------------|------------|-----|
| Avg. Daily Flow for 2013 | <u>2.5</u> | MGD |
| Facility Design Capacity: | <u>4.0</u> | MGD |

2. Estimated Septage Quantity Handled (Residuals Removed from Septic Tank Systems)

| | | |
|-----------------------------|------------|-------------------|
| Average Domestic Septage: | <u>N/A</u> | gallons per month |
| Average Commercial Septage: | <u>N/A</u> | gallons per month |

3. Method of Septage Processing

Mixed with Influent Wastewater for Treatment

Mixed with Sewage Sludge

N/A

4. Estimated Percentage Contributing Wastewater Flow

| | | |
|--------------|-----------|---|
| Residential: | <u>90</u> | % |
| Industrial: | <u>2</u> | % |
| Other: | <u>8</u> | % |

Describe: Commercial

5. List type of wastewater treatment process(es) utilized at this facility:
Bar Screening, Grit Removal, Extended Aeration with Activated Sludge,
Clarification, UV Disinfection, Step Aeration

6. Estimated sewage sludge wasting rate at this facility: _____ lb/day dry weight
or 21,457 gallons per day

7. Estimated untreated sludge received from off site: _____ lb/day dry weight
or _____ gallons per day

8. Estimated percent solids of combined sewage sludge prior to treatment: 2 %

9. List the sewage sludge treatment processes used in preparing sludge for final use or disposal:

| | Sludge Quantity (untreated pounds per day) |
|---------------------------------|---|
| Aerobic Digestion | |
| Thicker | |
| Drying Beds (Air Drying) | |
| | |

10. Estimate the total volume of sludge generated:

614
(dry U.S. tons per year)

Sludge Disposal Methods

1. Which of the following describes the current method of sewage sludge disposal for this facility:

| | Current Practices Approved by ADEM | | Quantity (dry U.S. tons/year) | Proposed Practices Approved by ADEM | |
|--|---------------------------------------|--------------------------|----------------------------------|--|--------------------------|
| | Yes | No | | Yes | No |
| a. <input checked="" type="checkbox"/> Land Application, Bulk Shipped | | | 614 | | |
| <input checked="" type="checkbox"/> Agriculture | X | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Forest | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Public Contact | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Lawn/Home Garden | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| b. <input type="checkbox"/> Land Application, Bagged/Other Container | | | | | |
| <input type="checkbox"/> Agriculture | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Forest | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Public Contact | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Lawn/Home Garden | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| c. <input type="checkbox"/> Incineration | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| d. <input type="checkbox"/> Subtitle D Landfill (Disposal Only) | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| e. <input type="checkbox"/> Lined Treatment Lagoon or Stabilization Pond | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| f. <input type="checkbox"/> Unlined Lagoon or Stabilization Pond | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| g. <input type="checkbox"/> Other (Please Describe) | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | | | |
| | | | | | |
| | | | | | |

2. If "f" was selected above and sludge is stored for 2 or more years, enter the distance between the surface disposal site and the property line: N/A feet

Pollutant Concentrations

1. Enter the total concentrations of the following analytes using existing data. Do not enter TCLP results.

| Analyte | Concentration (mg/kg or ppm) | Sample Type | Sample Date | Detection Level of Analysis |
|-------------------------|------------------------------|-------------|-------------|-----------------------------|
| Arsenic | <PQL | Grab | * | 11.0 |
| Cadmium | <PQL | Grab | * | 5.0 |
| Chromium | 62 | Grab | * | 6.0 |
| Copper | 2,075 | Grab | * | 5.0 |
| Lead | 24 | Grab | * | 12.0 |
| Mercury | 1.9 | Grab | * | 0.03 |
| Molybdenum | 9.2 | Grab | * | 6.0 |
| Nickel | 32 | Grab | * | 6.0 |
| Selenium | <PQL | Grab | * | 12.0 |
| Zinc | 1,317.5 | Grab | * | 8.0 |
| Ammonium-Nitrogen | | N/A | N/A | N/A |
| Nitrate-Nitrogen | | N/A | N/A | N/A |
| Total Kjeldahl Nitrogen | 38,500 | Grab | * | 0.09 |

PQL=Practical Quantitative Limit

*= Yearly Average

2. Enter the estimated or determined percent solids of the sewage sludge when sampled for the above analysis: 61 %

Treatment Provided for Sewage Sludge at the Facility

1. Which class of pathogen reduction does the sewage sludge meet at the facility? (As defined in 40 CFR Part 503)

Class A

Alternative A1 - Time and Temperature

Alternative A2 - Alkaline Treatment

Alternative A3 - Analysis and Operation

Alternative A4 - Analysis Only

Alternative A5 - Processes to Further Reduce Pathogens (PFRP)

Heat Drying

Thermophilic Aerobic Digestion

Heat Treatment

Pasteurization

Gamma Ray Irradiation

Beta Ray Irradiation

Composting

Alternative A6 - PFRP Equivalent

Class B

Alternative B1 - Fecal Coliform Count

Alternative B2 - Process to Significantly Reduce Pathogens (PSRP)

Aerobic Digestion

Air Drying

Anaerobic Digestion

Composting

Lime Stabilization

Alternative B3 - PSRP Equivalent

Neither or Unknown

- Option 1 - Minimum 38% Reduction in Volatile Solids
- Option 2 - Anaerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 3 - Aerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 4 - Specific Oxygen Uptake Rate (SOUR) for Aerobically Digested Sludge
- Option 5 - Aerobic Processes plus Elevated Temperature
- Option 6 - Raised pH to 12 and Retained at 11.5
- Option 7 - 75% Solids with no Unstabilized Solids
- Option 8 - 90% Solids with Unstabilized Solids
- Option 9 - Injection Below Land Surface
- Option 10 - Incorporation into Soil within 6 or 8 Hours
- Option 11 - Covering Active Sewage Sludge Unit Daily
- None of the Above

Groundwater Monitoring

1. If disposal practice is surface disposal or land application, is groundwater monitoring required or performed at the site?

- Yes (If yes, please submit a copy of the groundwater monitoring reports along with this survey. Also please provide the approximate depth to groundwater and the groundwater monitoring procedures used to obtain the data.)
- No

Land Application of Sewage Sludge

Answer the following questions if sewage sludge is applied to land.

1. If sewage sludge is land applied in bulk form, what type of crop or other vegetation is grown on this site?

Tifton Bermuda Grass, Ryegrass

2. If sewage sludge is land applied in bulk form, what is the nitrogen requirement for this crop or vegetation?

600lb/acre/year (Reclamation Site)

3. If sewage sludge is land applied in bulk form, briefly describe the nature of any complaints filed from neighbors?

No complaints have been received.

Note: Permittees that submitted the "Annual Report Review Form" for sludge to the EPA may submit a copy with the MWPP in lieu of this Attachment.

Trussville Wastewater Treatment Plant
ATTACHMENT 4 – Plant and Collection System
Personnel Inventory



PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Trussville WWTP

PLANT GRADE: III

PERMIT NUMBER: AL0022934

PLANT SUPERINTENDENT: David Willoughby

TEL. # (205) 655-3617

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5806

PLANT OPERATORS:

| NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|---------------------|-------------------------|--------------|------------|
| 1. David Willoughby | IV | C002616 | 11/30/2015 |
| 2. Brian Key | IV | C003285 | 12/31/2014 |
| 3. Ladonna Coalburn | IV | C002043 | 12/31/2014 |
| 4. Rosemary Sparks | IV | C002168 | 12/31/2014 |
| 5. Ronald Johnson | II | C005501 | 2/28/2014 |
| 6. | | | |
| 7. | | | |
| 8. | | | |
| 9. | | | |
| 10. | | | |

COLLECTION SYSTEM OPERATORS:

| | | | |
|----|--|--|--|
| 1. | | | |
| 2. | | | |
| 3. | | | |
| 4. | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | 120 | 3 |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | 40 | 1 |
| GRADE III | | |
| GRADE IV | 40 | 1 |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | 40 | 1 |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | | | |
|-----|---|------------|-----|
| 1ST | 3 | START TIME | 700 |
| 2ND | | | |
| 3RD | | | |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | x | x | x | x | x | x | x |
| 2ND | | | | | | | |
| 3RD | | | | | | | |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|-----|----|
| | |
| | |

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Sewer Line Maintenance
 PERMIT NUMBER: _____
 PLANT SUPERINTENDENT: _____
 SYSTEM MANAGER: David Denard

PLANT GRADE: IV
 TEL. # (205) 540-7585
 TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|----------------|----------------------------|--------------|------------|
| 1. | Brian Champion | I (c) | C002094 | 6/30/2015 |
| 2. | Don Goodwin | I (c) | C005423 | 6/30/2015 |
| 3. | Lavon Evans | I (c) | C004631 | 12/31/2014 |
| 4. | Brian Rohling | I (c) | C005418 | 6/30/2015 |
| 5. | | | | |
| 6. | | | | |
| 7. | | | | |
| 8. | | | | |
| 9. | | | | |
| 10. | | | | |

COLLECTION SYSTEM OPERATORS:

| | | | | |
|----|--|--|--|--|
| 1. | | | | |
| 2. | | | | |
| 3. | | | | |
| 4. | | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | | |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | | |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | | |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | | | |
|-----|----------------------|------------|----------------------|
| 1ST | <input type="text"/> | START TIME | <input type="text"/> |
| 2ND | <input type="text"/> | | <input type="text"/> |
| 3RD | <input type="text"/> | | <input type="text"/> |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | | | | | | | |
| 2ND | | | | | | | |
| 3RD | | | | | | | |

ADEM USE ONLY

- DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
- DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|--------------------------|--------------------------|
| <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> |

**Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013**

For the

Turkey Creek WWTP

as required by the
Alabama Department of Environmental Management NPDES Program



Prepared by
Jefferson County Commission
Environmental Services Department

May 31, 2014

JEFFERSON COUNTY COMMISSION



DAVID CARRINGTON - PRESIDENT
GEORGE F. BOWMAN
SANDRA LITTLE BROWN - PRESIDENT PRO TEMPORE
T. JOE KNIGHT
JAMES A. "JIMMIE" STEPHENS

DAVID CARRINGTON – COMMISSIONER
ENVIRONMENTAL SERVICES

TONY PETELOS, COUNTY MANAGER

Office of

DAVID DENARD
Director of Environmental Services
Suite A-300
716 Richard Arrington, Jr. Blvd. N.
Birmingham, Alabama 35203
Telephone (205) 325-5496
Fax (205) 325-5981

May 31, 2014

Mr. Nic Caraway
Alabama Department of Environmental Management
Water Division – Municipal Branch
P.O. Box 301463
Montgomery, AL 36130-1463

RE: Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013

Mr. Caraway:

The Jefferson County Environmental Services Department submits the above referenced report for the Turkey Creek Wastewater Treatment Facility, NPDES Permit No. AL0022926. Included is information as required in ADEM Form 41701/06ml, bypass/overflow event reports, MWPP Sewage Sludge Survey, and the Plant & Collection System Personnel Inventory.

If you have any questions regarding this information, please contact me at 205.325.5979 or Celeste Brown at Jefferson County Barton Laboratory at 205.238.3859.

Sincerely,

David Denard, Director
Environmental Services Department

pc: Celeste Brown, JCESD Barton Laboratory
Daniel White, JCESD Deputy Director
Chad Quick, Turkey Creek WWTP

**MUNICIPAL WATER POLLUTION PREVENTION (MWPP)
ANNUAL REPORT**

SUBMITTED BY:

TREATMENT FACILITY: Turkey Creek WWTP NPDES #: 0022926

MUNICIPALITY: Jefferson County COUNTY: Jefferson

CONTACT PERSON: David Denard

Municipal Official

Director of Environmental Services

Title

Telephone #: (205)325-5979 Fax #: (205)325-5806

Email Address: denardd@jccal.org

CHIEF OPERATOR: Chad Quick

Name

Telephone #: (205)681-7971 Fax #: (205)680-8139

Email Address: quicke@jccal.org

Date: May 14, 2014

REVIEWED BY: Daniel White P.E. ESD Engineer

Consulting Engineer

Telephone #: (205) 214-8610 Fax #: (205)325-5688

Date: May 14, 2014

**MWPP Annual Report
Information Source List**

The following information will be needed to complete the compliance maintenance report that covers the calendar year of 2013 (due **May 31,** 2014).

- Part 1 A. The average plant influent flow for each month (million gallons per day/MGD) during the year.
B. The average plant influent BOD (CBOD) for each month (mg/l and lb/day) in the year.
C. The plant's average design flow (MGD) and design BOD loading (lbs/day).
- Part 2 A. The monthly average permit and DMR effluent concentration for BOD (CBOD), TSS, NH₃-N, and/or TKN in mg/l for the year
B. The monthly average effluent limits and DMR loading for BOD, TSS, NH₃-N, and/or TKN in lbs/day for the year
- Part 3 The age of the treatment plant defined as the number of years since the last major reconstruction to increase the organic or hydraulic capacity of the plant. The last calendar year minus the year the new construction was brought on-line.
- Part 4 Bypass and overflow information. This is the number of bypass or overflow events of untreated wastewater due to heavy rain or equipment failure whether intentional or inadvertent from all collection systems tributary to the treatment facility.
- Part 5 A. Describe the characteristics and quantity of sludge generated.
B. If sludge is landspread, how many months of sludge storage does the plant have? This should include on-site and off-site storage from the treatment plant. The digester capacity may be used in the calculation.
- Part 6 A. Sludge Disposal Method
B. The number of approved land disposal sites for sludge available, and how many months or years these disposal sites will these be available for use.
- Part 7 The number of sewer extensions installed in the community last year--the design population, design flow, and design BOD for each sewer extension.
- Part 8 Operator Certification
- Part 9 Financial Status
- Part 10 Subjective Evaluation
- Part 11 Summary Sheet

State of Alabama
MWPP Annual Report
Department of Environmental Management

Instructions to the Operator-in-Charge

1. Complete all sections of the MWPP Report to the best of your ability.
2. Parts 1 through 8 contain questions for which points will be generated. These points are intended to communicate to the Department and the governing body or owner the actions necessary to prevent effluent violations. Enter the point totals from Parts 1 through 8 on Part 11: Summary Sheet.
3. Add the point totals on Part 11: Summary Sheet.
4. Submit the MWPP Report to the governing body and the consulting engineer and owner for review and approval.
5. The governing body should pass a resolution which contains the following points:
 - a. The resolution should acknowledge the governing body or owner has reviewed the MWPP Report.
 - b. The resolution should indicate what actions will be taken to prevent effluent violations.
 - c. The resolution should provide any other information the governing body or owner deems appropriate.
6. **The MWPP Report and the resolution must be submitted by May 31st to Municipal Section, Water Division, ADEM, P.O. Box 301463, Montgomery, AL 36130-1463.**

Facility Name: Turkey Creek WWTP

Part 1: Influent Loading/Flows

- A. List the average monthly volumetric flows and BOD₅ (CBOD₅) loadings received at your facility during the last calendar year.

| <u>Month</u> | <u>Column 1 Average Monthly Flowrate (MGD)</u> | <u>Column 2 Average Monthly BOD₅ (CBOD₅) Concentration (mg/l)</u> | <u>Column 3 Average Loading BOD₅ (CBOD₅) (lbs/day**)</u> |
|--------------------|--|---|--|
| January | 7.4 | 33 | 2111 |
| February | 7.4 | 33 | 1941 |
| March | 6.4 | 44 | 2184 |
| April | 6.9 | 44 | 2368 |
| May | 7.0 | 45 | 2238 |
| June | 6.6 | 51 | 2715 |
| July | 5.3 | 58 | 2756 |
| August | 6.3 | 39 | 1895 |
| September | 4.0 | 63 | 2105 |
| October | 3.4 | 78 | 2204 |
| November | 4.3 | 72 | 2404 |
| December | 6.1 | 42 | 2084 |
| Annual Avg. | 5.9 | 50 | 2250 |

**As reported on NPDES Discharge Monitoring Reports (DMRs) and as required by EPA's NPDES Self-Monitoring System, User Guide, March 1985.

- B. List the average design flow and average design BOD₅ loading for the facility below. If you are not aware of these design quantities, contact your consulting engineer or the Alabama Department of Environmental Management.

| | <u>Average Design Flow</u> | <u>Average Design BOD₅ Loading (lbs/day)</u> |
|----------------------------|----------------------------|---|
| Design Criteria | 5.0 | 7506 |
| 90% of the Design Criteria | 4.5 | 6755 |

- C. How many times did the monthly flow (Column 1) to the WWTP exceed 90% of design flow?
 _____ (Check the appropriate point total)
 0 - 4 = 0 points 5 or more = 5 points
- D. How many times did the monthly flow (Column 1) to the WWTP exceed the design flow?
 _____ (Check the appropriate point total)
 0 = 0 points 1 - 2 = 5 points 3 - 4 = 10 points 5 or more = 15 points
- E. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed 90% of the design loading? _____ (Check the appropriate point total)
 0 - 1 = 0 points 2 - 4 = 5 points 5 or more = 10 points
- F. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed the design loading? _____ (Check the appropriate point total)
 0 = 0 points 1 = 10 points 2 = 20 points 3 = 30 points 4 = 40 points 5 or more = 50 points
- G. Enter each point value marked for C through F and enter the sum in the appropriate blank below.

C points = 5

D points = 15

E points = 0

F points = 0

TOTAL POINTS VALUE OR PART 1 20
 Enter this value on Part 11: Summary Sheet.

*To obtain equivalent BOD₅ loading for comparison with design loading for those permittees using influent CBOD₅, divide annual average CBOD₅, loading in lbs/day from Part 1, A by 0.7.

Facility Name: Turkey Creek WWTP

Part 2: Effluent Quality/Plant Performance

A. List the monthly average permit limits for the facility in the blanks below and the average monthly effluent DMR BOD₅, (CBOD₅) TSS, NH₃-N and/or TKN concentration produced by the facility during the last calendar year.

(1) NPDES Permit Concentration

| Permit Limit | Months | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------|------------|--|---------------|------------------------------|---------------|
| | | April- Oct | 20.0 | 24.0 | 2.5 |
| | Nov- March | 20.0 | 24.0 | 5.0 | Report |

(2) DMR Concentration

| Qtr | Month | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------------|-----------|--|---------------|------------------------------|---------------|
| 1 | January | 1.2 | 5.8 | 0.01 | 0.52 |
| | February | 1.5 | 6.9 | 0.0 | 0.42 |
| | March | 1.4 | 7.0 | 0.01 | 0.43 |
| 2 | April | 0.89 | 4.5 | 0.0 | 0.17 |
| | May | 1.1 | 6.0 | 0.0 | 0.65 |
| | June | 0.83 | 5.7 | 0.01 | 0.43 |
| 3 | July | 1.3 | 4.6 | 0.0 | 0.22 |
| | August | 0.77 | 3.3 | 0.0 | 0.0 |
| | September | 1.4 | 4.1 | 0.0 | 0.47 |
| 4 | October | 2.0 | 4.6 | 0.0 | 0.35 |
| | November | 1.4 | 7.3 | 0.01 | 0.30 |
| | December | 0.93 | 5.4 | 0.02 | 0.26 |
| Annual Avg. | | 1.2 | 5.4 | 0.01 | 0.35 |

B. List the monthly average permit limit and DMR loadings below.

(1) NPDES Permit Loading

| Permit Limit | Months | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|-----------------|-----------|---|------------------|---------------------------------|------------------|
| | April-Oct | 834 | 1000 | 104 | Report |
| Nov-March | 834 | 1000 | 208 | Report | |

(2) DMR Loading

| Qtr | Month | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|--------------------|-----------|---|------------------|---------------------------------|------------------|
| 1 | January | 79 | 468 | 0.68 | 60 |
| | February | 93 | 449 | 0.0 | 22 |
| | March | 70 | 387 | 0.64 | 23 |
| 2 | April | 48 | 245 | 0.0 | 9.9 |
| | May | 54 | 314 | 0.0 | 30 |
| | June | 46 | 325 | 0.66 | 31 |
| 3 | July | 59 | 217 | 0.0 | 7.6 |
| | August | 43 | 176 | 0.0 | 0.0 |
| | September | 49 | 139 | 0.0 | 14 |
| 4 | October | 57 | 129 | 0.0 | 10 |
| | November | 49 | 262 | 0.45 | 9.3 |
| | December | 50 | 293 | 0.98 | 11 |
| Annual Avg. | | 58 | 284 | 0.28 | 19 |

C. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

D. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

E. During the past year did the effluent TSS concentration (mg/l) or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

F. During the past year did the TSS concentration (mg/l) and/or loading (lbs/day) exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

G. During the past year did the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

H. During the past year did either the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

I. Enter each point value checked for C through H in the blanks below.

C Points = 0

D Points = 0

E Points = 0

F Points = 0

G Points = 0

H Points = 0

HIGHEST INDIVIDUAL POINT VALUE FOR PART 2 (C-H) 0 (HIGHEST POINT = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Turkey Creek WWTP

Part 3: Age of the Wastewater Treatment Facility

A. What year was the wastewater treatment plant constructed or last reconstructed? 2004

Subtract the above answer from the report year to determine age:

$$\text{Age} = (\text{Last Calendar year}) - (\text{Answer to A})$$

$$\text{Age } ^9 = (\text{2013}) - (\text{2004})$$

Enter Age in Part C below.

B. Check the type of treatment facility employed.

| | Factor |
|---------------------------------------|--------|
| <u>2.0</u> Mechanical Treatment Plant | 2.0 |
| _____ Aerated Lagoon | 1.5 |
| _____ Stabilization Pond | 1.0 |
| _____ Other (Specify: _____) | 1.0 |

C. Multiply the factor listed next to the type of the facility your community employs by the age of your facility to determine the total point value for Part 3:

$$\frac{2.0}{\text{(Factor)}} \times \frac{9}{\text{(Age)}} = 18 \text{ TOTAL POINT VALUE FOR PART 3}$$

Enter the above value on Part 11: Summary Sheet. If the total point value exceeds 40, enter 40 on Part 11: Summary Sheet.

Facility Name: Turkey Creek WWTP

Part 4: Bypassing and Overflows

A. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to heavy rain? 0

B. How many bypass or overflow events of untreated wastewater occurred in the last year prior to the headworks of the WWTP due to heavy rain? 0

C. How many of the bypass or overflow events listed in Parts A and B have been corrected such that future bypass or overflow events at the same location due to heavy rain are not anticipated? 0

D. Add together Answers A and B and subtract Answer C from that total.

A + B - C = _____ (Check the appropriate point total.)

0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
 7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points

E. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to equipment failure? (This includes clogged/broken lines or manholes.) 1.0

F. How many bypass or overflow events of untreated wastewater occurred in the last year due to equipment failure prior to the headworks of the WWTP? (This includes clogged/broken lines or manholes.) 1.0

G. How many of the bypass or overflow events listed in Parts E and F have been corrected such that future bypass or overflow events at the same location due to the same equipment failure are not anticipated? 2.0

H. Add together Answers E and F and subtract Answer G from that total.

E + F - G = _____ (Check the appropriate point total.)

0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
 7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points

I. Add point values circled in D and H and enter the total in the blank below.

TOTAL POINT VALUE FOR PART 4 0

Enter this value on Part 11: Summary Sheet.

All bypass or overflow events that have occurred in the last year (for any reason) must be individually reported with this MWPP report.

Facility Name: Turkey Creek WWTP

Part 5: Sludge Quantity and Storage

- A. Please provide information concerning sludge quantity, characteristics, and storage practices based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months of sludge storage capacity does the wastewater treatment facility have available, either on-site or off-site? (i.e., How many months can the facility operate without land spreading or disposing of sludge?) 4

(Check the appropriate point total.)

- | | | |
|---|-------------|-------------------------------------|
| Greater than or equal to 4 months | = 0 points | <input checked="" type="checkbox"/> |
| Less than 4 months, but greater than or equal to 3 months | = 10 points | <input type="checkbox"/> |
| Less than 3 months, but greater than or equal to 2 months | = 20 points | <input type="checkbox"/> |
| Less than 2 months, but greater than or equal to 1 month | = 30 points | <input type="checkbox"/> |
| Less than one month | = 50 points | <input type="checkbox"/> |

TOTAL POINT VALUE FOR PART 5 0

Enter this value on Part 11: Summary Sheet.

Part 6: Sludge Disposal Practices and Sites

- A. Please provide the sludge disposal practices and site information based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months or years does the facility have access to and approval for sufficient land disposal sites to provide proper land disposal? (Check the appropriate point total.)

- | | | |
|--------------------|-------------|-------------------------------------|
| 36 or more months | = 0 points | <input type="checkbox"/> |
| 24 - 35 months | = 10 points | <input type="checkbox"/> |
| 12 - 23 months | = 20 points | <input checked="" type="checkbox"/> |
| 6 - 11 months | = 30 points | <input type="checkbox"/> |
| Less than 6 months | = 50 points | <input type="checkbox"/> |

TOTAL POINT VALUE FOR PART 6 20

Enter this value on Part 11: Summary Sheet.

Facility Name: Turkey Creek WWTP

Part 7: New Development

Are there any major new developments (industrial, commercial, or residential) in the last calendar year or anticipated in the next 2-3 years such that either flow or BOD₅ loadings to the sewage system could significantly increase? Estimate additional loadings below.

Design Population: _____
Equivalent (PE)

Design Flow: _____ MGD

Design BOD₅: _____ lbs/day

List industrial and/or residential developments.

No major developments are planned.

Will the additional loading overload the plant? (Check the appropriate point total.)

No = 0 points Yes = 121 points

Enter the point total in the blank below.

TOTAL POINT VALUE FOR PART 7 ⁰ _____ (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Part 8: Operator Certification

Complete the *Plant and Collection System Personnel Inventory*, ADEM Form 441.

Do both the plant operator and collection system staffing comply with ADEM Administrative Code; Division 10, Operator Certification Program? (Check the appropriate point total.)

Yes = 0 points No = 121 points

TOTAL POINT VALUE FOR PART 8 ⁰ _____ (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Turkey Creek WWTP

Part 9: Financial Status

- A. Are User-Charge Revenues sufficient to cover operation and maintenance expenses? If no, how are O&M costs being financed? ***Include user charge rates.***

Revenues are sufficient. The below values are based on a 5/8" meter and 6000 gallons of water use.

Jefferson County has a three tier block rate structure for residential users for 0-3, 4-6, and 7+ccf water use.

Residential Minimum 15.00 Plus rate 6.02, 9.36, 10.69 /1,000 gal.

Industrial Minimum 15.00 Plus rate 10.51 /1,000 gal.

Monthly residential rate based on 6,000 gallons usage \$ 56.04(includes 15% credit for residential)

****Please complete the above information based on your user charge rates for the report year. You may attach a sample water and sewer bill for clarity.***

- B. What financial resources are available to pay for the wastewater improvements and/or reconstruction needs?

In 2013, Jefferson County issued Series 2013 Sewer Warrants that fund capital improvements

through 2023 at an annual average rate of \$71.9 million over the 10-year period.

Part 10: Subjective Evaluation

- A. Describe briefly the physical and structural conditions of the wastewater treatment facility.

All structures are in good condition.

- B. Describe the general condition of the sewer system (sewer lines, manholes, lift stations).

The Turkey system includes roughly 460,000' of pipe and 8 pumping stations. The system's rate of

SSO's/100 miles of sewer is below the department's goal. There are no known capacity deficiencies,

but I/I rates were high. The general condition of the system is fair.

C. What sewage system improvements does the community have planned for construction in the next 5 years?

Improvements to the Womack Road sanitary sewer area that experienced a break in the April 2014

flooding.

D. What is the theoretical design life of the plant, and what is the estimated remaining useful life of the wastewater treatment facility?

Calculated remaining useful life of the structures is 41 years (50 years - 9 years age of facility).

Calculated remaining useful life of the equipment is 16 years (25 years - 9 years age of equipment).

Based on EPA's 2002 Clean Water and Drinking Water Infrastructure Gap Analysis Report.

E. What problems, if any, over the last year have threatened treatment or conveyance within the system?

On May 18, 2013, Turkey Creek flooded after receiving 6+" of rain in a 12-hour period.

Debris overwhelmed and blocked the influent screens. Between 1.6 and 2.2 million gallons of

sewage flowed to Turkey Creek before the screens could be cleared and restarted.

F. Is the community presently involved in formal planning for treatment facility upgrading?

No

G. How many days in the last year were there residential backups at any point in the collection system for any reason other than clogging of the lateral connection? 4

H. Does the plant have a written plan for preventive maintenance on major equipment items? If yes, describe.

Yes, O&M manuals for all equipment are on site. We record lubrication and repairs on all equipment in an asset

management program (Infor) for future reference and to keep a log on all repairs. Preventive maintenance

schedules are loaded in the program, and work orders are automatically generated.

I. Does this preventive maintenance program depict frequency of intervals, types of lubrication, and other preventive maintenance tasks necessary for each piece of equipment? (Check the appropriate response.) Yes No

J. Are these preventive maintenance tasks, as well as equipment problems, being recorded and filed so future maintenance problems can be assessed properly? (Check the appropriate response.) Yes No

K. Describe any major repairs or mechanical equipment replacement made in the last year and include the approximate cost for those repairs. Do not include major treatment plant construction or upgrading programs.

L. List any additional comments. (Attach additional sheets if necessary.)

Facility Name: Turkey Creek WWTP

Part 11: Summary Sheet

1. Enter in the values from Parts 1 through 8 in the left column below. Add the numbers in the left column to determine the MWPP Report point total the wastewater system generated for the previous calendar year.

| <u>Actual Values</u> | <u>Maximum Possible</u> |
|---------------------------|-------------------------|
| Part 1 <u>20</u> points | 80 points |
| Part 2 <u>0</u> points | 121 points |
| Part 3 <u>18</u> points | 40 points |
| Part 4 <u> </u> points | 200 points |
| Part 5 <u>0</u> points | 50 points |
| Part 6 <u>20</u> points | 50 points |
| Part 7 <u>0</u> points | 121 points |
| Part 8 <u>0</u> points | 121 points |
| Total <u>58</u> points | 783 points |

2. Check the facility type that best describes the plant's treatment and disposal of wastewater.

- Mechanical plant with surface water discharge
 Aerated Lagoon or stabilization pond with surface water discharge
 Mechanical plant using land disposal of liquid wastes
 Aerated Lagoon or stabilization pond using land disposal of liquid wastes

3. Check the range that describes the action needed to address problems identified in the report.

- 0 - 70 pts. Actions as Appropriate*
 71 - 120 pts. Departmental Recommendation Range*
 121 - 783 Municipality Action Range*

***Other actions may be required by NPDES outside the scope of this report.**


4. Complete the *Municipal Water Pollution Prevention Resolution Form*, ADEM Form 418.

Turkey Creek Wastewater Treatment Plant
ATTACHMENT 2 – Raw Sewage Bypass and

SUMMARY



TURKEY CREEK BASIN 2013 DISCHARGES



NOTE: OVERFLOWS SHOWN ARE OVER 10,000 GALLONS.

JEFFERSON COUNTY
ENVIRONMENTAL SERVICES
PLOTTED: 2-11-14



Summary of Unpermitted Discharges - Turkey Creek

January 01, 2013 through December 31, 2013

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-----------|---------------|------------------------|-------------------|--|-----------------|-----------------|-----------------------------------|------------|------------------|------------------|------------------------------|
| T00045 | 5/18/13 | 7137 Disposal Plant Rd | Turkey Creek | Turkey Creek | 2,000,000 | Treatment Plant | Treatment Plant Equipment Failure | Heavy Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| T00047 | 8/19/13 | 6517 Womack Rd | Turkey Creek | Drainage Ditch/ Feeder to Turkey Creek | 18,994 | Pipe | Manhole Washed Out | No Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |

Notes: Influent screens blinded by debris from influent flow.

Notes:

Turkey Creek Wastewater Treatment Plant

ATTACHMENT 3 – MWPP Sewage Sludge

SURVEY



MWPP SEWAGE SLUDGE SURVEY

Facility Background Information:

1. Facility Information

Permit Number: AL0022926

Name: Turkey Creek WWTP

Street Address: 7137 Disposal Plant Road

County: Jefferson

2. Facility Contact

Name: Chad Quick

Title: Plant Supervisor

Telephone: (205) 681-7971

Permitted Name: Jefferson County Commission- Turkey Creek WWTP

Mailing Address: Suite A-300, 716 Richard Arrington JR. Blvd. N.

Birmingham AL 35203

Facility Flow Information

1. Facility Wastewater Treatment Capacity

Avg. Daily Flow for 2013: 5.9 MGD

Facility Design Capacity: 5.0 MGD

2. Estimated Septage Quantity Handled (Residuals Removed from Septic Tank Systems)

Average Domestic Septage: N/A gallons per month

Average Commercial Septage: N/A gallons per month

3. Method of Septage Processing

Mixed with Influent Wastewater for Treatment

Mixed with Sewage Sludge

N/A

4. Estimated Percentage Contributing Wastewater Flow

Residential: 95 %

Industrial: 0 %

Other: 5 %

Describe: Commercial

5. List type of wastewater treatment process(es) utilized at this facility:

Bar Screening, Grit Removal, Extended Aeration with Activated Sludge,
Clarification, Traveling Bridge Sand Filtration, UV Disinfection, Step Aeration

6. Estimated sewage sludge wasting rate at this facility:

7297 lb/day dry weight
or 7297 gallons per day

7. Estimated untreated sludge received from off site:

N/A lb/day dry weight
or gallons per day

8. Estimated percent solids of combined sewage sludge prior to treatment: 2.2 %

9. List the sewage sludge treatment processes used in preparing sludge for final use or disposal:

| | Sludge Quantity (untreated pounds per day) |
|--|---|
| Aerobic Digestion, Drying Beds (Air Drying) | |
| | |
| | |
| | |

10. Estimate the total volume of sludge generated: 251
(dry U.S. tons per year)

Sludge Disposal Methods

1. Which of the following describes the current method of sewage sludge disposal for this facility:

| | Current Practices | | Quantity (dry U.S. tons/year) | Proposed Practices Approved by ADEM | |
|--|--------------------------|--------------------------|----------------------------------|--|--------------------------|
| | Approved by ADEM Yes | No | | Yes | No |
| a. <input checked="" type="checkbox"/> Land Application, Bulk Shipped | | | 251 | | |
| <input checked="" type="checkbox"/> Agriculture | X | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Forest | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Public Contact | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Lawn/Home Garden | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| b. <input type="checkbox"/> Land Application, Bagged/Other Container | | | | | |
| <input type="checkbox"/> Agriculture | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Forest | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Public Contact | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Lawn/Home Garden | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| c. <input type="checkbox"/> Incineration | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| d. <input type="checkbox"/> Subtitle D Landfill (Disposal Only) | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| e. <input type="checkbox"/> Lined Treatment Lagoon or Stabilization Pond | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| f. <input type="checkbox"/> Unlined Lagoon or Stabilization Pond | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| g. <input type="checkbox"/> Other (Please Describe) | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | | | |
| | | | | | |
| | | | | | |

2. If "f" was selected above and sludge is stored for 2 or more years, enter the distance between the surface disposal site and the property line: N/A feet

Pollutant Concentrations

1. Enter the total concentrations of the following analytes using existing data. Do not enter TCLP results.

| Analyte | Concentration (mg/kg or ppm) | Sample Type | Sample Date | Detection Level of Analysis |
|-------------------------|------------------------------|-------------|-------------|-----------------------------|
| Arsenic | <PQL | Grab | * | 11.0 |
| Cadmium | <PQL | Grab | * | 5.0 |
| Chromium | 47 | Grab | * | 6.0 |
| Copper | 957 | Grab | * | 5.0 |
| Lead | 16 | Grab | * | 12.0 |
| Mercury | 2 | Grab | * | 0.0 |
| Molybdenum | <PQL | Grab | * | 6.0 |
| Nickel | 25 | Grab | * | 6.0 |
| Selenium | <PQL | Grab | * | 12.0 |
| Zinc | 937 | Grab | * | 8.0 |
| Ammonium-Nitrogen | | N/A | N/A | N/A |
| Nitrate-Nitrogen | | N/A | N/A | N/A |
| Total Kjeldahl Nitrogen | 40,667 | Grab | * | 0.09 |

PQL=Practical Quantitative Limit

*= Yearly Average

2. Enter the estimated or determined percent solids of the sewage sludge when sampled for the above analysis: 82 %

Treatment Provided for Sewage Sludge at the Facility

1. Which class of pathogen reduction does the sewage sludge meet at the facility? (As defined in 40 CFR Part 503)

Class A

Alternative A1 - Time and Temperature

Alternative A2 - Alkaline Treatment

Alternative A3 - Analysis and Operation

Alternative A4 - Analysis Only

Alternative A5 - Processes to Further Reduce Pathogens (PFRP)

Heat Drying

Thermophilic Aerobic Digestion

Heat Treatment

Pasteurization

Gamma Ray Irradiation

Beta Ray Irradiation

Composting

Alternative A6 - PFRP Equivalent _____

Class B

Alternative B1 - Fecal Coliform Count

Alternative B2 - Process to Significantly Reduce Pathogens (PSRP)

Aerobic Digestion

Air Drying

Anaerobic Digestion

Composting

Lime Stabilization

Alternative B3 - PSRP Equivalent _____

Neither or Unknown

Vector Attraction Control

- Option 1 - Minimum 38% Reduction in Volatile Solids
- Option 2 - Anaerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 3 - Aerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 4 - Specific Oxygen Uptake Rate (SOUR) for Aerobically Digested Sludge
- Option 5 - Aerobic Processes plus Elevated Temperature
- Option 6 - Raised pH to 12 and Retained at 11.5
- Option 7 - 75% Solids with no Unstabilized Solids
- Option 8 - 90% Solids with Unstabilized Solids
- Option 9 - Injection Below Land Surface
- Option 10 - Incorporation into Soil within 6 or 8 Hours
- Option 11 - Covering Active Sewage Sludge Unit Daily
- None of the Above

Groundwater Monitoring

1. If disposal practice is surface disposal or land application, is groundwater monitoring required or performed at the site?

- Yes (If yes, please submit a copy of the groundwater monitoring reports along with this survey. Also please provide the approximate depth to groundwater and the groundwater monitoring procedures used to obtain the data.)
- No

Land Application of Sewage Sludge

Answer the following questions if sewage sludge is applied to land.

1. If sewage sludge is land applied in bulk form, what type of crop or other vegetation is grown on this site?

Tifton Bermuda Grass, Ryegrass

2. If sewage sludge is land applied in bulk form, what is the nitrogen requirement for this crop or vegetation?

600lb/acre/year (Reclamation Site)

3. If sewage sludge is land applied in bulk form, briefly describe the nature of any complaints filed from neighbors?

No complaints have been received.

Note: Permittees that submitted the "Annual Report Review Form" for sludge to the EPA may submit a copy with the MWPP in lieu of this Attachment.

Turkey Creek Wastewater Treatment Plant
ATTACHMENT 4 – Plant and Collection System
Personnel Inventory



PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Turkey Creek WWTP

PLANT GRADE: III

PERMIT NUMBER: AL 0022926

PLANT SUPERINTENDENT: Chad Quick

TEL. # (205)681-7971

SYSTEM MANAGER: David Denard

TEL. # (205)326-8232

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|--------------------|----------------------------|----------------|------------------|
| 1. | Eric Pond | IV | C003706 | 2/28/2016 |
| 2. | Mark Lee | IV | C000389 | 8/31/2016 |
| 3. | Chad Quick | IV | C003616 | 2/28/2015 |
| 4. | Pat McCarty | IV | C003224 | 8/31/2014 |
| 5. | Adam Moore | IV | C006513 | 11/1/2014 |
| 6. | | | | |
| 7. | | | | |
| 8. | | | | |
| 9. | | | | |
| 10. | | | | |

COLLECTION SYSTEM OPERATORS:

| | | | |
|----|--|--|--|
| 1. | | | |
| 2. | | | |
| 3. | | | |
| 4. | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|----------|
| MANAGEMENT/SUPERVISOR | 120 | 3 |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | 80 | 2 |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | | |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | |
|-----|----------|
| 1ST | 1 |
| 2ND | |
| 3RD | |

| | |
|------------|----------------|
| START TIME | 7:00 AM |
| | |
| | |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|----------|----------|----------|----------|----------|----------|----------|
| 1ST | X | X | X | X | X | X | X |
| 2ND | | | | | | | |
| 3RD | | | | | | | |

ADEM USE ONLY

- DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
- DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|----------|----|
| X | |
| | |

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Sewer Line Maintenance
 PERMIT NUMBER: _____
 PLANT SUPERINTENDENT: _____
 SYSTEM MANAGER: David Denard

PLANT GRADE: IV

TEL. # (205) 540-7585
 TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|----------------|----------------------------|--------------|------------|
| 1. | Brian Champion | I (c) | C002094 | 6/30/2015 |
| 2. | Don Goodwin | I (c) | C005423 | 6/30/2015 |
| 3. | Lavon Evans | I (c) | C004631 | 12/31/2014 |
| 4. | Brian Rohling | I (c) | C005418 | 6/30/2015 |
| 5. | | | | |
| 6. | | | | |
| 7. | | | | |
| 8. | | | | |
| 9. | | | | |
| 10. | | | | |

COLLECTION SYSTEM OPERATORS:

| | | | |
|----|--|--|--|
| 1. | | | |
| 2. | | | |
| 3. | | | |
| 4. | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | | |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | | |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | | |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | | | |
|-----|----------------------|------------|----------------------|
| 1ST | <input type="text"/> | START TIME | <input type="text"/> |
| 2ND | <input type="text"/> | | <input type="text"/> |
| 3RD | <input type="text"/> | | <input type="text"/> |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | | | | | | | |
| 2ND | | | | | | | |
| 3RD | | | | | | | |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|--------------------------|--------------------------|
| <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> |

**Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013**

For the

Valley Creek WWTP

as required by the
Alabama Department of Environmental Management NPDES Program



Prepared by
Jefferson County Commission
Environmental Services Department

May 31, 2014

JEFFERSON COUNTY COMMISSION



DAVID CARRINGTON - PRESIDENT
GEORGE F. BOWMAN
SANDRA LITTLE BROWN - PRESIDENT PRO TEMPORE
T. JOE KNIGHT
JAMES A. "JIMMIE" STEPHENS

DAVID CARRINGTON – COMMISSIONER
ENVIRONMENTAL SERVICES

TONY PETELOS, COUNTY MANAGER

Office of

DAVID DENARD
Director of Environmental Services
Suite A-300
716 Richard Arrington, Jr. Blvd. N.
Birmingham, Alabama 35203
Telephone (205) 325-5496
Fax (205) 325-5981

May 31, 2014

Mr. Nic Caraway
Alabama Department of Environmental Management
Water Division – Municipal Branch
P.O. Box 301463
Montgomery, AL 36130-1463

RE: Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013

Mr. Caraway:

The Jefferson County Environmental Services Department submits the above referenced report for the Valley Creek Wastewater Treatment Facility, NPDES Permit No. AL0023655. Included is information as required in ADEM Form 41701/06ml, bypass/overflow event reports, MWPP Sewage Sludge Survey, and the Plant & Collection System Personnel Inventory.

If you have any questions regarding this information, please contact me at 205.325.5979 or Celeste Brown at Jefferson County Barton Laboratory at 205.238.3859.

Sincerely,

David Denard, Director
Environmental Services Department

pc: Celeste Brown, JCESD Barton Laboratory
Daniel White, JCESD Deputy Director
Robby Bennett, Valley Creek WWTP

**MUNICIPAL WATER POLLUTION PREVENTION (MWPP)
ANNUAL REPORT**

SUBMITTED BY:

TREATMENT FACILITY: Valley Creek WWTP NPDES #: AL0023655

MUNICIPALITY: Jefferson County COUNTY: Jefferson

CONTACT PERSON: David Denard

Municipal Official

Director of Environmental Services

Title

Telephone #: (205) 327-8232 Fax #: (205) 325-5981

Email Address: denaradd@jccal.org

CHIEF OPERATOR: Robby Bennett

Name

Telephone #: (205) 428-2614 Fax #: (205) 426-3274

Email Address: bennettr@jccal.org

Date: May 14, 2014

REVIEWED BY: Daniel White P.E., ESD Engineer

Consulting Engineer

Telephone #: 205 214 8610 Fax #: 205 325-5688

Date: May 14, 2014

**MWPP Annual Report
Information Source List**

The following information will be needed to complete the compliance maintenance report that covers the calendar year of 2013 (due **May 31, 2014**).

- Part 1 A. The average plant influent flow for each month (million gallons per day/MGD) during the year.
B. The average plant influent BOD (CBOD) for each month (mg/l and lb/day) in the year.
C. The plant's average design flow (MGD) and design BOD loading (lbs/day).
- Part 2 A. The monthly average permit and DMR effluent concentration for BOD (CBOD), TSS, NH3-N, and/or TKN in mg/l for the year
B. The monthly average effluent limits and DMR loading for BOD, TSS, NH3-N, and/or TKN in lbs/day for the year
- Part 3 The age of the treatment plant defined as the number of years since the last major reconstruction to increase the organic or hydraulic capacity of the plant. The last calendar year minus the year the new construction was brought on-line.
- Part 4 Bypass and overflow information. This is the number of bypass or overflow events of untreated wastewater due to heavy rain or equipment failure whether intentional or inadvertent from all collection systems tributary to the treatment facility.
- Part 5 A. Describe the characteristics and quantity of sludge generated.
B. If sludge is landspread, how many months of sludge storage does the plant have? This should include on-site and off-site storage from the treatment plant. The digester capacity may be used in the calculation.
- Part 6 A. Sludge Disposal Method
B. The number of approved land disposal sites for sludge available, and how many months or years these disposal sites will these be available for use.
- Part 7 The number of sewer extensions installed in the community last year--the design population, design flow, and design BOD for each sewer extension.
- Part 8 Operator Certification
- Part 9 Financial Status
- Part 10 Subjective Evaluation
- Part 11 Summary Sheet

Instructions to the Operator-in-Charge

1. Complete all sections of the MWPP Report to the best of your ability.
2. Parts 1 through 8 contain questions for which points will be generated. These points are intended to communicate to the Department and the governing body or owner the actions necessary to prevent effluent violations. Enter the point totals from Parts 1 through 8 on Part 11: Summary Sheet.
3. Add the point totals on Part 11: Summary Sheet.
4. Submit the MWPP Report to the governing body and the consulting engineer and owner for review and approval.
5. The governing body should pass a resolution which contains the following points:
 - a. The resolution should acknowledge the governing body or owner has reviewed the MWPP Report.
 - b. The resolution should indicate what actions will be taken to prevent effluent violations.
 - c. The resolution should provide any other information the governing body or owner deems appropriate.
6. **The MWPP Report and the resolution must be submitted by May 31st to Municipal Section, Water Division, ADEM, P.O. Box 301463, Montgomery, AL 36130-1463.**

Facility Name: Valley Creek WWTP

Part 1: Influent Loading/Flows

- A. List the average monthly volumetric flows and BOD₅ (CBOD₅) loadings received at your facility during the last calendar year.

| <u>Month</u> | <u>Column 1 Average Monthly Flowrate (MGD)</u> | <u>Column 2 Average Monthly BOD₅ (CBOD₅) Concentration (mg/l)</u> | <u>Column 3 Average Loading BOD₅ (CBOD₅) (lbs/day**)</u> |
|--------------------|--|---|--|
| January | 87 | 53 | 34602 |
| February | 89 | 54 | 37054 |
| March | 62 | 87 | 43682 |
| April | 60 | 123 | 57792 |
| May | 52 | 122 | 44532 |
| June | 35 | 135 | 38659 |
| July | 49 | 118 | 46310 |
| August | 47 | 108 | 42357 |
| September | 22 | 159 | 29330 |
| October | 22 | 163 | 30150 |
| November | 27 | 160 | 36679 |
| December | 63 | 107 | 54757 |
| Annual Avg. | 51 | 116 | 41325 |

**As reported on NPDES Discharge Monitoring Reports (DMRs) and as required by EPA's NPDES Self-Monitoring System, User Guide, March 1985.

- B. List the average design flow and average design BOD₅ loading for the facility below. If you are not aware of these design quantities, contact your consulting engineer or the Alabama Department of Environmental Management.

| | <u>Average Design Flow</u> | <u>Average Design BOD₅ Loading (lbs/day)</u> |
|----------------------------|----------------------------|---|
| Design Criteria | 85.0 | 141,780 |
| 90% of the Design Criteria | 76.5 | 127,602 |

- C. How many times did the monthly flow (Column 1) to the WWTP exceed 90% of design flow?
 _____ (Check the appropriate point total)
 0 - 4 = 0 points 5 or more = 5 points
- D. How many times did the monthly flow (Column 1) to the WWTP exceed the design flow?
 _____ (Check the appropriate point total)
 0 = 0 points 1 - 2 = 5 points 3 - 4 = 10 points 5 or more = 15 points
- E. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed 90% of the design loading? _____ (Check the appropriate point total)
 0 - 1 = 0 points 2 - 4 = 5 points 5 or more = 10 points
- F. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed the design loading? _____ (Check the appropriate point total)
 0 = 0 points 1 = 10 points 2 = 20 points 3 = 30 points 4 = 40 points 5 or more = 50 points
- G. Enter each point value marked for C through F and enter the sum in the appropriate blank below.

C points = 0

D points = 5

E points = 0

F points = 0

TOTAL POINTS VALUE OR PART 1 5 _____
 Enter this value on Part 11: Summary Sheet.

*To obtain equivalent BOD₅ loading for comparison with design loading for those permittees using influent CBOD₅, divide annual average CBOD₅, loading in lbs/day from Part 1, A by 0.7.

Facility Name: Valley Creek WWTP

Part 2: Effluent Quality/Plant Performance

A. List the monthly average permit limits for the facility in the blanks below and the average monthly effluent DMR BOD₅, (CBOD₅) TSS, NH₃-N and/or TKN concentration produced by the facility during the last calendar year.

(1) NPDES Permit Concentration

| Permit Limit | Months | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------|-----------|--|---------------|------------------------------|---------------|
| | May - Nov | 8.0 | 24.0 | 1.0 | 3.0 |
| | Dec - Apr | 8.0 | 24.0 | 1.0 | 4.0 |

(2) DMR Concentration

| Qtr | Month | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|-----|--------------------|--|---------------|------------------------------|---------------|
| 1 | January | 2.0 | 5.3 | 0.01 | 0.86 |
| | February | 1.7 | 5.8 | 0.02 | 0.76 |
| | March | 1.8 | 4.7 | 0.02 | 0.67 |
| 2 | April | 1.1 | 4.1 | 0.01 | 0.50 |
| | May | 1.2 | 4.5 | 0.01 | 0.64 |
| | June | 0.88 | 1.8 | 0.01 | 0.61 |
| 3 | July | 1.2 | 4.7 | 0.03 | 0.59 |
| | August | 0.94 | 2.9 | 0.01 | 0.57 |
| | September | 1.1 | 3.5 | 0.04 | 0.80 |
| 4 | October | 1.2 | 3.7 | 0.02 | 0.89 |
| | November | 2.0 | 7.3 | 0.06 | 1.1 |
| | December | 2.2 | 7.8 | 0.03 | 0.97 |
| | Annual Avg. | 1.4 | 4.7 | 0.02 | 0.75 |

B. List the monthly average permit limit and DMR loadings below.

(1) NPDES Permit Loading

| Permit Limit | Months | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|-----------------|-----------|---|------------------|---------------------------------|------------------|
| | May - Nov | 5671 | 17013 | 708 | 2126 |
| Dec - Apr | 5671 | 17013 | 708 | 2835 | |

(2) DMR Loading

| Qtr | Month | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|--------------------|-----------|---|------------------|---------------------------------|------------------|
| 1 | January | 1557 | 4468 | 4.9 | 648 |
| | February | 1320 | 4598 | 23 | 563 |
| | March | 906 | 2679 | 12 | 360 |
| 2 | April | 510 | 1956 | 2.7 | 240 |
| | May | 499 | 2023 | 5.0 | 262 |
| | June | 251 | 582 | 2.5 | 184 |
| 3 | July | 535 | 2097 | 11 | 243 |
| | August | 394 | 1243 | 4.8 | 232 |
| | September | 199 | 673 | 8.1 | 149 |
| 4 | October | 222 | 708 | 3.2 | 165 |
| | November | 757 | 2796 | 22 | 328 |
| | December | 1227 | 4217 | 18 | 506 |
| Annual Avg. | | 698 | 2337 | 9.7 | 323 |

C. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

D. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

E. During the past year did the effluent TSS concentration (mg/l) or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

F. During the past year did the TSS concentration (mg/l) and/or loading (lbs/day) exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

G. During the past year did the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

H. During the past year did either the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

I. Enter each point value checked for C through H in the blanks below.

C Points = 0

D Points = 0

E Points = 0

F Points = 0

G Points = 0

H Points = 0

HIGHEST INDIVIDUAL POINT VALUE FOR PART 2 (C-H) 0 (HIGHEST POINT = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Valley Creek WWTP

Part 4: Bypassing and Overflows

- A. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to heavy rain? 0
- B. How many bypass or overflow events of untreated wastewater occurred in the last year prior to the headworks of the WWTP due to heavy rain? 57
- C. How many of the bypass or overflow events listed in Parts A and B have been corrected such that future bypass or overflow events at the same location due to heavy rain are not anticipated? 8
- D. Add together Answers A and B and subtract Answer C from that total.
A + B - C = _____ (Check the appropriate point total.)
 0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
 7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points
- E. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to equipment failure? (This includes clogged/broken lines or manholes.) 0
- F. How many bypass or overflow events of untreated wastewater occurred in the last year due to equipment failure prior to the headworks of the WWTP? (This includes clogged/broken lines or manholes.) 126
- G. How many of the bypass or overflow events listed in Parts E and F have been corrected such that future bypass or overflow events at the same location due to the same equipment failure are not anticipated? 126
- H. Add together Answers E and F and subtract Answer G from that total.
E + F - G = _____ (Check the appropriate point total.)
 0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
 7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points
- I. Add point values circled in D and H and enter the total in the blank below.

TOTAL POINT VALUE FOR PART 4 100

Enter this value on Part 11: Summary Sheet.

All bypass or overflow events that have occurred in the last year (for any reason) must be individually reported with this MWPP report.

Facility Name: Valley Creek WWTP

Part 5: Sludge Quantity and Storage

- A. Please provide information concerning sludge quantity, characteristics, and storage practices based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months of sludge storage capacity does the wastewater treatment facility have available, either on-site or off-site? (i.e., How many months can the facility operate without land spreading or disposing of sludge?) 4

(Check the appropriate point total.)

- Greater than or equal to 4 months = 0 points
- Less than 4 months, but greater than or equal to 3 months = 10 points
- Less than 3 months, but greater than or equal to 2 months = 20 points
- Less than 2 months, but greater than or equal to 1 month = 30 points
- Less than one month = 50 points

TOTAL POINT VALUE FOR PART 5 0

Enter this value on Part 11: Summary Sheet.

Part 6: Sludge Disposal Practices and Sites

- A. Please provide the sludge disposal practices and site information based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months or years does the facility have access to and approval for sufficient land disposal sites to provide proper land disposal? (Check the appropriate point total.)

- 36 or more months = 0 points
- 24 - 35 months = 10 points
- 12 - 23 months = 20 points
- 6 - 11 months = 30 points
- Less than 6 months = 50 points

TOTAL POINT VALUE FOR PART 6 20

Enter this value on Part 11: Summary Sheet.

Facility Name: Valley Creek WWTP

Part 7: New Development

Are there any major new developments (industrial, commercial, or residential) in the last calendar year or anticipated in the next 2-3 years such that either flow or BOD₅ loadings to the sewage system could significantly increase? Estimate additional loadings below.

Design Population: _____ Design Flow: 0.324 MGD Design BOD₅: 6,200 lbs/day
Equivalent (PE)

List industrial and/or residential developments.

The Cahaba River WWTP to Valley Creek WWTP Sludge Transfer Force Main
is under design. The project is needed to comply with the Cahaba River TMDL.
Waste sludge from Cahaba will be pumped to the Shades Transfer Sewer
and routed to the Valley Creek WWTP.

Will the additional loading overload the plant? (Check the appropriate point total.)

No = 0 points Yes = 121 points

Enter the point total in the blank below.

TOTAL POINT VALUE FOR PART 7 ⁰ _____ (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Part 8: Operator Certification

Complete the *Plant and Collection System Personnel Inventory*, ADEM Form 441.

Do both the plant operator and collection system staffing comply with ADEM Administrative Code; Division 10, Operator Certification Program? (Check the appropriate point total.)

Yes = 0 points No = 121 points

TOTAL POINT VALUE FOR PART 8 ⁰ _____ (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Valley Creek WWTP

Part 9: Financial Status

- A. Are User-Charge Revenues sufficient to cover operation and maintenance expenses? If no, how are O&M costs being financed? **Include user charge rates.**

Revenues are sufficient. The below values are based on a 5/8" meter and 6,000 gallons water use. Jefferson

County has a three tier block rate structure for residential users for 0-3, 4-6, and 7+ ccf water use.

Residential Minimum \$15.00 Plus rate 6.02; 9.36; 10.69 /1,000 gal.

Industrial Minimum \$15.00 Plus rate \$10.51 /1,000 gal.

Monthly residential rate based on 6,000 gallons usage \$ 56.04 (includes 15% credit for residential)

***Please complete the above information based on your user charge rates for the report year. You may attach a sample water and sewer bill for clarity.**

- B. What financial resources are available to pay for the wastewater improvements and/or reconstruction needs?

In 2013, Jefferson County issued Series 2013 Sewer Warrants that fund capital improvements

through 2023 at an annual average rate of \$71.9 million over the 10-year period.

Part 10: Subjective Evaluation

- A. Describe briefly the physical and structural conditions of the wastewater treatment facility.

Most of the WWTP was upgraded or newly constructed in 2005 and is in good condition. Some

equipment and processes were constructed in the 1970s, 80s, and 90s and are in fair to average condition.

Maintenance and refurbishments are planned for assets needing improvements.

- B. Describe the general condition of the sewer system (sewer lines, manholes, lift stations).

The Valley system includes roughly 7,600,000' of pipe and 80 pump stations. The system's performance

is below the expectations of the County. Repairs, replacements, and improvements are underway

and planned.

C. What sewage system improvements does the community have planned for construction in the next 5 years?

See attachment

D. What is the theoretical design life of the plant, and what is the estimated remaining useful life of the wastewater treatment facility?

See attachment

E. What problems, if any, over the last year have threatened treatment or conveyance within the system?

See attachment

F. Is the community presently involved in formal planning for treatment facility upgrading?

No

G. How many days in the last year were there residential backups at any point in the collection system for any reason other than clogging of the lateral connection? 47

H. Does the plant have a written plan for preventive maintenance on major equipment items? If yes, describe.

Yes. We have a comprehensive maintenance plan that schedules all preventive

maintenance per manufacturers recommendations or better.

Valley Creek

Part 10.C

The County has plans to bid an estimated \$14,000,000 worth of sewer line rehabilitation and repairs primarily located in the Valley Creek collection system in the summer of 2014. Design is underway for the Lincoln Ave sewer replacement that will increase capacity along a section with multiple wet-weather overflows. The County has plans to commence collection system modeling work in Valley in the summer of 2014. The results of the model will be used to develop improvement strategies for sites with past wet-weather overflows identified in Part 4.B&C of this MWPP. Headworks screen refurbishment, clarifier floor grout repairs, and significant painting efforts are all planned for the Valley Creek WWTP in the next 24 months.

Backup power generators are planned for the following pump stations: Chapel Drive #2, Moss Lane, Oakwood Drive, Trace Ridge, and Walker Avenue. Wet-well rehabilitation and pump and pipe improvements are planned for the Halls Branch pump station.

Part 10.E

Prolonged weather patterns producing saturated ground conditions prior to a storm have been identified as the primary cause of most I/I related SSOs observed in the last few years. The mini-system areas that have repeat overflows attributed to excessive I/I were included in a SSES project that included television inspection (TVI), manhole inspections, and smoke testing of all sewers. Defects and/or deficiencies have been identified and designs are being developed for rehabilitation and replacement construction projects that will bid in the summer of 2014. Several collapsed sections of sewer discovered through the TVI have already been repaired. Engineering capacity analysis of the sewers will also be performed.

While very small in volume, the Eastern Valley Road force main broke 12 times in 2013 contributing to 12 separate SSO events. A construction contract for replacement commenced on 2/5/2014 and the original scope was completed on 4/16/2014 eliminating the potential for future overflows from pipe failure. Additional replacement work is planned after more corroded pipe was identified through the construction work.

Part 10.L

Jefferson County's bankruptcy impacted the County's ability to fund needed system improvements. Specific to Valley, the hydraulic model proposed in the 2013 MWPP Resolution Form and response to Part 10.C was delayed. Design of the WWTP work described Part 10.C (digester mixing, headworks screen refurbishment, energy optimization, SCADA replacement) was also delayed. The County exited bankruptcy on December 3, 2013. The County has completed a QBS process and selected a consultant to perform the modeling work. The County is in contract negotiations and plans to commence modeling work in the summer of 2014. The County now post-bankruptcy has capital funding through 2023 at an

annual average rate of \$71.9 million over the 10-year period. This capital funding will be adequate to provide for needed improvements and system renewal. The County is committed to improving the performance of the Valley Creek complete waste treatment system.

The elimination of the Eastern Valley Force Main was listed in the 2013 MWPP Resolution Form. Through the design process it was determined to be more cost effective to replace the corroded portions of the force main than to eliminate through line extensions and capacity upgrades to a nearby gravity line. The construction to replace the force main began on 2/5/2014 and was completed on 4/16/2014 eliminating the potential for future overflows from pipe failure.

- I. Does this preventive maintenance program depict frequency of intervals, types of lubrication, and other preventive maintenance tasks necessary for each piece of equipment? (Check the appropriate response.) Yes No
- J. Are these preventive maintenance tasks, as well as equipment problems, being recorded and filed so future maintenance problems can be assessed properly? (Check the appropriate response.) Yes No
- K. Describe any major repairs or mechanical equipment replacement made in the last year and include the approximate cost for those repairs. Do not include major treatment plant construction or upgrading programs.

Trojan UV Components - \$335,850.00

Dewatering Communications Repairs - \$118,900.00

Hy-Bon Gas Compressor Parts - \$22,400.00

Dewatering Filter Press Belts - \$36,400.00

Trojan UV Communications Boards - \$15,850.00

Blower Touchscreen & Programming - \$12,500.00

Dewatering Press Parts & Cylinders - \$12,100.00

- L. List any additional comments. (Attach additional sheets if necessary.)

Facility Name: Valley Creek WWTP

Part 11: Summary Sheet

1. Enter in the values from Parts 1 through 8 in the left column below. Add the numbers in the left column to determine the MWPP Report point total the wastewater system generated for the previous calendar year.

| <u>Actual Values</u> | <u>Maximum Possible</u> |
|--------------------------|-------------------------|
| Part 1 <u>5</u> points | 80 points |
| Part 2 <u>0</u> points | 121 points |
| Part 3 <u>16</u> points | 40 points |
| Part 4 <u>100</u> points | 200 points |
| Part 5 <u>0</u> points | 50 points |
| Part 6 <u>20</u> points | 50 points |
| Part 7 <u>0</u> points | 121 points |
| Part 8 <u>0</u> points | 121 points |
| Total <u>141</u> points | 783 points |

2. Check the facility type that best describes the plant's treatment and disposal of wastewater.

- Mechanical plant with surface water discharge
 Aerated Lagoon or stabilization pond with surface water discharge
 Mechanical plant using land disposal of liquid wastes
 Aerated Lagoon or stabilization pond using land disposal of liquid wastes

3. Check the range that describes the action needed to address problems identified in the report.

- 0 - 70 pts. Actions as Appropriate*
 71 - 120 pts. Departmental Recommendation Range*
 121 - 783 Municipality Action Range*

***Other actions may be required by NPDES outside the scope of this report.**

4. Complete the *Municipal Water Pollution Prevention Resolution Form*, ADEM Form 418.

Valley - Part 11.5

Eliminating wet-weather and repeat sanitary sewer overflows in the Valley Creek system is one of the Environmental Services Department's highest priorities, and the County has dedicated significant resources to correcting the problem. In 2013, the County completed SSES investigations in 14 mini-systems in the Valley system that had recurring (2 or more) I/I related SSOs. The results of the TVI and smoke testing are being utilized to prepare rehabilitation and replacement designs. The construction work is planned to bid in the summer of 2014. The 49 SSOs noted in Part 4.D as uncorrected and potentially anticipated future SSOs are from five localized areas out of the 14 mini-systems noted above. Nearly half (24 of the 49) of the SSOs are from mini-system 1029 in Hueytown. This grouping of SSOs includes overflows from 230 Wabash Ave, 231 Dexter Court, 406 Wickstead Rd, and 612 Fairlawn Ct. Rehabilitation and sewer replacement work are included in the design plans scheduled to bid this year. Downstream capacity improvement work will likely be required to eliminate the potential for future overflows. The County has plans to commence collection system modeling work in Valley in the summer of 2014. The results of the model will be used to develop improvement strategies at this site and any other capacity limited locations identified in the collection system.

A second area with reoccurring SSOs includes 1624, 1625, and 1628 17th ST SW Birmingham in mini-system 1069. The Lincoln Ave Sewer Relocation project is under design and also planned to bid in the summer of 2014. This project will relocate the sewer to eliminate multiple siphons and increase the capacity of the sewer.


The other areas include 306 4th Ave SW Bessemer, 2122 Fulton Ave Birmingham, and 2405 Berkley Ave Bessemer. The County is committed to identifying and correcting all wet-weather related SSOs and all repetitive SSOs in the collection system.

The County has already replaced significant portions of a force main that had corrosion damage and failed 12 times in 2013 causing 12 different SSO events.

Valley Creek Wastewater Treatment Plant
ATTACHMENT 2 – Raw Sewage Bypass and
SUMMARY



VALLEY CREEK BASIN 2013 DISCHARGES



NOTE: OVERFLOWS SHOWN ARE OVER 10,000 GALLONS.



Summary of Unpermitted Discharges - Valley Creek

January 01, 2013 through December 31, 2013

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|--|-------------------|--|-----------------|--------------|-----------------------------------|---------------|-----------------------|------------------|-----------------------------------|
| C01033 | 1/2/13 | 5034 Eastern Valley Road | Valley | Ground Absorbed | 2,500 | Pipe | Force Main Break | Moderate Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| C01034 | 1/2/13 | 306 4th Ave SW | Valley | Feeder Creek to Valley Creek | 1,200 | Manhole | Grease/Debris/Surcharge from Rain | Moderate Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| C01035 | 1/2/13 | 3696 Hilltop Rd (Morgan Greenwood #2 PS) | Valley | Ground Absorbed | 1,080 | Pump Station | P.S. Equipment Failure | Moderate Rain | Pump Station Repaired | Brian Champion | Sewer Maintenance Supervisor |
| Notes: #1 pump was clogged causing it to not pump incoming flow. #2 pump was put on line and the overflow was stopped. | | | | | | | | | | | |
| C01036 | 1/14/13 | 306 4th Ave SW | Valley | Storm Drain/Feeder Creek to Valley Creek | 1,437,200 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Don Goodwin | Sewer Video Operations Supervisor |
| Notes: | | | | | | | | | | | |
| C01039 | 1/15/13 | 101 Hemmosa Drive | Valley | Ground Absorbed/Storm Drain/Shades Creek | 1,867,502 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| C01042 | 1/15/13 | 260 Shades Crest Road (Ross Bridge Pkwy) | Valley | Shades Creek | 250,000 | Manhole | Surcharge from Rain | Moderate Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|--------------------------|-------------------|------------------------------|-----------------|------------------|---------------------|------------|----------------|------------------|-----------------------------------|
| C01043 | 1/16/13 | 5082 Eastern Valley Road | Valley | Ground Absorbed | 1,740 | Pipe | Force Main Break | Heavy Rain | Line Repaired | Don Goodwin | Sewer Video Operations Supervisor |
| Notes: | | | | | | | | | | | |
| C01044 | 1/18/13 | 5082 Eastern Valley Road | Valley | Ground Absorbed | 2,990 | Pipe | Force Main Break | Light Rain | Line Repaired | Don Goodwin | Sewer Video Operations Supervisor |
| Notes: | | | | | | | | | | | |
| C01045 | 1/18/13 | 5082 Eastern Valley Road | Valley | Ground Absorbed | 1,725 | Pipe | Force Main Break | Light Rain | Line Repaired | Don Goodwin | Sewer Video Operations Supervisor |
| Notes: | | | | | | | | | | | |
| C01046 | 1/25/13 | 5082 Eastern Valley Rd | Valley | Ground Absorbed | 506 | Pipe | Force Main Break | No Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| C01047 | 1/25/13 | 101 Hermosa Drive | Valley | Storm Drain | 1,028 | Bypass Pump Hose | Bypass Pumping | No Rain | Area Cleaned | Brian Champion | Sewer Maintenance Supervisor |
| Notes: When rolling up hose from bypass pumping operations, sewage contained within the hose was released. | | | | | | | | | | | |
| C01049 | 1/29/13 | 1923 21st Ave S | Valley | Ground Absorbed | | Manhole | Unknown | No Rain | Sent to TVI | Brian Champion | Sewer Maintenance Supervisor |
| Notes: Manhole was not overflowing upon crew arrival. Evidence of an overflow found around manhole. | | | | | | | | | | | |
| C01051 | 1/30/13 | 101 Hermosa Drive | Valley | Storm Drain/ Shades Creek | 57,486 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| C01052 | 1/30/13 | 306 4th Ave SW | Valley | Drainage Ditch/ Valley Creek | 487,400 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|--------------------------------|-------------------|--|-----------------|---------|---|---------------|---------------------|------------------|------------------------------|
| C01053 | 1/30/13 | Cahaba Rd & 20th Place S | Valley | Drainage Ditch/ Storm Drain/ Shades Creek | 33,825 | Manhole | Grease | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01054 | 1/30/13 | G&H Road and Eastern Valley Rd | Valley | Ground Absorbed | 912 | Pipe | Force Main Break | Moderate Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01055 | 1/31/13 | 5082 Eastern Valley Road | Valley | Ground Absorbed | 920 | Pipe | Force Main Break | Moderate Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01056 | 2/11/13 | 306 4th Ave SW | Valley | Drainage Ditch/ Feeder Creek to Valley Creek | 1,274,000 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01057 | 2/11/13 | 5016 Eastern Valley Road | Valley | Ground Absorbed | 874 | Pipe | Force Main Break | Moderate Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01058 | 2/11/13 | 101 Hemmosa Dr | Valley | Storm Drain/ Shades Creek | 164,484 | Manhole | Broken Water Main Discharging into Sanitary Sewer | Heavy Rain | Water Main Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Large diameter water main was broken discharging approximately 5 MGD into sanitary sewer line. Broken small diameter water line also discharging into sanitary sewer line.</i> | | | | | | | | | | | |
| C01059 | 2/11/13 | 4939 Bessemer Johns Rd | Valley | Ground Absorbed | 3 | Manhole | Roots | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|---|---------------|---------------------------|-------------------|--|-----------------|------------------|---|---------------|-----------------------|------------------|------------------------------|
| C01060 | 2/12/13 | Eastern Valley Rd & Ave G | Valley | Ground Absorbed | 948 | Pipe | Force Main Break | Moderate Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Level control fault caused pumps to run on air.</i> | | | | | | | | | | | |
| C01061 | 2/22/13 | 2017 Mississippi Ave | Valley | Drainage Ditch/ Valley Creek | 785 | Manhole | P.S. Equipment Failure | Moderate Rain | Pump Station Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Large diameter water main was broken discharging approximately .5 MGD into sanitary sewer line. Broken small diameter water line also discharging into sanitary sewer line.</i> | | | | | | | | | | | |
| C01062 | 2/22/13 | 101 Hermosa Drive | Valley | Storm Drain/ Shades Creek | 252,870 | Manhole | Broken Water Main Discharging into Sanitary Sewer | Heavy Rain | Water Main Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Pump station pumps became clogged with rags.</i> | | | | | | | | | | | |
| C01063 | 2/22/13 | 3696 Hilltop Rd SE | Valley | Ground Absorbed | 639 | Manhole | P.S. Equipment Failure | Moderate Rain | Pump Station Repaired | Brian Champion | Sewer Maintenance Supervisor |
| C01064 | 2/23/13 | 306 4th Ave SW | Valley | Drainage Ditch/ Feeder Creek to Valley Creek | 117,182 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: When bypass pumping operation was disassembled there was an amount of sewage that could not be contained. The affected area was washed and cleaned.</i> | | | | | | | | | | | |
| C01067 | 2/27/13 | 4954 Eastern Valley Rd | Valley | Ground Absorbed | 770 | Pipe | Force Main Break | No Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| C01068 | 3/6/13 | 101 Hermosa Dr. | Valley | Ground Absorbed/ Storm Drain | 879 | Bypass Pump Hose | Removing Bypass Pumps | No Rain | Cleaned Areas | Brian Champion | Sewer Maintenance Supervisor |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|------------------------|-------------------|--|-----------------|---------|------------------------|---------------|------------------|-------------------|------------------------------------|
| C01070 | 3/23/13 | 2 Country Club Rd | Valley | Storm Drain/ Watkins Branch | | Manhole | Surcharge from Rain | Heavy Rain | Cleaned Area | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Manhole not overflowing upon crew arrival, but there was evidence on the ground.</i> | | | | | | | | | | | |
| C01071 | 3/23/13 | 1149 Daniel Dr | Valley | Valley Creek | 2,704 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01072 | 3/23/13 | 1923 21st Ave S | Valley | Ground Absorbed/ Feeder to Shades Creek | | Manhole | Surcharge from Rain | Heavy Rain | Cleaned Area | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Manhole not overflowing upon crew arrival, but there was evidence on the ground.</i> | | | | | | | | | | | |
| C01073 | 3/24/13 | 306 4th Ave SW | Valley | Drainage Ditch/ Feeder Creek to Valley Creek | 14,355 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01075 | 4/12/13 | 551 W Oxmoor Rd | Valley | Shades Creek | 882 | Manhole | Roots/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01078 | 5/4/13 | 306 4th Ave SW | Valley | Drainage Ditch/ Feeder Creek to Valley Creek | 6,924 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01084 | 7/19/13 | 105 Oxmoor Pl Cir | Valley | Storm Drain | 93 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01085 | 7/24/13 | 4954 Eastern Valley Rd | Valley | Ground Absorbed | 900 | Pipe | Force Main Break | No Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|-------------------|-------------------|--|-----------------|------------------------------|--|---------------|---|------------------|------------------------------|
| C01089 | 8/30/13 | 320 Kenilworth Dr | Valley | Shades Creek | | Pipe | Gravity Main Break/ Contractors Bypass Operations | No Rain | Contractor Adjusted the Bypass Operation/ Project Planned to Replace/ Repair Line | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Volume was not determinable.</i> | | | | | | | | | | | |
| C01090 | 9/5/13 | 168 Lucerne Blvd | Valley | Storm Drain | | Pipe | Construction Damage/ Gravity Main Break | No Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Contractor working on storm sewer for City of Homewood broke sanitary sewer line. Volume was not determinable.</i> | | | | | | | | | | | |
| C01091 | 9/9/13 | 320 Kenilworth Dr | Valley | Shades Creek | | Pipe | Gravity Main Break/ Plug Failure | No Rain | Plug Replaced | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Contractor performing rehabilitation work for the County had a plug failure while bypassing flow. Volume was not determinable.</i> | | | | | | | | | | | |
| C01092 | 9/23/13 | 306 4th Ave SW | Valley | Drainage Ditch/ Feeder to Valley Creek | | Manhole | Surcharge from Rain | Moderate Rain | Crew Responded | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Overflow occurred on 9/21/13 but was not called in until 9/23/13. County crew responded and did not find manhole overflowing. Volume was not determinable.</i> | | | | | | | | | | | |
| C01093 | 9/23/13 | 320 Kenilworth Dr | Valley | Shades Creek | | Pipe | Gravity Main Break/ Pump Failure | No Rain | Pumps Back Online | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Contractor performing rehabilitation work for the County had a pump failure while bypassing flow. Volume was not determinable.</i> | | | | | | | | | | | |
| C01094 | 9/24/13 | 2169 Headrick Rd | Valley | Ground Absorbed/ Shades Creek | 675 | Air Release Valve in Manhole | Cracked Air Release Valve | No Rain | Repaired Air Release Valve | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01095 | 9/25/13 | 320 Kenilworth Dr | Valley | Shades Creek | | Pipe | Gravity Main Break/ Plug Failure | No Rain | Plug Replaced | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Contractor performing rehabilitation work for the County had a plug failure while bypassing flow. Volume was not determinable.</i> | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|---|---------------|-------------------------------|-------------------|---|-----------------|----------------------|---------------------------|------------------|---|-------------------|------------------------------------|
| C01096 | 9/29/13 | 320 Kenilworth Dr | Valley | Storm Drain/ Shades Creek | | Discharge Hose | Hole in Discharge Hose | No Rain | Hose Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Contractor performing rehabilitation work for the County had a hole develop in the hose while bypassing flow. Volume was not determinable.</i> | | | | | | | | | | | |
| C01097 | 9/30/13 | 323 Edgewood Blvd | Valley | Ground Absorbed | | Cleanout | Bypass Pump | No Rain | Cleaned and Adjusted Pumps and Plugs | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Contractor performing rehabilitation work for the County caused a cleanout to overflow while bypassing flow. Evidence of a cleanout overflow was not discovered until the following morning. Volume was not determinable.</i> | | | | | | | | | | | |
| C01100 | 12/9/13 | 306 4th Ave SW | Valley | Feeder to Valley Creek | 27,848 | Manhole | Surcharge from Rain | Moderate Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01101 | 12/10/13 | 5034 Eastern Valley Rd | Valley | Ground Absorbed | 2,520 | Pipe | Force Main Break | No Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01102 | 12/25/13 | Orchard Ave & Southampton Cir | Valley | Storm Drain | 324 | Manhole | P.S. Equipment Failure | No Rain | Pump Station Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Level control failure. Electricians repaired and restarted pump station.</i> | | | | | | | | | | | |
| M04309 | 1/1/13 | 529 Flint Road | Valley | Ground Absorbed | 5,000 | Manhole | Grease/ Rags | Heavy Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04310 | 1/2/13 | 2227 21st St SW | Valley | Storm Drain/ Drainage Ditch/ Valley Creek | 66,001 | Cleanout/ Manhole | Grease/ Debris/ Rags | Heavy Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04311 | 1/2/13 | 2227 21st Street SW | Valley | Ground Absorbed | | Pipe | Construction Damage | Heavy Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: ALAGASCO drilled through sanitary sewer line. Volume was not determinable.</i> | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|---------------------------------|-------------------|---|-----------------|----------|-----------------------|---------------|------------------|------------------|-----------------------------------|
| M04314 | 1/6/13 | Green Springs Hwy & Raleigh Ave | Valley | Storm Drain/ Shades Creek | 2,000 | Manhole | Debris/ Small Bottles | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Volume not determinable. Evidence was found around manhole while jetwashing lines in the area.</i> | | | | | | | | | | | |
| M04316 | 1/8/13 | 5331 Woodward Road | Valley | Ground Absorbed | | Manhole | Unknown | No Rain | Lines Cleaned | Brian Champion | Sewer Maintenance Supervisor |
| M04317 | 1/9/13 | 1860 Russet Hill Cir | Valley | Storm Drain | 79 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04318 | 1/10/13 | 132 17th St SW | Valley | Ground Absorbed | 1,386 | Cleanout | Grease/ Debris/ Rags | Light Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04319 | 1/13/13 | 612 Fairlawn Ct | Valley | Drainage Ditch/ Feeder Creek to Valley Creek | 285,525 | Manhole | Surcharge from Rain | Moderate Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04320 | 1/14/13 | 920 Fairdale Rd | Valley | Feeder Creek to Valley Creek | 260,820 | Cleanout | Surcharge from Rain | Moderate Rain | Line Monitored | Don Goodwin | Sewer Video Operations Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04321 | 1/14/13 | 406 Wickstead Rd | Valley | Drainage Ditch/ Feeder Creek to Valley Creek | 424,260 | Cleanout | Surcharge from Rain | Moderate Rain | Line Monitored | Don Goodwin | Sewer Video Operations Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04322 | 1/14/13 | 1628 & 1625 17th St SW | Valley | Storm Drain/ Valley Creek | 5,212,395 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|---|---------------|--------------------------------------|-------------------|---|-----------------|---------|----------------------------|---------------|--|------------------|------------------------------|
| M04324 | 1/14/13 | 735 9th Ave W | Valley | Ground Absorbed | 22,000 | Manhole | Grease | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04327 | 1/14/13 | 2122 Fulton Ave SW & St. Charles Ave | Valley | Drainage Ditch/ Storm Drain/ Valley Creek | 5,158 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04328 | 1/15/13 | 2405 Berkley Ave | Valley | Storm Drain/ Feeder Creek to Valley Creek | 1,189,890 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: Manholes 1014-026/024/019/0144/014 | | | | | | | | | | | |
| M04329 | 1/15/13 | 230 Wabash Ave | Valley | Storm Drain/ Valley Creek | 302,994 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04330 | 1/15/13 | 5320 Central Ave | Valley | Drainage Ditch/ Valley Creek | 3,391 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04334 | 1/22/13 | 2905 Carlisle Rd | Valley | Drainage Ditch/ Watkins Brook | 18 | Pipe | Grease/ Gravity Main Break | No Rain | Blockage Removed/ Project Planned to Replace/Repair Line | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04335 | 1/23/13 | 6633 Ave N | Valley | Ground Absorbed | 3 | Manhole | Grease/ Roots/ Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04338 | 1/30/13 | 2122 Fulton Ave | Valley | Storm Drain/ Valley Creek | 87,426 | Manhole | Surcharge from Rain | Light Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-----------|---------------|---|-------------------|---|-----------------|----------|------------------------|----------------------------|------------------|-------------------|------------------------------------|
| M04339 | 1/30/13 | St. Charles Ave & 21st St SW | Valley | Drainage Ditch/ Valley Creek | 230,040 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04340 | 1/30/13 | 231 Dexter Court | Valley | Drainage Ditch/ Valley Creek | 75,846 | Manhole | Surcharge from Rain | Light Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04341 | 1/30/13 | 406 Wickstead Rd | Valley | Drainage Ditch/ Valley Creek | 296,192 | Cleanout | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04342 | 1/30/13 | 2405 Berkley Ave & 317 25th St S | Valley | Storm Drain/ Feeder Creek to Valley Creek | 172,141 | Manhole | Surcharge from Rain | Light/ Moderate Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04343 | 1/31/13 | 1624 17th St SW | Valley | Storm Drain/ Feeder Creek to Valley Creek | 115,978 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04344 | 2/1/13 | 1521 Valley View Cir | Valley | Ground Absorbed | 8 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04345 | 2/1/13 | 2905 Carlisle Rd | Valley | Ground Absorbed | 2 | Manhole | Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04346 | 2/4/13 | Old Montgomery Hwy downstream of Foxcroft St | Valley | Ground Absorbed | 936 | Manhole | Grease/ Roots | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|---|---------------|---|-------------------|--|-----------------|----------------------------|----------------------|---------------|------------------|------------------|------------------------------|
| M04347 | 2/6/13 | 5229 Ross Bridge Parkway | Valley | Storm Drain | | Bypass Pump Discharge Hose | Ruptured Hose | No Rain | Hose Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Bypass hose coupling being utilized by a Contractor performing a sanitary sewer repair was run over by a vehicle and damaged.</i> | | | | | | | | | | | |
| M04348 | 2/10/13 | Alley between 1900 & 2000 Rev Abraham Woods Jr Blvd | Valley | Ground Absorbed | 111 | Manhole | Grease | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04349 | 2/11/13 | 406 Wickstead Rd | Valley | Drainage Ditch/ Feeder Creek to Valley Creek | 537,848 | Cleanout | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04350 | 2/11/13 | 231 Dexter Court | Valley | Drainage Ditch/ Valley Creek | 29,147 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04351 | 2/11/13 | 1625 & 1628 17th St SW | Valley | Storm Drain/ Valley Creek | 31,335 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04352 | 2/11/13 | 921 Barclay Dr & 660 9th Ave SW | Valley | Drainage Ditch/ Storm Drain | 6,711 | Manhole | Grease/ Debris/ Rags | Heavy Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04353 | 2/13/13 | 401 Woodland Village | Valley | Ground Absorbed | 65 | Manhole | Grease/ Debris/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04355 | 2/15/13 | 5420 Stadium Trace Pkwy | Valley | Ground Absorbed | | Manhole | Jetwashing trap | No Rain | Removed trap | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: While jetwashing the sanitary sewer line the debris trap became hung when the pump station started causing a partial blockage in the manhole.</i> | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|-------------------------|-------------------|--|-----------------|----------|---------------------|---------------|----------------|------------------|------------------------------|
| M04356 | 2/22/13 | 2405 Berkley Ave | Valley | Storm Drain | 1,572 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04357 | 2/22/13 | 1625 & 1628 17th St SW | Valley | Storm Drain/ Valley Creek | 36,954 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04358 | 2/22/13 | 5400 Stadium Trace Pkwy | Valley | Drainage Ditch/ Storm Drain | | Manhole | Jetwashing trap | No Rain | Removed trap | Brian Champion | Sewer Maintenance Supervisor |
| Notes: While jetwashing the sanitary sewer line the debris trap became hung when the pump station started causing a partial blockage in the manhole. | | | | | | | | | | | |
| M04359 | 2/22/13 | 231 Dexter Court | Valley | Drainage Ditch/ Feeder Creek to Valley Creek | 139,630 | Manhole | Surcharge from Rain | Light Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04360 | 2/22/13 | 612 Fairlawn Cir | Valley | Drainage Ditch/ Feeder Creek to Valley Creek | 145 | Manhole | Surcharge from Rain | Light Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04361 | 2/22/13 | 406 Wickstead Rd | Valley | Drainage Ditch/ Feeder Creek to Valley Creek | 103,880 | Cleanout | Surcharge from Rain | Light Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04363 | 2/26/13 | 406 Wickstead Rd | Valley | Drainage Ditch/ Feeder Creek to Valley Creek | 126,300 | Cleanout | Surcharge from Rain | Light Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04364 | 2/26/13 | 231 Dexter Court | Valley | Drainage Ditch/ Feeder Creek to Valley Creek | 3,000 | Manhole | Surcharge from Rain | Moderate Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|------------------------------|-------------------|---|-----------------|----------|-------------------------------|---------------|-----------------------|------------------|------------------------------|
| M04366 | 2/27/13 | 1501 Arthur Shores Dr SW | Valley | Ground Absorbed | 74 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04367 | 2/27/13 | 1625 17th St SW | Valley | Storm Drain/ Feeder to Valley Creek | 80,940 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04368 | 3/7/13 | 113 Stratford Road | Valley | Ground Absorbed | 235 | Manhole | Roots | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04369 | 3/9/13 | 301 Beacon Drive | Valley | Ground Absorbed | 77 | Cleanout | Grease/ Bed Sheets/ Towels | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04371 | 3/12/13 | 2905 Carlisle Rd | Valley | Watkins Brook | 3 | Manhole | Gravity Main Break | Light Rain | Manhole Repaired | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04372 | 3/12/13 | 3209 Lee Ave SW | Valley | Ground Absorbed | 6,020 | Cleanout | Grease/ Roots/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04375 | 3/19/13 | Int. of Rose Ave & Isabel St | Valley | Feeder to Valley Creek | 13,114 | Manhole | Construction Damage | No Rain | Bypass Pump Restarted | Brian Champion | Sewer Maintenance Supervisor |
| Notes: Contractor's bypass pump shut down and caused overflow. Company returned and restarted pump and the overflow stopped. | | | | | | | | | | | |
| M04377 | 3/21/13 | 1023 Princeton Ave SW | Valley | Drainage Ditch | 76 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-----------|---------------|---------------------|-------------------|--|-----------------|----------|------------------------|------------------|------------------|-------------------|------------------------------------|
| M04378 | 3/23/13 | 231 Dexter Court | Valley | Storm Drain/ Feeder to Valley Creek | 956 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04379 | 3/23/13 | 406 Wickstead Road | Valley | Drainage Ditch/ Feeder to Valley Creek | 19,950 | Cleanout | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04380 | 3/23/13 | 2122 Fulton Ave | Valley | Storm Drain/ Valley Creek | 84,992 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04381 | 3/23/13 | 1301 Lincoln St SW | Valley | Ground Absorbed | 289 | Manhole | Grease/ Rags | Heavy Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04384 | 4/1/13 | 1901 6th Ave S | Valley | Storm Drain | 1,326 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04386 | 4/4/13 | 4369 Mountindale Rd | Valley | Storm Drain | 163 | Manhole | Grease/ Debris | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04388 | 4/7/13 | 135 Robertson Ave | Valley | Feeder to Lick Creek | 2,511 | Manhole | Grease/ Roots | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04389 | 4/8/13 | 3817 Montevallo Rd | Valley | Ground Absorbed/ Drainage Ditch | 113 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|---|---------------|------------------------|-------------------|--|-----------------|----------|----------------------|---------------|------------------|------------------|------------------------------|
| M04390 | 4/8/13 | 509 & 511 35th St | Valley | Ground Absorbed | 588 | Cleanout | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04391 | 4/10/13 | 1650 28th Cr S | Valley | Ground Absorbed | | Manhole | Grease/ Debris/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Manhole not overflowing upon crew arrival, but there was evidence on the asphalt.</i> | | | | | | | | | | | |
| M04392 | 4/11/13 | 1625 & 1628 17th St SW | Valley | Storm Drain/ Valley Creek | 9,418 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04393 | 4/11/13 | 406 Wickstead Rd | Valley | Feeder Creek to Valley Creek | 70,348 | Cleanout | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04397 | 4/15/13 | 801 Golf Course Rd | Valley | Storm Drain | 2,625 | Manhole | Grease/ Debris/ Rags | Light Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04398 | 4/19/13 | 2122 Fulton Ave | Valley | Storm Drain/ Valley Creek | 110 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04399 | 4/19/13 | 2820 Commerce Blvd | Valley | Ground Absorbed | 3,357 | Manhole | Roots | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04400 | 4/19/13 | 231 Dexter Ct | Valley | Drainage Ditch/ Feeder to Valley Creek | 1,380 | Manhole | Surcharge from Rain | Moderate Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|---|---------------|--------------------|-------------------|--|-----------------|----------|---|------------------|------------------|-------------------|------------------------------------|
| M04401 | 4/19/13 | 406 Wickstead Rd | Valley | Drainage Ditch/ Valley Creek | 18,830 | Cleanout | Surcharge from Rain | Moderate Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04406 | 4/29/13 | 3845 South Cove Dr | Valley | Drainage Ditch/ Storm Drain/ Drainage to Shades Creek | | Pipe | Construction Damage/ Gravity Main Break | No Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| Notes: Gravity sewer line damaged by Birmingham Water Works crew. | | | | | | | | | | | |
| M04407 | 4/29/13 | 6701 Forest Drive | Valley | Ground Absorbed | 3 | Pipe | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04409 | 5/4/13 | 406 Wickstead Rd | Valley | Drainage Ditch/ Valley Creek | 235,468 | Cleanout | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04410 | 5/4/13 | 231 Dexter Court | Valley | Storm Drain/ Valley Creek | 73,440 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04411 | 5/4/13 | 2405 Berkley Ave | Valley | Storm Drain/ Valley Creek | 25,881 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04413 | 5/9/13 | 409 Ridgewood Ave | Valley | Ground Absorbed | 11,360 | Cleanout | Grease/ Roots/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-----------|---------------|-------------------------|-------------------|---|-----------------|----------|-----------------------------|------------|--|------------------|------------------------------|
| M04414 | 5/12/13 | 104 Woodland Village Dr | Valley | Storm Drain | 183 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04415 | 5/15/13 | 2909 Overhill Rd | Valley | Storm Drain | 107 | Manhole | Roots | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04416 | 5/16/13 | 407 Rosewood St | Valley | Shades Creek | 4,551 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04420 | 5/24/13 | 4101 Brook Way | Valley | Feeder Creek to Shades Creek | | Pipe | Gravity Main Break | No Rain | Project Planned to Replace/Repair Line | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04421 | 5/25/13 | 5320 Beacon Drive | Valley | Storm Drain | 3,968 | Manhole | Grease/ Debris/ Rags/ Rocks | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04425 | 6/10/13 | 231 Dexter Court | Valley | Ground Absorbed/ Valley Creek | 115 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04426 | 6/10/13 | 406 Wickstead Rd | Valley | Ground Absorbed/ Drainage Ditch/ Valley Creek | 27,520 | Cleanout | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04427 | 6/11/13 | 30 Laverne Ave | Valley | Drainage Ditch | 42 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|---|---------------|-----------------------|-------------------|---------------------------------|-----------------|----------|----------------------|---------------|------------------|------------------|------------------------------|
| M04428 | 6/20/13 | 2305 Granville Ave | Valley | Ground Absorbed | 16 | Cleanout | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04429 | 6/22/13 | 2801 Wilson Rd SW | Valley | Ground Absorbed | 270 | Cleanout | Grease/ Debris/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04430 | 7/1/13 | 517 21st Ave S | Valley | Ground Absorbed | 1 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: Manhole not overflowing upon crew arrival, but there was evidence on the ground. | | | | | | | | | | | |
| M04433 | 7/11/13 | 529 Flint Hill Road | Valley | Ground Absorbed | 162 | Manhole | Grease/ Rags | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04434 | 7/18/13 | 921 Medical Center Dr | Valley | Storm Drain | 720 | Manhole | Grease/ Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04435 | 7/22/13 | 3103 Ensley Avenue | Valley | Storm Drain | 560 | Cleanout | Grease | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04436 | 8/12/13 | 204 St Charles St | Valley | Ground Absorbed/ Drainage Ditch | 96 | Manhole | Roots/ Debris/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04437 | 8/17/13 | 2828 Linden Ave | Valley | Storm Drain | 6,000 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-------------------------------------|---------------|------------------------|-------------------|----------------------------------|-----------------|----------|--|---------|--------------------|-------------------|------------------------------------|
| M04438 | 8/19/13 | 3212 Country Club Rd | Valley | Drainage Ditch/ Watkins Brook | 294 | Manhole | Grease/ Roots/ Debris/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04439 | 8/23/13 | 504 Brookwood Blvd | Valley | Storm Drain/ Shades Creek | | Pipe | Gravity Main Break | No Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| Notes: Volume was not determinable. | | | | | | | | | | | |
| M04440 | 8/30/13 | 7780 Ludington Ln | Valley | Storm Drain | 63 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04443 | 9/10/13 | 6637 Seminole Cir | Valley | Ground Absorbed | 95 | Manhole | Grease/ Roots | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04445 | 9/17/13 | 1025 Woodward Rd | Valley | Storm Drain | 1,370 | Manhole | Grease/ Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04446 | 9/18/13 | 1144 Daniel Dr | Valley | Ground Absorbed | 1 | Manhole | Jetwashing a Line and Had a Blowback | No Rain | Stopped Jetwashing | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04447 | 9/19/13 | 1100 Medical Center Dr | Valley | Ground Absorbed | 6 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04448 | 9/20/13 | 3325 Country Club Rd | Valley | Drainage Ditch | 5,684 | Cleanout | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-----------|---------------|-------------------------------|-------------------|------------------------------|-----------------|----------|---------------------------------|---------|---------------------------------|------------------|------------------------------|
| M04449 | 9/20/13 | Between 4212 & 4216 Terrace S | Valley | Drainage Ditch | 2,675 | Pipe | Gravity Main Break/ Rags/ Rocks | No Rain | Blockage Removed/ Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04450 | 9/26/13 | 2305 Granville Ave | Valley | Ground Absorbed | 67 | Manhole | Grease/ Rags | No Rain | Blockage Replaced | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04451 | 10/9/13 | 5012 5th Ave N | Valley | Ground Absorbed | 93 | Manhole | Grease/ Debris/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04452 | 10/10/13 | 103 Creel St | Valley | Ground Absorbed | 3 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04453 | 10/13/13 | 301 Beacon Crest Ln | Valley | Ground Absorbed | 504 | Cleanout | Grease/ Debris/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04454 | 10/15/13 | 7205 Pine Tree Ln | Valley | Ground Absorbed | 330 | Cleanout | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04456 | 10/18/13 | 5240 Dresden Rd | Valley | Ground Absorbed | 354 | Manhole | Grease/ Roots/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04457 | 10/18/13 | 5012 5th Ave N | Valley | Drainage Ditch/ Valley Creek | 1,350 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-------------------------------------|---------------|------------------------|-------------------|--|-----------------|-----------------------|---------------------|------------|---------------------------------|------------------|------------------------------|
| M04458 | 10/21/13 | 143 Oak Ave | Valley | Drainage Ditch | 1,350 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04459 | 10/29/13 | 2177 11th Cr S | Valley | Storm Drain | 54 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04461 | 11/5/13 | 1001 17th St S | Valley | Storm Drain | 1,456 | Manhole | Grease/ Asphalt | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04462 | 11/8/13 | 3345 45th St SW | Valley | Ground Absorbed | 26,400 | Cleanout | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04463 | 11/8/13 | 2800 Wilson Rd | Valley | Valley Creek | 25,168 | Manhole | Debris/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04464 | 11/14/13 | 1477 Milner Crescent | Valley | Storm Drain | | Pipe/ Holes in Ground | Gravity Main Break | No Rain | Blockage Removed/ Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| Notes: Volume was not determinable. | | | | | | | | | | | |
| M04467 | 11/20/13 | 9218 Country Club Blvd | Valley | Storm Drain/ Watkins Brook | | Pipe | Grease/ Roots/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: Volume was not determinable. | | | | | | | | | | | |
| M04471 | 11/26/13 | 231 Dexter Court | Valley | Drainage Ditch/ Feeder to Valley Creek | 12,420 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-----------|---------------|------------------------------|-------------------|---|-----------------|----------|---------------------|------------|------------------|------------------|------------------------------|
| M04472 | 11/26/13 | 5600 Oporto Madrid Blvd | Valley | Drainage Ditch | 69 | Manhole | Rags | Heavy Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04473 | 11/26/13 | St. Charles Ave & 21st St SW | Valley | Drainage Ditch/ Valley Creek | 6,750 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04474 | 11/26/13 | 2122 Fulton Ave | Valley | Storm Drain/ Valley Creek | 12,789 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04475 | 11/26/13 | 406 Wickstead Rd | Valley | Drainage Ditch/ Feeder to Valley Creek | 18,158 | Cleanout | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04476 | 11/27/13 | 913 Cotton Ave SW | Valley | Ground Absorbed | 12 | Cleanout | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04477 | 11/27/13 | 801 Golf Course Rd | Valley | Storm Drain | 13,500 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04484 | 12/6/13 | 249 Graymont Ave W | Valley | Ground Absorbed | 4 | Manhole | Grease/ Rags | Light Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04485 | 12/7/13 | 2613 Cherokee Rd | Valley | Drainage Ditch | 60 | Manhole | Grease/ Rags | Light Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|------------------------|-------------------|------------------------|-----------------|----------|------------------------|---------------|------------------------------------|------------------|------------------------------|
| M04488 | 12/9/13 | 1625 & 1628 17th St SW | Valley | Storm Drain | 38,640 | Manhole | Surcharge from Rain | Moderate Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04489 | 12/9/13 | 406 Wickstead Rd | Valley | Feeder to Valley Creek | 404 | Cleanout | Surcharge from Rain | Moderate Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: Cleanout not overflowing upon crew arrival, but there was evidence on the ground. | | | | | | | | | | | |
| M04491 | 12/13/13 | 521 Fair Oaks Dr | Valley | Ground Absorbed | 864 | Manhole | Grease/ Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04492 | 12/13/13 | 1044 Sunset Blvd | Valley | Storm Drain | 246 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04493 | 12/15/13 | 101 Peachtree Rd | Valley | Ground Absorbed | 103 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04494 | 12/16/13 | 2330 Highland Ave S | Valley | Ground Absorbed | 24 | Manhole | Gravity Main Break | No Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04495 | 12/17/13 | 705 19th St SW | Valley | Storm Drain | | Pipe | Grease/ Leaking Joints | No Rain | Blockage Removed/ Pumped Siphon | Brian Champion | Sewer Maintenance Supervisor |
| Notes: Volume was not determinable. | | | | | | | | | | | |
| M04498 | 12/19/13 | 803 Green Springs Hwy | Valley | Storm Drain | 336 | Cleanout | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|--|---------------|-----------------------------|-------------------|----------------------|-----------------|-------------------|----------------------|---------------|------------------|------------------|------------------------------|
| M04501 | 12/26/13 | Goldwire St SW & 1st Ave SW | Valley | Drainage Ditch | 44,750 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04502 | 12/30/13 | 5103 7th Ave Wylam | Valley | Storm Drain | 481 | Manhole | Grease/ Debris | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04503 | 12/30/13 | 6500 Cherokee Dr | Valley | Ground Absorbed | 896 | Cleanout | Grease/ Debris/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04504 | 12/31/13 | 1108 1st St N | Valley | Ground Absorbed | | Pipe | Grease/ Debris/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Volume was not determinable.</i> | | | | | | | | | | | |
| M04522 | 1/31/13 | 501 Palisades Blvd | Valley | Drainage Ditch | 2,641 | Cleanout/ Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |

Valley Creek Wastewater Treatment Plant

ATTACHMENT 3 – MWPP Sewage Sludge

SURVEY



MWPP SEWAGE SLUDGE SURVEY

Facility Background Information:

1. Facility Information

Permit Number: AL0023655Name: Valley Creek WWTPStreet Address: 3923 Clear Water Drive Bessemer, AL 35023County: Jefferson

2. Facility Contact

Name: Robby BennettTitle: Plant ManagerTelephone: (205) 428-2614Permittee Name: Jefferson County CommissionMailing Address: ESD Suite A-300 716 Richard Arrington Jr. Blvd. N.
Birmingham, AL 35203

Facility Flow Information

1. Facility Wastewater Treatment Capacity

Avg. Daily Flow for 2000: 51.1 MGDFacility Design Capacity: 85.0 MGD

2. Estimated Septage Quantity Handled (Residuals Removed from Septic Tank Systems)

Average Domestic Septage: 301,917 gallons per monthAverage Commercial Septage: N/A gallons per month

3. Method of Septage Processing

Mixed with Influent Wastewater for TreatmentMixed with Sewage SludgeMixed with influent wastewater for treatment

4. Estimated Percentage Contributing Wastewater Flow

Residential: 85 %Industrial: 7 %Other: 8 %Describe: Commercial

5. List type of wastewater treatment process(es) utilized at this facility:

Screening, Grit Removal, Settling, Aeration with Activated Sludge,
Clarification, & U.V. Disinfection.

6. Estimated sewage sludge wasting rate at this facility:

or 197,443lb/day dry weight
gallons per day

7. Estimated untreated sludge received from off site:

or 9,926lb/day dry weight
gallons per day

8. Estimated percent solids of combined sewage sludge prior to treatment:

0.1 %

9. List the sewage sludge treatment processes used in preparing sludge for final use or disposal:

| | Sludge Quantity (untreated pounds per day) |
|--|---|
| <u>Thickening</u> | _____ |
| <u>Anaerobic Digestion</u> | _____ |
| <u>Mechanical Dewatering (Belt Filter Presses)</u> | _____ |
| <u>Lime Stabilization</u> | _____ |

10. Estimate the total volume of sludge generated:

_____ 4111 _____
(dry U.S. tons per year)

Sludge Disposal Methods

1. Which of the following describes the current method of sewage sludge disposal for this facility:

| | Current Practices | | Quantity (dry U.S. tons/year) | Proposed Practices | |
|---|--------------------------------|-----------|----------------------------------|--------------------------------|-----------|
| | Approved by ADEM <u>Yes</u> | <u>No</u> | | Approved by ADEM <u>Yes</u> | <u>No</u> |
| a. Land Application, Bulk Shipped | | | 4111 | | |
| Agriculture | | | | | |
| Forest | | | | | |
| Public Contact | | | | | |
| Lawn/Home Garden | | | | | |
| b. Land Application, Bagged/Other Container | | | | | |
| Agriculture | | | | | |
| Forest | | | | | |
| Public Contact | | | | | |
| Lawn/Home Garden | | | | | |
| c. Incineration | | | | | |
| d. Subtitle D Landfill (Disposal Only) | | | | | |
| e. Lined Treatment Lagoon or Stabilization Pond | | | | | |
| f. Unlined Lagoon or Stabilization Pond | | | | | |
| g. Other (Please Describe) | | | | | |
| _____ | | | | | |
| _____ | | | | | |
| _____ | | | | | |

2. If "f" was selected above and sludge is stored for 2 or more years, enter the distance between the surface disposal site and the property line: NA feet

Pollutant Concentrations

1. Enter the total concentrations of the following analytes using existing data. Do not enter TCLP results.

| Analyte | Concentration (mg/kg or ppm) | Sample Type | Sample Date | Detection Level of Analysis |
|-------------------------|------------------------------|-------------|----------------|-----------------------------|
| Arsenic | <PQL | Grab | Yearly Average | 11 |
| Cadmium | <PQL | Grab | Yearly Average | 8.0 |
| Chromium | 48 | Grab | Yearly Average | 8.0 |
| Copper | 450 | Grab | Yearly Average | 8.0 |
| Lead | 40 | Grab | Yearly Average | 15 |
| Mercury | 1.3 | Grab | Yearly Average | 0.6 |
| Molybdenum | 11 | Grab | Yearly Average | 5.0 |
| Nickel | 37 | Grab | Yearly Average | 6.0 |
| Selenium | <PQL | Grab | Yearly Average | 15 |
| Zinc | 1280 | Grab | Yearly Average | 18 |
| Ammonium-Nitrogen | | | | |
| Nitrate-Nitrogen | | | | |
| Total Kjeldahl Nitrogen | 37,167 | Grab | Yearly Average | |

2. Enter the estimated or determined percent solids of the sewage sludge when sampled for the above analysis: 19 %

Treatment Provided for Sewage Sludge at the Facility

1. Which class of pathogen reduction does the sewage sludge meet at the facility? (As defined in 40 CFR Part 503)

Class A

Alternative A1 - Time and Temperature

Alternative A2 - Alkaline Treatment

Alternative A3 - Analysis and Operation

Alternative A4 - Analysis Only

Alternative A5 - Processes to Further Reduce Pathogens (PFRP)

Heat Drying

Thermophilic Aerobic Digestion

Heat Treatment

Pasteurization

Gamma Ray Irradiation

Beta Ray Irradiation

Composting

Alternative A6 - PFRP Equivalent

Class B

Alternative B1 - Fecal Coliform Count

Alternative B2 - Process to Significantly Reduce Pathogens (PSRP)

Aerobic Digestion

Air Drying

Anaerobic Digestion

Composting

Lime Stabilization

Alternative B3 - PSRP Equivalent

Neither or Unknown

Vector Attraction Control

- Option 1 - Minimum 38% Reduction in Volatile Solids
- Option 2 - Anaerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 3 - Aerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 4 - Specific Oxygen Uptake Rate (SOUR) for Aerobically Digested Sludge
- Option 5 - Aerobic Processes plus Elevated Temperature
- Option 6 - Raised pH to 12 and Retained at 11.5
- Option 7 - 75% Solids with no Unstabilized Solids
- Option 8 - 90% Solids with Unstabilized Solids
- Option 9 - Injection Below Land Surface
- Option 10 - Incorporation into Soil within 6 or 8 Hours
- Option 11 - Covering Active Sewage Sludge Unit Daily
- None of the Above

Groundwater Monitoring

1. If disposal practice is surface disposal or land application, is groundwater monitoring required or performed at the site?

- Yes
 - No
- (If yes, please submit a copy of the groundwater monitoring reports along with this survey. Also please provide the approximate depth to groundwater and the groundwater monitoring procedures used to obtain the data.)

Land Application of Sewage Sludge

Answer the following questions if sewage sludge is applied to land.

1. If sewage sludge is land applied in bulk form, what type of crop or other vegetation is grown on this site?

Tifton Bermuda Grass and Ryegrass

2. If sewage sludge is land applied in bulk form, what is the nitrogen requirement for this crop or vegetation?

600 lbs/acre/year (reclamation site)

3. If sewage sludge is land applied in bulk form, briefly describe the nature of any complaints filed from neighbors?

No complaints have been received

Note: Permittees that submitted the "Annual Report Review Form" for sludge to the EPA may submit a copy with the MWPP in lieu of this Attachment.

Valley Creek Wastewater Treatment Plant
ATTACHMENT 4 – Plant and Collection System
Personnel Inventory



PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Valley Creek WWTP

PLANT GRADE: IV

PERMIT NUMBER: AL0023655

PLANT SUPERINTENDENT: Robby Bennett

TEL. # (205) 428-2614

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|------------------|----------------------------|--------------|------------|
| 1. | Robby Bennett | IV | C001594 | 9/30/2015 |
| 2. | David Humphryes | IV | C000819 | 12/31/2014 |
| 3. | Luelliot Maneice | IV | C000819 | 8/31/2015 |
| 4. | Kevin Waters | IV | C002962 | 11/30/2015 |
| 5. | Warren Gooden | IV | C000519 | 3/31/2015 |
| 6. | Glenda Waldrop | IV | C003017 | 11/30/2015 |
| 7. | Brigitte Akins | IV | C001557 | 11/30/2015 |
| 8. | Jason Bates | IV | C006032 | 11/30/2014 |
| 9. | Warren Burns | IV | C006163 | 5/31/2014 |
| 10. | Larry Cleckler | IV | C002038 | 11/30/2015 |

COLLECTION SYSTEM OPERATORS:

| | | | |
|----|--|--|--|
| 1. | | | |
| 2. | | | |
| 3. | | | |
| 4. | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | 240 | 6 |
| OPERATOR(S): | | |
| GRADE I-C | 160 | 4 |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | 720 | 18 |
| DESIGNATED TRAINEE(S) | 760 | 19 |
| LABORATORY | 40 | 1 |
| MAINTENANCE | 320 | 8 |
| OTHER PLANT WORKERS | 40 | 1 |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | |
|-----|----|
| 1ST | 4 |
| 2ND | 27 |
| 3RD | 5 |

| | |
|------------|------|
| START TIME | 0 |
| | 800 |
| | 1600 |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | X | X | X | X | X | X | X |
| 2ND | X | X | X | X | X | X | X |
| 3RD | X | X | X | X | X | X | X |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|--------------------------|--------------------------|
| <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> |

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Valley Creek WWTP

PLANT GRADE: IV

PERMIT NUMBER: AL0023655

PLANT SUPERINTENDENT: Robby Bennett

TEL. # (205) 428-2614

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|----------------|----------------------------|--------------|------------|
| 1. | William Doss | IV | C005868 | 5/30/2013 |
| 2. | Michael Gaines | IV | C000725 | 11/30/2015 |
| 3. | Mary Hardisty | IV | C000374 | 8/31/2016 |
| 4. | Heath Hinch | IV | C001149 | 8/31/2016 |
| 5. | Robert Myers | IV | C005721 | 9/30/2014 |
| 6. | Neal Poole | IV | C006958 | 7/31/2014 |
| 7. | James Rogers | IV | C002364 | 11/30/2015 |
| 8. | Joel Waldrop | IV | C003020 | 11/30/2015 |
| 9. | | Trainee | | |
| 10. | Kenneth Bush | Trainee | | |

COLLECTION SYSTEM OPERATORS:

| | | | | |
|----|--|--|--|--|
| 1. | | | | |
| 2. | | | | |
| 3. | | | | |
| 4. | | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | 240 | 6 |
| OPERATOR(S): | | |
| GRADE I-C | 160 | 4 |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | 720 | 18 |
| DESIGNATED TRAINEE(S) | 760 | 19 |
| LABORATORY | 40 | 1 |
| MAINTENANCE | 320 | 8 |
| OTHER PLANT WORKERS | 40 | 1 |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | |
|-----|----|
| 1ST | 4 |
| 2ND | 27 |
| 3RD | 5 |

| | |
|------------|------|
| START TIME | 0 |
| | 800 |
| | 1600 |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | X | X | X | X | X | X | X |
| 2ND | X | X | X | X | X | X | X |
| 3RD | X | X | X | X | X | X | X |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|-----|----|
| | |

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Valley Creek WWTP

PLANT GRADE: IV

PERMIT NUMBER: AL0023655

PLANT SUPERINTENDENT: Robby Bennett

TEL. # (205) 428-2614

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|-----------------|----------------------------|--------------|-----------|
| 1. | Doug Carter | Trainee | | |
| 2. | Ed Crumley | Trainee | | |
| 3. | John Ellard | Trainee | | |
| 4. | Keith Frederick | Trainee | | |
| 5. | Malcolm Glass | Trainee | | |
| 6. | Earl Harper | Trainee | | |
| 7. | Jeff Hill | Trainee | | |
| 8. | Danny Hill | Trainee | | |
| 9. | Joshua Hughes | Trainee | | |
| 10. | Donald Kelly | Trainee | | |

COLLECTION SYSTEM OPERATORS:

| | | | | |
|----|--|--|--|--|
| 1. | | | | |
| 2. | | | | |
| 3. | | | | |
| 4. | | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | 240 | 6 |
| OPERATOR(S): | | |
| GRADE I-C | 160 | 4 |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | 720 | 18 |
| DESIGNATED TRAINEE(S) | 760 | 19 |
| LABORATORY | 40 | 1 |
| MAINTENANCE | 320 | 8 |
| OTHER PLANT WORKERS | 40 | 1 |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | |
|-----|----|
| 1ST | 4 |
| 2ND | 27 |
| 3RD | 5 |

| | |
|------------|------|
| START TIME | 0 |
| | 800 |
| | 1600 |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | X | X | X | X | X | X | X |
| 2ND | X | X | X | X | X | X | X |
| 3RD | X | X | X | X | X | X | X |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|-----|----|
| | |

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Valley Creek WWTP

PLANT GRADE: IV

PERMIT NUMBER: AL0023655

PLANT SUPERINTENDENT: Robby Bennett

TEL. # (205) 428-2614

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|----------------|----------------------------|--------------|-----------|
| 1. | Vince Leroy | Trainee | | |
| 2. | Herman McClain | Trainee | | |
| 3. | Percy Mims | Trainee | | |
| 4. | Emma Pleasant | Trainee | | |
| 5. | John Rockett | Trainee | | |
| 6. | Belinda Sexton | Trainee | | |
| 7. | Jason Sims | Trainee | | |
| 8. | | | | |
| 9. | | | | |
| 10. | | | | |

COLLECTION SYSTEM OPERATORS:

| | | | | |
|----|----------------|-------|---------|------------|
| 1. | Brian Champion | I (c) | C002094 | 6/30/2015 |
| 2. | Don Goodwin | I (c) | C005423 | 6/30/2015 |
| 3. | Lavon Evans | I (c) | C004631 | 12/31/2014 |
| 4. | Brian Rohling | I (c) | C005418 | 6/30/2015 |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | 240 | 6 |
| OPERATOR(S): | | |
| GRADE I-C | 160 | 4 |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | 720 | 18 |
| DESIGNATED TRAINEE(S) | 760 | 19 |
| LABORATORY | 40 | 1 |
| MAINTENANCE | 320 | 8 |
| OTHER PLANT WORKERS | 40 | 1 |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | |
|-----|----|
| 1ST | 4 |
| 2ND | 27 |
| 3RD | 5 |

| | |
|------------|------|
| START TIME | 0 |
| | 800 |
| | 1600 |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | X | X | X | X | X | X | X |
| 2ND | X | X | X | X | X | X | X |
| 3RD | X | X | X | X | X | X | X |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|--------------------------|--------------------------|
| <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> |

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Sewer Line Maintenance

PLANT GRADE: IV

PERMIT NUMBER: _____

PLANT SUPERINTENDENT: _____

TEL. # (205) 540-7585

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|----------------|----------------------------|--------------|------------|
| 1. | Brian Champion | I (c) | C002094 | 6/30/2015 |
| 2. | Don Goodwin | I (c) | C005423 | 6/30/2015 |
| 3. | Lavon Evans | I (c) | C004631 | 12/31/2014 |
| 4. | Brian Rohling | I (c) | C005418 | 6/30/2015 |
| 5. | | | | |
| 6. | | | | |
| 7. | | | | |
| 8. | | | | |
| 9. | | | | |
| 10. | | | | |

COLLECTION SYSTEM OPERATORS:

| | | | | |
|----|--|--|--|--|
| 1. | | | | |
| 2. | | | | |
| 3. | | | | |
| 4. | | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | | |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | | |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | | |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | | | |
|-----|----------------------|------------|----------------------|
| 1ST | <input type="text"/> | START TIME | <input type="text"/> |
| 2ND | <input type="text"/> | | <input type="text"/> |
| 3RD | <input type="text"/> | | <input type="text"/> |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| 1ST | <input type="text"/> | <input type="text"/> | <input type="text"/> | <input type="text"/> | <input type="text"/> | <input type="text"/> | <input type="text"/> |
| 2ND | <input type="text"/> | <input type="text"/> | <input type="text"/> | <input type="text"/> | <input type="text"/> | <input type="text"/> | <input type="text"/> |
| 3RD | <input type="text"/> | <input type="text"/> | <input type="text"/> | <input type="text"/> | <input type="text"/> | <input type="text"/> | <input type="text"/> |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|--------------------------|--------------------------|
| <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> |

**Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013**

For the

Village Creek WWTP

as required by the
Alabama Department of Environmental Management NPDES Program



Prepared by
Jefferson County Commission
Environmental Services Department

May 31, 2014

JEFFERSON COUNTY COMMISSION



DAVID CARRINGTON - PRESIDENT
GEORGE F. BOWMAN
SANDRA LITTLE BROWN - PRESIDENT PRO TEMPORE
T. JOE KNIGHT
JAMES A. "JIMMIE" STEPHENS

May 31, 2014

Mr. Nic Caraway
Alabama Department of Environmental Management
Water Division – Municipal Branch
P.O. Box 301463
Montgomery, AL 36130-1463

RE: Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013

Mr. Caraway:

The Jefferson County Environmental Services Department submits the above referenced report for the Village Creek Wastewater Treatment Facility, NPDES Permit No. AL0023647. Included is information as required in ADEM Form 41701/06ml, bypass/overflow event reports, MWPP Sewage Sludge Survey, and the Plant & Collection System Personnel Inventory.

If you have any questions regarding this information, please contact me at 205.325.5979 or Celeste Brown at Jefferson County Barton Laboratory at 205.238.3859.

Sincerely,

David Denard, Director
Environmental Services Department

pc: Celeste Brown, JCESD Barton Laboratory
Daniel White, JCESD Deputy Director
Greg James, Village Creek WWTP

DAVID CARRINGTON – COMMISSIONER
ENVIRONMENTAL SERVICES

TONY PETELOS, COUNTY MANAGER

Office of

DAVID DENARD
Director of Environmental Services
Suite A-300
716 Richard Arrington, Jr. Blvd. N.
Birmingham, Alabama 35203
Telephone (205) 325-5496
Fax (205) 325-5981

**MUNICIPAL WATER POLLUTION PREVENTION (MWPP)
ANNUAL REPORT**

SUBMITTED BY:

TREATMENT FACILITY: Village Creek WWTP NPDES #: AL0023647

MUNICIPALITY: Jefferson County COUNTY: Jefferson

CONTACT PERSON: David Denard
Municipal Official

Director, Environmental Services Department

Title

Telephone #: 205-327-8232 Fax #: 205-325-5981

Email Address: denaradd@jccal.org

CHIEF OPERATOR: Greg James
Name

Telephone #: 205-791-6405 Fax #: 205-791-3030

Email Address: jamesgr@jccal.org

Date: May 14, 2014

REVIEWED BY: Daniel White P.E., ESD Engineer
Consulting Engineer

Telephone #: 205-214-8610 Fax #: 205-325-5239

Date: May 14, 2014

**MWPP Annual Report
Information Source List**

The following information will be needed to complete the compliance maintenance report that covers the calendar year of 2013 (due **May 31,** 2014).

- Part 1 A. The average plant influent flow for each month (million gallons per day/MGD) during the year.
B. The average plant influent BOD (CBOD) for each month (mg/l and lb/day) in the year.
C. The plant's average design flow (MGD) and design BOD loading (lbs/day).
- Part 2 A. The monthly average permit and DMR effluent concentration for BOD (CBOD), TSS, NH3-N, and/or TKN in mg/l for the year
B. The monthly average effluent limits and DMR loading for BOD, TSS, NH3-N, and/or TKN in lbs/day for the year
- Part 3 The age of the treatment plant defined as the number of years since the last major reconstruction to increase the organic or hydraulic capacity of the plant. The last calendar year minus the year the new construction was brought on-line.
- Part 4 Bypass and overflow information. This is the number of bypass or overflow events of untreated wastewater due to heavy rain or equipment failure whether intentional or inadvertent from all collection systems tributary to the treatment facility.
- Part 5 A. Describe the characteristics and quantity of sludge generated.
B. If sludge is landspread, how many months of sludge storage does the plant have? This should include on-site and off-site storage from the treatment plant. The digester capacity may be used in the calculation.
- Part 6 A. Sludge Disposal Method
B. The number of approved land disposal sites for sludge available, and how many months or years these disposal sites will these be available for use.
- Part 7 The number of sewer extensions installed in the community last year--the design population, design flow, and design BOD for each sewer extension.
- Part 8 Operator Certification
- Part 9 Financial Status
- Part 10 Subjective Evaluation
- Part 11 Summary Sheet

Instructions to the Operator-in-Charge

1. Complete all sections of the MWPP Report to the best of your ability.
2. Parts 1 through 8 contain questions for which points will be generated. These points are intended to communicate to the Department and the governing body or owner the actions necessary to prevent effluent violations. Enter the point totals from Parts 1 through 8 on Part 11: Summary Sheet.
3. Add the point totals on Part 11: Summary Sheet.
4. Submit the MWPP Report to the governing body and the consulting engineer and owner for review and approval.
5. The governing body should pass a resolution which contains the following points:
 - a. The resolution should acknowledge the governing body or owner has reviewed the MWPP Report.
 - b. The resolution should indicate what actions will be taken to prevent effluent violations.
 - c. The resolution should provide any other information the governing body or owner deems appropriate.
6. **The MWPP Report and the resolution must be submitted by May 31st to Municipal Section, Water Division, ADEM, P.O. Box 301463, Montgomery, AL 36130-1463.**

Facility Name: Village Creek WWTP

Part 1: Influent Loading/Flows

A. List the average monthly volumetric flows and BOD₅ (CBOD₅) loadings received at your facility during the last calendar year.

| <u>Month</u> | <u>Column 1</u> <u>Average</u> <u>Monthly</u> <u>Flowrate</u> <u>(MGD)</u> | | <u>Column 2</u> <u>Average Monthly</u> <u>BOD₅ (CBOD₅)</u> <u>Concentration</u> <u>(mg/l)</u> | | <u>Column 3</u> <u>Average</u> <u>Loading BOD₅</u> <u>(CBOD₅)</u> <u>(lbs/day)**</u> | |
|--------------------|--|------------|---|----|--|------|
| | <u>001</u> | <u>602</u> | | | | |
| January | 33 | 25 | 37 | 18 | 8548 | 3773 |
| February | 34 | 25 | 33 | 15 | 8850 | 3382 |
| March | 23 | 18 | 48 | 27 | 7420 | 4166 |
| April | 21 | 17 | 35 | 25 | 5928 | 3877 |
| May | 24 | 15 | 59 | 22 | 8616 | 2659 |
| June | 28 | 12 | 72 | 26 | 16830 | 2746 |
| July | 20 | 12 | 58 | 24 | 10691 | 2514 |
| August | 22 | 8.3 | 53 | 17 | 10003 | 1240 |
| September | 19 | 8.7 | 78 | 46 | 12244 | 3456 |
| October | 17 | 8.5 | 110 | 56 | 15441 | 4222 |
| November | 18 | 9.9 | 110 | 57 | 15305 | 4855 |
| December | 24 | 15 | 41 | 19 | 6862 | 2757 |
| Annual Avg. | 24 | 14 | 61 | 29 | 10562 | 3304 |

**As reported on NPDES Discharge Monitoring Reports (DMRs) and as required by EPA's NPDES Self-Monitoring System, User Guide, March 1985.

B. List the average design flow and average design BOD₅ loading for the facility below. If you are not aware of these design quantities, contact your consulting engineer or the Alabama Department of Environmental Management.

| | <u>Average Design Flow</u> | | <u>Average Design</u> <u>BOD₅ Loading (lbs/day)</u> | |
|----------------------------|----------------------------|------|---|-------|
| Design Criteria | 60.0 | 60.0 | 70056 | 70056 |
| 90% of the Design Criteria | 54.0 | 54.0 | 63050 | 63050 |

- C. How many times did the monthly flow (Column 1) to the WWTP exceed 90% of design flow?
 _____ (Check the appropriate point total)
 0 - 4 = 0 points 5 or more = 5 points
- D. How many times did the monthly flow (Column 1) to the WWTP exceed the design flow?
 _____ (Check the appropriate point total)
 0 = 0 points 1 - 2 = 5 points 3 - 4 = 10 points 5 or more = 15 points
- E. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed 90% of the design loading? _____ (Check the appropriate point total)
 0 - 1 = 0 points 2 - 4 = 5 points 5 or more = 10 points
- F. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed the design loading? _____ (Check the appropriate point total)
 0 = 0 points 1 = 10 points 2 = 20 points 3 = 30 points 4 = 40 points 5 or more = 50 points
- G. Enter each point value marked for C through F and enter the sum in the appropriate blank below.

C points = 0

D points = 0

E points = 0

F points = 0

TOTAL POINTS VALUE OR PART 1 0
 Enter this value on Part 11: Summary Sheet.

*To obtain equivalent BOD₅ loading for comparison with design loading for those permittees using influent CBOD₅, divide annual average CBOD₅, loading in lbs/day from Part 1, A by 0.7.

Facility Name: Village Creek WWTP

Part 2: Effluent Quality/Plant Performance

A. List the monthly average permit limits for the facility in the blanks below and the average monthly effluent DMR BOD₅, (CBOD₅) TSS, NH₃-N and/or TKN concentration produced by the facility during the last calendar year.

(1) NPDES Permit Concentration

| Permit Limit | Months | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------|----------|--|---------------|------------------------------|---------------|
| | May-Nov. | 4.0 | 24.0 | 1.0 | Report |
| Dec. -Apr. | 6.0 | 24.0 | 1.0 | Report | |

(2) DMR Concentration

| Qtr | Month | BOD ₅ (CBOD ₅) (mg/l) | | TSS (mg/l) | | NH ₃ -N (mg/l) | | TKN (mg/l) | |
|-----|--------------------|--|---------|---------------|------|------------------------------|-------|---------------|-------|
| | | 1 | January | 0.95 | 0.56 | 1.5 | 0.67 | 0.01 | 0.003 |
| | February | 1.0 | 0.58 | 1.5 | 0.33 | 0.01 | 0.00 | 0.51 | 0.25 |
| | March | 0.95 | 0.70 | 1.9 | 0.40 | 0.02 | 0.002 | 0.47 | 0.30 |
| 2 | April | 0.66 | 0.57 | 2.2 | 0.57 | 0.01 | 0.01 | 0.56 | 0.19 |
| | May | 0.55 | 0.51 | 3.0 | 0.94 | 0.01 | 0.01 | 0.71 | 0.32 |
| | June | 0.84 | 0.46 | 2.5 | 0.79 | 0.02 | 0.02 | 0.45 | 0.40 |
| 3 | July | 0.83 | 0.64 | 2.4 | 0.46 | 0.05 | 0.08 | 0.26 | 0.19 |
| | August | 0.68 | 0.56 | 2.0 | 0.31 | 0.01 | 0.004 | 1.00 | 0.3 |
| | September | 0.79 | 0.46 | 2.2 | 0.39 | 0.08 | 0.08 | 0.85 | 0.37 |
| 4 | October | 0.95 | 0.49 | 2.0 | 0.67 | 0.05 | 0.04 | 0.76 | 0.41 |
| | November | 1.2 | 1.1 | 2.9 | 1.3 | 0.03 | 0.01 | 1.10 | 0.4 |
| | December | 0.93 | 0.65 | 2.2 | 0.56 | 0.03 | 0.03 | 0.42 | 0.22 |
| | Annual Avg. | 0.86 | 0.61 | 2.2 | 0.61 | 0.03 | 0.02 | 0.64 | 0.29 |

B. List the monthly average permit limit and DMR loadings below.

(1) NPDES Permit Loading

| Permit Limit | Months | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|-----------------|----------|---|------------------|---------------------------------|------------------|
| | May-Nov. | 2001 | 12009 | 500 | Report |
| Dec.-Apr. | 3002 | 12009 | 500 | Report | |

(2) DMR Loading

| Qtr | Month | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|--------------------|-----------|---|------------------|---------------------------------|------------------|
| 1 | January | 389 | 648 | 3.2 | 419 |
| | February | 424 | 462 | 2.2 | 133 |
| | March | 288 | 537 | 2.8 | 81 |
| 2 | April | 197 | 438 | 2.8 | 101 |
| | May | 153 | 620 | 1.9 | 140 |
| | June | 244 | 690 | 7.1 | 215 |
| 3 | July | 220 | 495 | 17.2 | 56 |
| | August | 163 | 397 | 1.7 | 178 |
| | September | 166 | 397 | 18.6 | 156 |
| 4 | October | 170 | 330 | 10.1 | 134 |
| | November | 313 | 607 | 6.0 | 162 |
| | December | 280 | 548 | 11.3 | 94 |
| Annual Avg. | | 251 | 514 | 7.1 | 156 |

C. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

D. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

E. During the past year did the effluent TSS concentration (mg/l) or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

F. During the past year did the TSS concentration (mg/l) and/or loading (lbs/day) exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

G. During the past year did the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

H. During the past year did either the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

I. Enter each point value checked for C through H in the blanks below.

C Points = 0

D Points = 0

E Points = 0

F Points = 0

G Points = 0

H Points = 0

HIGHEST INDIVIDUAL POINT VALUE FOR PART 2 (C-H) 0 (HIGHEST POINT = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Village Creek WWTP

Part 4: Bypassing and Overflows

- A. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to heavy rain? 0
- B. How many bypass or overflow events of untreated wastewater occurred in the last year prior to the headworks of the WWTP due to heavy rain? 2
- C. How many of the bypass or overflow events listed in Parts A and B have been corrected such that future bypass or overflow events at the same location due to heavy rain are not anticipated? 2
- D. Add together Answers A and B and subtract Answer C from that total.
A + B - C = _____ (Check the appropriate point total.)
 0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points
- E. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to equipment failure? (This includes clogged/broken lines or manholes.) 0
- F. How many bypass or overflow events of untreated wastewater occurred in the last year due to equipment failure prior to the headworks of the WWTP? (This includes clogged/broken lines or manholes.) 40
- G. How many of the bypass or overflow events listed in Parts E and F have been corrected such that future bypass or overflow events at the same location due to the same equipment failure are not anticipated? 40
- H. Add together Answers E and F and subtract Answer G from that total.
E + F - G = _____ (Check the appropriate point total.)
 0 = 0 points 1 = 5 points 2 = 10 points 3 = 15 points 4 = 20 points 5 = 25 points 6 = 30 points
7 = 35 points 8 = 40 points 9 = 45 points 10 = 50 points 11 or more = 100 points
- I. Add point values circled in D and H and enter the total in the blank below.

TOTAL POINT VALUE FOR PART 4 10

Enter this value on Part 11: Summary Sheet.

All bypass or overflow events that have occurred in the last year (for any reason) must be individually reported with this MWPP report.

Facility Name: Village Creek WWTP

Part 5: Sludge Quantity and Storage

- A. Please provide information concerning sludge quantity, characteristics, and storage practices based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months of sludge storage capacity does the wastewater treatment facility have available, either on-site or off-site? (i.e., How many months can the facility operate without land spreading or disposing of sludge?) >4

(Check the appropriate point total.)

- | | | |
|---|-------------|-------------------------------------|
| Greater than or equal to 4 months | = 0 points | <input checked="" type="checkbox"/> |
| Less than 4 months, but greater than or equal to 3 months | = 10 points | <input type="checkbox"/> |
| Less than 3 months, but greater than or equal to 2 months | = 20 points | <input type="checkbox"/> |
| Less than 2 months, but greater than or equal to 1 month | = 30 points | <input type="checkbox"/> |
| Less than one month | = 50 points | <input type="checkbox"/> |

TOTAL POINT VALUE FOR PART 5 0

Enter this value on Part 11: Summary Sheet.

Part 6: Sludge Disposal Practices and Sites

- A. Please provide the sludge disposal practices and site information based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months or years does the facility have access to and approval for sufficient land disposal sites to provide proper land disposal? (Check the appropriate point total.)

- | | | |
|--------------------|-------------|-------------------------------------|
| 36 or more months | = 0 points | <input type="checkbox"/> |
| 24 - 35 months | = 10 points | <input type="checkbox"/> |
| 12 - 23 months | = 20 points | <input checked="" type="checkbox"/> |
| 6 - 11 months | = 30 points | <input type="checkbox"/> |
| Less than 6 months | = 50 points | <input type="checkbox"/> |

TOTAL POINT VALUE FOR PART 6 20

Enter this value on Part 11: Summary Sheet.

Facility Name: Village Creek WWTP

Part 7: New Development

Are there any major new developments (industrial, commercial, or residential) in the last calendar year or anticipated in the next 2-3 years such that either flow or BOD₅ loadings to the sewage system could significantly increase? Estimate additional loadings below.

Design Population: _____
Equivalent (PE)

Design Flow: _____ MGD

Design BOD₅: _____ lbs/day

List industrial and/or residential developments.

No major new developments planned.

Will the additional loading overload the plant? (Check the appropriate point total.)

No = 0 points Yes = 121 points

Enter the point total in the blank below.

TOTAL POINT VALUE FOR PART 7 ⁰ _____ (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Part 8: Operator Certification

Complete the *Plant and Collection System Personnel Inventory*, ADEM Form 441.

Do both the plant operator and collection system staffing comply with ADEM Administrative Code; Division 10, Operator Certification Program? (Check the appropriate point total.)

Yes = 0 points No = 121 points

TOTAL POINT VALUE FOR PART 8 ⁰ _____ (highest point total = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Village Creek WWTP

Part 9: Financial Status

A. Are User-Charge Revenues sufficient to cover operation and maintenance expenses? If no, how are O&M costs being financed? ***Include user charge rates.***

Revenues are sufficient. The below values are based on a 5/8" meter and 6,000 gallons water use. Jefferson

County has a three tier block rate structure for residential users for 0-3, 4-6, and 7+ ccf water use.

Residential Minimum 15.00 Plus rate 6.02; 9.36; 10.69 /1,000 gal.

Industrial Minimum 15.00 Plus rate 10.51 /1,000 gal.

Monthly residential rate based on 6,000 gallons usage \$ 56.04 (includes 15% credit for residential)

****Please complete the above information based on your user charge rates for the report year. You may attach a sample water and sewer bill for clarity.***

B. What financial resources are available to pay for the wastewater improvements and/or reconstruction needs?

In 2013, Jefferson County issued Series 2013 Sewer Warrants that fund capital improvements

through 2023 at an annual average rate of \$71.9 million over the 10-year period.

Part 10: Subjective Evaluation

A. Describe briefly the physical and structural conditions of the wastewater treatment facility.

The 002 WWTP was constructed in 2004 and is in good condition. Some equipment and processes

were constructed or upgraded in the 1970s, 80s, and 90s and are in fair to average condition.

Maintenance and refurbishments are planned for assets needing improvements.

B. Describe the general condition of the sewer system (sewer lines, manholes, lift stations).

The Village system includes roughly 3,460,000' of pipe and 24 pump stations. The system's rate of

SSO's/100 miles of sewer is above the department's goal. There are no known capacity deficiencies.

The general condition of the system is fair.

C. What sewage system improvements does the community have planned for construction in the next 5 years?

Construction work began in October 2013 to rehab 001 Plant bar screens , final settling tanks, dewatering building improvements, and 002 plant U.V. disinfection system upgrades. This project will end in October 2014. See attachment for additional planned work..

D. What is the theoretical design life of the plant, and what is the estimated remaining useful life of the wastewater treatment facility?

Calculated remaining useful life of the structures is 50 years - years age of facility.
Calculated remaining useful life of the equipment is 25 years - years age of equipment.
Based on EPA's 2002 Clean Water and Drinking Water Infrastructure Gap Analysis Report.

E. What problems, if any, over the last year have threatened treatment or conveyance within the system?

The primary cause of SSO's was blockage from grease. These occurred in residential areas.

F. Is the community presently involved in formal planning for treatment facility upgrading?

No.

G. How many days in the last year were there residential backups at any point in the collection system for any reason other than clogging of the lateral connection? 16

H. Does the plant have a written plan for preventive maintenance on major equipment items? If yes, describe.

Yes. O & M Manuals are used for all equipment maintenance schedules. Preventive maintenance schedules are input into the INFOR maintenance system and PM work orders are automatically generated. All equipment PM schedules and records are maintained in the INFOR system.

Village Creek

Part 10.C

Planned improvements at the Fairmont and Harrimon pump stations include wetwell rehabilitation, increased pumping capacity, piping repairs, updated electrical components and control panels. Pump replacement is planned for the Lewisburg #1 pump station.

I. Does this preventive maintenance program depict frequency of intervals, types of lubrication, and other preventive maintenance tasks necessary for each piece of equipment? (Check the appropriate response.) Yes No

J. Are these preventive maintenance tasks, as well as equipment problems, being recorded and filed so future maintenance problems can be assessed properly? (Check the appropriate response.) Yes No

K. Describe any major repairs or mechanical equipment replacement made in the last year and include the approximate cost for those repairs. Do not include major treatment plant construction or upgrading programs.

Rebuild of Dewatering cake pumps - \$299,760

Lightning Protection for emergency generators- \$31,368

Generator Controls Upgrade - \$28,125

L. List any additional comments. (Attach additional sheets if necessary.)

Facility Name: Village Creek WWTP

Part 11: Summary Sheet

1. Enter in the values from Parts 1 through 8 in the left column below. Add the numbers in the left column to determine the MWPP Report point total the wastewater system generated for the previous calendar year.

| <u>Actual Values</u> | <u>Maximum Possible</u> |
|-------------------------|-------------------------|
| Part 1 <u>0</u> points | 80 points |
| Part 2 <u>0</u> points | 121 points |
| Part 3 <u>18</u> points | 40 points |
| Part 4 <u>10</u> points | 200 points |
| Part 5 <u>0</u> points | 50 points |
| Part 6 <u>20</u> points | 50 points |
| Part 7 <u>0</u> points | 121 points |
| Part 8 <u>0</u> points | 121 points |
| Total <u>48</u> points | 783 points |

2. Check the facility type that best describes the plant's treatment and disposal of wastewater.

- Mechanical plant with surface water discharge
- Aerated Lagoon or stabilization pond with surface water discharge
- Mechanical plant using land disposal of liquid wastes
- Aerated Lagoon or stabilization pond using land disposal of liquid wastes

3. Check the range that describes the action needed to address problems identified in the report.

- 0 - 70 pts. Actions as Appropriate*
- 71 - 120 pts. Departmental Recommendation Range*
- 121 - 783 Municipality Action Range*

***Other actions may be required by NPDES outside the scope of this report.**

4. Complete the *Municipal Water Pollution Prevention Resolution Form*, ADEM Form 418.


5. In Question 1, do any of the actual point values in the left column equal the maximum possible points in the right column? (Check the appropriate response) Yes No

If yes, provide a written explanation for this situation in the space below.

Village Creek Wastewater Treatment Plant
ATTACHMENT 2 – Raw Sewage Bypass and
SUMMARY



VILLAGE CREEK BASIN 2013 DISCHARGES



NOTE: OVERFLOWS SHOWN ARE OVER 10,000 GALLONS.

JEFFERSON COUNTY
ENVIRONMENTAL SERVICES
PLOTTED: 2-11-14



Summary of Unpermitted Discharges - Village Creek

January 01, 2013 through December 31, 2013

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|---|---------------|-----------------------|--|--|-----------------|-----------------------------|--|------------|------------------|------------------|------------------------------|
| C01082 | 6/12/13 | 3999 14th Ave N | Village - East of WWTP | Storm Drain | 9 | Hose on back of Combo Truck | Hose came out of manhole while decanting | No Rain | Closed the Valve | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| C01099 | 10/24/13 | 2430 Minor Parkway | Village - West of WWTP (Remainder of System) | Ground Absorbed/ Corbet Branch | 1,400 | Cleanout for Force Main | Cleanout on Force Main | No Rain | Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes: Maintenance crews clearing ROW broke cleanout with cutting equipment.</i> | | | | | | | | | | | |
| M04312 | 1/4/13 | 1208 Hibernian Street | Village - West of WWTP (Remainder of System) | Ground Absorbed | 367 | Cleanout | Grease/ Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04313 | 1/5/13 | 316 Half Moon Bend | Village - East of WWTP | Ground Absorbed | 5,100 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04323 | 1/14/13 | 4304 43rd Ave N | Village - East of WWTP | Ground Absorbed | 708 | Cleanout | Grease/ Debris | Light Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04326 | 1/14/13 | 43rd St & 38th Ave N | Village - East of WWTP | Storm Drain/ Feeder Creek to Village Creek | 125,112 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-----------|---------------|---------------------|--|-----------------------------------|-----------------|--------------|-------------------------------------|---------------|------------------|------------------|------------------------------|
| M04331 | 1/15/13 | #1 Ave W | Village - West of WWTP (Remainder of System) | Ground Absorbed | 11,952 | Cleanout | Surcharge from Rain | Moderate Rain | Line Monitored | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04332 | 1/16/13 | 8920 Roebuck Blvd | Village - East of WWTP | Ground Absorbed/ Village Creek | 12,206 | Manhole/Pipe | Grease/ Rags/ Gravity Main Break | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04333 | 1/18/13 | 540 Gadsden Hwy | Village - East of WWTP | Ground Absorbed | 160 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04337 | 1/28/13 | 3171 44th Ave N | Village - East of WWTP | Storm Drain | 13,824 | Cleanout | Grease/ Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04354 | 2/13/13 | 500 Oakmont St | Village - West of WWTP (Remainder of System) | Storm Drain | 2,025 | Manhole | Grease/ Rags/ Spray rock | Moderate Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04362 | 2/26/13 | 7 41st St N | Village - East of WWTP | Ground Absorbed | 395 | Drain | Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04365 | 2/26/13 | 912 Five Mile Road | Village - East of WWTP | Ground Absorbed | 12 | Cleanout | Grease/ Roots/ Rags | Light Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04373 | 3/15/13 | 564 Antwerp Court S | Village - East of WWTP | Storm Drain | 1,168 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Rohling | Chief Civil Engineer |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|---------------|---------------|-------------------------|--|----------------------|-----------------|----------|-----------------------------|---------|------------------|------------------|------------------------------|
| M04376 | 3/20/13 | 925 52nd St N | Village - East of WWTP | Ground Absorbed | 2 | Cleanout | Roots | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04382 | 3/25/13 | 2733 16th Court | Village - East of WWTP | Ground Absorbed | 4,075 | Manhole | Grease/ Roots/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04383 | 3/26/13 | 700 8th St S | Village - East of WWTP | Storm Drain | 2,052 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04385 | 4/1/13 | 714 Gene Reed Rd | Village - East of WWTP | Storm Drain | 1,184 | Manhole | Grease/ Roots/ Debris/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04394 | 4/12/13 | 433 Blount St | Village - West of WWTP (Remainder of System) | Ground Absorbed | 144 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04395 | 4/12/13 | 4140 Messer Airport Hwy | Village - East of WWTP | Storm Drain | 1,428 | Manhole | Grease/ Roots/ Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04402 | 4/19/13 | 756 71st Pl S | Village - East of WWTP | Ground Absorbed | 16,856 | Cleanout | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| <i>Notes:</i> | | | | | | | | | | | |
| M04403 | 4/23/13 | 945 Elizabeth Dr | Village - East of WWTP | Ground Absorbed | | Cleanout | Grease/ Roots/ Debris/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |

Notes: Cleanout not overflowing upon crew arrival, but there was evidence on the ground.

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-----------|---------------|--------------------|------------------------|------------------------------|-----------------|----------|-----------------------------|------------|-------------------|------------------|------------------------------|
| M04404 | 4/26/13 | 9248 Brookhurst Dr | Village - East of WWTP | Ground Absorbed | 252 | Cleanout | Grease/ Roots/ Debris/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04405 | 4/29/13 | 600 Biscayne Dr | Village - East of WWTP | Storm Drain | 164 | Cleanout | Roots | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04408 | 5/3/13 | 812 85th St South | Village - East of WWTP | Storm Drain | 13,392 | Cleanout | Grease/ Roots/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04417 | 5/18/13 | 1116 Barnisdale Rd | Village - East of WWTP | Ground Absorbed | 4,018 | Cleanout | Grease | Heavy Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04418 | 5/19/13 | 5712 5th Ct S | Village - East of WWTP | Storm Drain | 38 | Manhole | Grease/ Roots/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04423 | 6/3/13 | 7525 Marks Drive | Village - East of WWTP | Storm Drain | 513 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04431 | 7/9/13 | 7525 Marks Dr | Village - East of WWTP | Storm Drain | 2,430 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04441 | 9/1/13 | 3040 44th Ave N | Village - East of WWTP | Ground Absorbed/ Storm Drain | 6,949 | Manhole | Grease | No Rain | Blockage Repaired | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-----------|---------------|-------------------------|--|---------------------------------|-----------------|----------|------------------------|------------|------------------|------------------|------------------------------|
| M04444 | 9/13/13 | 540 Gadsden Hwy | Village - East of WWTP | Storm Drain | 230 | Manhole | Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04460 | 11/4/13 | 548 & 552 Gadsden Hwy | Village - East of WWTP | Ground Absorbed/ Storm Drain | 232 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04465 | 11/16/13 | 749 71st Pl S | Village - East of WWTP | Storm Drain | 70 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04466 | 11/19/13 | 6421 Joppa Court | Village - East of WWTP | Ground Absorbed | 184 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04468 | 11/22/13 | 1163 6th St W | Village - East of WWTP | Ground Absorbed | 133 | Manhole | Grease/ Rags | Light Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04469 | 11/22/13 | 13 Avenue W | Village - West of WWTP (Remainder of System) | Ground Absorbed | 129 | Cleanout | Grease/ Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04482 | 12/3/13 | 4020 Messer Airport Hwy | Village - East of WWTP | Storm Drain | 115 | Manhole | Grease/ Debris | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04483 | 12/4/13 | 444 23rd Ave | Village - East of WWTP | Ground Absorbed | 270 | Cleanout | Grease/ Rags/ Rocks | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Event No. | Date Reported | Location | Collection System | Ultimate Destination | Est. Vol. (gal) | Source | Cause | Weather | Action Taken | Person Reporting | Title |
|-----------|---------------|---------------------|--|----------------------|-----------------|----------|----------------------------|------------|--------------------------------|------------------|------------------------------|
| M04486 | 12/7/13 | 1009 & 1021 Erie St | Village - West of WWTP (Remainder of System) | Drainage Ditch | 1,152 | Manhole | Grease/ Rags | Light Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04487 | 12/9/13 | 661 Ave W | Village - East of WWTP | Storm Drain | 103 | Manhole | Grease | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04496 | 12/18/13 | 1153 2nd St N | Village - East of WWTP | Drainage Ditch | 294 | Manhole | Grease/ Rags | No Rain | Blockage Removed | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |
| M04497 | 12/18/13 | 444 23rd Ave W | Village - East of WWTP | Storm Drain | 10,200 | Cleanout | Gravity Main Break/ Gravel | No Rain | Blockage Removed/Line Repaired | Brian Champion | Sewer Maintenance Supervisor |
| Notes: | | | | | | | | | | | |

Village Creek Wastewater Treatment Plant

ATTACHMENT 3 – MWPP Sewage Sludge

SURVEY



MWPP SEWAGE SLUDGE SURVEY

Facility Background Information:

1. Facility Information Permit Number: AL0023647

Name: Village Creek WWTP

Street Address: 1440 Pleasant Hill Road

County: Jefferson

2. Facility Contact

Name: Greg James

Title: Plant Manager

Telephone: 205-791-6405

Permittee Name: Jefferson County Commision

Mailing Address: Suite A-300 716 Richard Arrington Jr. Blvd N.
Birmingham, Al 35203

Facility Flow Information

1. Facility Wastewater Treatment Capacity

| | | |
|---------------------------|----------------------------|-----|
| Avg. Daily Flow for 2013: | <u>001-23.6 / 002-14.5</u> | MGD |
| Facility Design Capacity: | <u>001-60 / 002-60</u> | MGD |

2. Estimated Septage Quantity Handled (Residuals Removed from Septic Tank Systems)

| | | |
|-----------------------------|----------------|----------------------------|
| Average Domestic Septage: | <u>245,292</u> | gallons per month |
| Average Commercial Septage: | <u>375,409</u> | gallons per month (GREASE) |

3. Method of Septage Processing

Mixed with Influent Wastewater for Treatment

Mixed with Sewage Sludge

4. Estimated Percentage Contributing Wastewater Flow

| | | |
|--------------|-----------|---|
| Residential: | <u>87</u> | % |
| Industrial: | <u>8</u> | % |
| Other: | <u>5</u> | % |

Describe: Commercial

5. List type of wastewater treatment process(es) utilized at this facility:

Screening, Grit Removal, Acctivated Sludge, Clarification

Chlorination, Dechlorination, Sand filtration, Uv Disinfeciton

6. Estimated sewage sludge wasting rate at this facility: _____ lb/day dry weight
or 144000 gallons per day

7. Estimated untreated sludge received from off site: N/A lb/day dry weight
or _____ gallons per day

8. Estimated percent solids of combined sewage sludge prior to treatment: 3 %

9. List the sewage sludge treatment processes used in preparing sludge for final use or disposal:

| | Sludge Quantity (untreated pounds per day) |
|---|---|
| Gravity Thickening | |
| Mesophyllic Anaerobic Digestion | |
| Mechanical Dewatering (Centrifuge) and Lime Stabilization | |

10. Estimate the total volume of sludge generated:

3,231
 (dry U.S. tons per year)

Sludge Disposal Methods

1. Which of the following describes the current method of sewage sludge disposal for this facility:

| | Current Practices | | | Proposed Practices | |
|--|--------------------------|--------------------------|----------------------------------|--------------------------|--------------------------|
| | Approved by ADEM | | Quantity (dry U.S. tons/year) | Approved by ADEM | |
| | Yes | No | | Yes | No |
| a. <input checked="" type="checkbox"/> Land Application, Bulk Shipped | | | 3,231 | | |
| <input type="checkbox"/> Agriculture | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Forest | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Public Contact | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Lawn/Home Garden | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| b. <input type="checkbox"/> Land Application, Bagged/Other Container | | | | | |
| <input type="checkbox"/> Agriculture | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Forest | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Public Contact | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Lawn/Home Garden | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| c. <input type="checkbox"/> Incineration | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| d. <input type="checkbox"/> Subtitle D Landfill (Disposal Only) | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| e. <input type="checkbox"/> Lined Treatment Lagoon or Stabilization Pond | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| f. <input type="checkbox"/> Unlined Lagoon or Stabilization Pond | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| g. <input type="checkbox"/> Other (Please Describe) | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| _____ | | | | | |
| _____ | | | | | |
| _____ | | | | | |

2. If "f" was selected above and sludge is stored for 2 or more years, enter the distance between the surface disposal site and the property line: N/A feet

Pollutant Concentrations

1. Enter the total concentrations of the following analytes using existing data. Do not enter TCLP results.

| Analyte | Concentration (mg/kg or ppm) | Sample Type | Sample Date | Detection Level of Analysis |
|-------------------------|------------------------------|-------------|----------------|-----------------------------|
| Arsenic | <PQL | Grab | Yearly Average | 11 |
| Cadmium | <PQL | Grab | Yearly Average | 8 |
| Chromium | 39.00 | Grab | Yearly Average | 8 |
| Copper | 400.00 | Grab | Yearly Average | 8 |
| Lead | 55.00 | Grab | Yearly Average | 15 |
| Mercury | 1.90 | Grab | Yearly Average | 0.6 |
| Molybdenum | 8.30 | Grab | Yearly Average | 5 |
| Nickel | 38.00 | Grab | Yearly Average | 6 |
| Selenium | <PQL | Grab | Yearly Average | 15 |
| Zinc | 1,013.00 | Grab | Yearly Average | 18 |
| Ammonium-Nitrogen | N/A | N/A | N/A | N/A |
| Nitrate-Nitrogen | N/A | N/A | N/A | N/A |
| Total Kjeldahl Nitrogen | 14,642.00 | N/A | N/A | N/A |

2. Enter the estimated or determined percent solids of the sewage sludge when sampled for the above analysis: 30 %

Treatment Provided for Sewage Sludge at the Facility

1. Which class of pathogen reduction does the sewage sludge meet at the facility? (As defined in 40 CFR Part 503)

Class A

Alternative A1 - Time and Temperature

Alternative A2 - Alkaline Treatment

Alternative A3 - Analysis and Operation

Alternative A4 - Analysis Only

Alternative A5 - Processes to Further Reduce Pathogens (PFRP)

Heat Drying

Thermophilic Aerobic Digestion

Heat Treatment

Pasteurization

Gamma Ray Irradiation

Beta Ray Irradiation

Composting

Alternative A6 - PFRP Equivalent

Class B

Alternative B1 - Fecal Coliform Count

Alternative B2 - Process to Significantly Reduce Pathogens (PSRP)

Aerobic Digestion

Air Drying

Anaerobic Digestion

Composting

Lime Stabilization

Alternative B3 - PSRP Equivalent

Neither or Unknown

Vector Attraction Control

Option 1 - Minimum 38% Reduction in Volatile Solids

Option 2 - Anaerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction

- Option 3 - Aerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 4 - Specific Oxygen Uptake Rate (SOUR) for Aerobically Digested Sludge
- Option 5 - Aerobic Processes plus Elevated Temperature
- Option 6 - Raised pH to 12 and Retained at 11.5
- Option 7 - 75% Solids with no Unstabilized Solids
- Option 8 - 90% Solids with Unstabilized Solids
- Option 9 - Injection Below Land Surface
- Option 10 - Incorporation into Soil within 6 or 8 Hours
- Option 11 - Covering Active Sewage Sludge Unit Daily
- None of the Above

Groundwater Monitoring

1. If disposal practice is surface disposal or land application, is groundwater monitoring required or performed at the site?

- Yes (If yes, please submit a copy of the groundwater monitoring reports along with this survey. Also please provide the approximate depth to groundwater and the groundwater monitoring procedures used to obtain the data.)
- No

Land Application of Sewage Sludge

Answer the following questions if sewage sludge is applied to land.

1. If sewage sludge is land applied in bulk form, what type of crop or other vegetation is grown on this site?

Tifton Bermuda Grass, Ryegrass

2. If sewage sludge is land applied in bulk form, what is the nitrogen requirement for this crop or vegetation?
600 lbs/acre/year (Reclamation Site)

3. If sewage sludge is land applied in bulk form, briefly describe the nature of any complaints filed from neighbors?

No complaints have been received.

Note: Permittees that submitted the "Annual Report Review Form" for sludge to the EPA may submit a copy with the MWPP in lieu of this Attachment.

Village Creek Wastewater Treatment Plant
ATTACHMENT 4 – Plant and Collection System
Personnel Inventory



PLANT PERSONNEL INVENTORY

FACILITY NAME Village Creek WWTP PLANT GRADE IV
 PERMIT NUMBER AL0023647
 PLANT MANAGER Greg James TEL # 205-791-6405
 DEPARTMENT DIRECTOR David Denard TEL # 205-327-8232
 PLANT OPERATORS:

| | NAME | GRADE | OPERATOR NO. | EXP. DATE |
|----|-------------------|-------|--------------|------------|
| 1 | Gregory James | IV | C000989 | 3/31/2015 |
| 2 | Terrence Lane | IV | C003437 | 3/31/2015 |
| 3 | Frederick Deamues | IV | C001885 | 3/31/2015 |
| 4 | Paul Hardisty | IV | C001001 | 2/28/2015 |
| 5 | Linda Jackson | IV | C000952 | 12/31/2014 |
| 6 | Ryan Tyler | IV | C002923 | 6/30/2015 |
| 7 | Tim Gilliland | IV | C004866 | 9/30/2014 |
| 8 | Corey Bates | IV | C001583 | 2/28/2013 |
| 9 | Rickie Hogeland | IV | C000855 | 11/30/2015 |
| 10 | Orlando Walker | IV | C000536 | 11/30/2015 |
| 11 | Brenda Scott | IV | C002569 | 6/30/2015 |
| 12 | Fred Cooper | IV | C001744 | 11/30/2015 |
| 13 | Kim Passmore | IV | C005368 | 8/31/2013 |

| COLLECTION SYSTEM OPERATORS: | | | |
|------------------------------|----------------|---------|--------------------|
| 1 | Brian Champion | 1 (C) | C002094 6/30/2015 |
| 2 | Don Goodwin | 1 (C) | C005423 6/30/2015 |
| 3 | Lavon Evans | 1 (C) | C004631 12/31/2014 |
| 4 | Brian Rohling | 1 (C) | C005418 6/30/2015 |

| | MAN HRS/WK | NUMBER |
|-----------------------|------------|--------|
| MANAGEMENT/SUPERVISOR | 320 | 8 |
| OPERATORS: | | |
| GRADE IV | 200 | 5 |
| MAINTENANCE | 200 | 7 |
| OTHER PLANT WORKERS | 960 | 22 |

| AVERAGE NUMBER OF EMPLOYEES PER SHIFT: | | START TIME |
|--|----|------------|
| 1ST | 29 | 8:00 AM |
| 2ND | 4 | 4:00 PM |
| 3RD | 4 | 12:00 AM |
| 4th | 4 | 12:00 AM |
| 5gh | 4 | 12:00 PM |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| Shift | Hours | Mon | Tues | Wed | Thu | Fri | Sat | Sun |
|-------|----------------|-----|------|-----|-----|-----|-----|-----|
| 1st | 12 am to 8 am | X | X | X | X | X | | |
| 2nd | 8 am to 4 pm | X | X | X | X | X | | |
| 3rd | 4 pm to 12 am | X | X | X | X | X | | |
| 4th | 12 am to 12 pm | | | | | | X | X |
| 5th | 12 pm to 12 am | | | | | | X | X |

| | YES | NO |
|--|-----|----|
| 1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE? | | |
| 2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE? | | |

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Sewer Line Maintenance

PLANT GRADE: IV

PERMIT NUMBER: _____

PLANT SUPERINTENDENT: _____

TEL. # (205) 540-7585

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|----------------|----------------------------|--------------|------------|
| 1. | Brian Champion | I (c) | C002094 | 6/30/2015 |
| 2. | Don Goodwin | I (c) | C005423 | 6/30/2015 |
| 3. | Lavon Evans | I (c) | C004631 | 12/31/2014 |
| 4. | Brian Rohling | I (c) | C005418 | 6/30/2015 |
| 5. | | | | |
| 6. | | | | |
| 7. | | | | |
| 8. | | | | |
| 9. | | | | |
| 10. | | | | |

COLLECTION SYSTEM OPERATORS:

| | | | | |
|----|--|--|--|--|
| 1. | | | | |
| 2. | | | | |
| 3. | | | | |
| 4. | | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | | |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | | |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | | |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | | | |
|-----|--|------------|--|
| 1ST | <input style="width: 80%;" type="text"/> | START TIME | <input style="width: 80%;" type="text"/> |
| 2ND | <input style="width: 80%;" type="text"/> | | <input style="width: 80%;" type="text"/> |
| 3RD | <input style="width: 80%;" type="text"/> | | <input style="width: 80%;" type="text"/> |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| 1ST | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2ND | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 3RD | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|--------------------------|--------------------------|
| <input type="checkbox"/> | <input type="checkbox"/> |

Municipal Water Pollution Prevention (MWPP) Annual Report Calendar Year 2013

For the

Warrior WWTP

as required by the
Alabama Department of Environmental Management NPDES Program



Prepared by
Jefferson County Commission
Environmental Services Department

May 31, 2014

JEFFERSON COUNTY COMMISSION



DAVID CARRINGTON - PRESIDENT
GEORGE F. BOWMAN
SANDRA LITTLE BROWN - PRESIDENT PRO TEMPORE
T. JOE KNIGHT
JAMES A."JIMMIE" STEPHENS

DAVID CARRINGTON – COMMISSIONER
ENVIRONMENTAL SERVICES

TONY PETELOS, COUNTY MANAGER

Office of

DAVID DENARD
Director of Environmental Services
Suite A-300
716 Richard Arrington, Jr. Blvd. N.
Birmingham, Alabama 35203
Telephone (205) 325-5496
Fax (205) 325-5981

May 31, 2014

Mr. Nic Caraway
Alabama Department of Environmental Management
Water Division – Municipal Branch
P.O. Box 301463
Montgomery, AL 36130-1463

RE: Municipal Water Pollution Prevention (MWPP)
Annual Report Calendar Year 2013

Mr. Caraway:

The Jefferson County Environmental Services Department submits the above referenced report for the Warrior Wastewater Treatment Facility, NPDES Permit No. AL0050881. Included is information as required in ADEM Form 41701/06ml, bypass/overflow event reports, MWPP Sewage Sludge Survey, and the Plant & Collection System Personnel Inventory.

If you have any questions regarding this information, please contact me at 205.325.5979 or Celeste Brown at Jefferson County Barton Laboratory at 205.238.3859.

Sincerely,

David Denard, Director
Environmental Services Department

pc: Celeste Brown, JCESD Barton Laboratory
Daniel White, JCESD Deputy Director
Chad Quick, Warrior WWTP

**MUNICIPAL WATER POLLUTION PREVENTION (MWPP)
ANNUAL REPORT**

SUBMITTED BY:

TREATMENT FACILITY: Warrior WWTP NPDES #: AL0050881

MUNICIPALITY: Jefferson County COUNTY: Jefferson

CONTACT PERSON: David Denard

Municipal Official

Director of Environmental Services

Title

Telephone #: (205)325-5806 Fax #: (205)325-5688

Email Address: denardd@jccal.org

CHIEF OPERATOR: Chad Quick

Name

Telephone #: (205)681-7971 Fax #: (205)680-8139

Email Address: quickc@jccal.org

Date: May 14, 2014

REVIEWED BY: Daniel White P.E. ESD Engineer

Consulting Engineer

Telephone #: (205) 214-8610 Fax #: (205)325-5688

Date: May 14, 2014

**MWPP Annual Report
Information Source List**

The following information will be needed to complete the compliance maintenance report that covers the calendar year of 2013 (due **May 31,** 2014).

- Part 1 A. The average plant influent flow for each month (million gallons per day/MGD) during the year.
B. The average plant influent BOD (CBOD) for each month (mg/l and lb/day) in the year.
C. The plant's average design flow (MGD) and design BOD loading (lbs/day).
- Part 2 A. The monthly average permit and DMR effluent concentration for BOD (CBOD), TSS, NH3-N, and/or TKN in mg/l for the year
B. The monthly average effluent limits and DMR loading for BOD, TSS, NH3-N, and/or TKN in lbs/day for the year
- Part 3 The age of the treatment plant defined as the number of years since the last major reconstruction to increase the organic or hydraulic capacity of the plant. The last calendar year minus the year the new construction was brought on-line.
- Part 4 Bypass and overflow information. This is the number of bypass or overflow events of untreated wastewater due to heavy rain or equipment failure whether intentional or inadvertent from all collection systems tributary to the treatment facility.
- Part 5 A. Describe the characteristics and quantity of sludge generated.
B. If sludge is landspread, how many months of sludge storage does the plant have? This should include on-site and off-site storage from the treatment plant. The digester capacity may be used in the calculation.
- Part 6 A. Sludge Disposal Method
B. The number of approved land disposal sites for sludge available, and how many months or years these disposal sites will these be available for use.
- Part 7 The number of sewer extensions installed in the community last year--the design population, design flow, and design BOD for each sewer extension.
- Part 8 Operator Certification
- Part 9 Financial Status
- Part 10 Subjective Evaluation
- Part 11 Summary Sheet

Instructions to the Operator-in-Charge

1. Complete all sections of the MWPP Report to the best of your ability.
2. Parts 1 through 8 contain questions for which points will be generated. These points are intended to communicate to the Department and the governing body or owner the actions necessary to prevent effluent violations. Enter the point totals from Parts 1 through 8 on Part 11: Summary Sheet.
3. Add the point totals on Part 11: Summary Sheet.
4. Submit the MWPP Report to the governing body and the consulting engineer and owner for review and approval.
5. The governing body should pass a resolution which contains the following points:
 - a. The resolution should acknowledge the governing body or owner has reviewed the MWPP Report.
 - b. The resolution should indicate what actions will be taken to prevent effluent violations.
 - c. The resolution should provide any other information the governing body or owner deems appropriate.
6. **The MWPP Report and the resolution must be submitted by May 31st to Municipal Section, Water Division, ADEM, P.O. Box 301463, Montgomery, AL 36130-1463.**

Facility Name: Warrior WWTP

Part 1: Influent Loading/Flows

A. List the average monthly volumetric flows and BOD₅ (CBOD₅) loadings received at your facility during the last calendar year.

| <u>Month</u> | <u>Column 1 Average Monthly Flowrate (MGD)</u> | <u>Column 2 Average Monthly BOD₅ (CBOD₅) Concentration (mg/l)</u> | <u>Column 3 Average Loading BOD₅ (CBOD₅) (lbs/day**)</u> |
|--------------------|--|---|--|
| January | 0.13 | 178 | 166 |
| February | 0.12 | 254 | 264 |
| March | 0.11 | 177 | 163 |
| April | 0.15 | 261 | 303 |
| May | 0.14 | 257 | 282 |
| June | 0.11 | 251 | 226 |
| July | 0.11 | 324 | 296 |
| August | 0.12 | 248 | 253 |
| September | 0.07 | 345 | 222 |
| October | 0.04 | 476 | 169 |
| November | 0.05 | 294 | 95 |
| December | 0.10 | 247 | 192 |
| Annual Avg. | 0.10 | 276 | 219 |

**As reported on NPDES Discharge Monitoring Reports (DMRs) and as required by EPA's NPDES Self-Monitoring System, User Guide, March 1985.

B. List the average design flow and average design BOD₅ loading for the facility below. If you are not aware of these design quantities, contact your consulting engineer or the Alabama Department of Environmental Management.

| | <u>Average Design Flow</u> | <u>Average Design BOD₅ Loading (lbs/day)</u> |
|----------------------------|----------------------------|---|
| Design Criteria | 0.20 mgd | 475.0 |
| 90% of the Design Criteria | 0.18 mgd | 427.5 |

- C. How many times did the monthly flow (Column 1) to the WWTP exceed 90% of design flow?
 _____ (Check the appropriate point total)
 0 - 4 = 0 points 5 or more = 5 points
- D. How many times did the monthly flow (Column 1) to the WWTP exceed the design flow?
 _____ (Check the appropriate point total)
 0 = 0 points 1 - 2 = 5 points 3 - 4 = 10 points 5 or more = 15 points
- E. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed 90% of the design loading? _____ (Check the appropriate point total)
 0 - 1 = 0 points 2 - 4 = 5 points 5 or more = 10 points
- F. How many times did the monthly BOD₅ (or CBOD₅)* loading (lbs/day) (Column 3) to the WWTP exceed the design loading? _____ (Check the appropriate point total)
 0 = 0 points 1 = 10 points 2 = 20 points 3 = 30 points 4 = 40 points 5 or more = 50 points
- G. Enter each point value marked for C through F and enter the sum in the appropriate blank below.

C points = 0

D points = 0

E points = 0

F points = 0

TOTAL POINTS VALUE OR PART 1 0
 Enter this value on Part 11: Summary Sheet.

*To obtain equivalent BOD₅ loading for comparison with design loading for those permittees using influent CBOD₅, divide annual average CBOD₅ loading in lbs/day from Part 1, A by 0.7.

Facility Name: Warrior WWTP

Part 2: Effluent Quality/Plant Performance

- A. List the monthly average permit limits for the facility in the blanks below and the average monthly effluent DMR BOD₅, (CBOD₅) TSS, NH₃-N and/or TKN concentration produced by the facility during the last calendar year.

(1) NPDES Permit Concentration

| Permit Limit | Months | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------|------------|--|---------------|------------------------------|---------------|
| | April- Oct | 18.0 | 24.0 | 1.2 | Report |
| Nov- March | 25.0 | 24.0 | 2.1 | Report | |

(2) DMR Concentration

| Qtr | Month | BOD ₅ (CBOD ₅) (mg/l) | TSS (mg/l) | NH ₃ -N (mg/l) | TKN (mg/l) |
|--------------------|-----------|--|---------------|------------------------------|---------------|
| 1 | January | 0.93 | 1.7 | 0.01 | n/a |
| | February | 0.81 | 4.2 | 0.02 | n/a |
| | March | 0.96 | 0.59 | 0.00 | n/a |
| 2 | April | 1.5 | 0.83 | 0.03 | 0.33 |
| | May | 1.6 | 2.0 | 0.01 | 0.59 |
| | June | 1.2 | 2.3 | 0.02 | 0.80 |
| 3 | July | 1.2 | 3.4 | 0.02 | 0.31 |
| | August | 1.8 | 3.3 | 0.00 | 0.67 |
| | September | 2.0 | 2.4 | 0.00 | 0.66 |
| 4 | October | 0.75 | 1.3 | 0.00 | 1.4 |
| | November | 1.1 | 2.4 | 0.03 | n/a |
| | December | 1.6 | 2.4 | 0.03 | n/a |
| Annual Avg. | | 1.3 | 2.2 | 0.01 | 0.68 |

B. List the monthly average permit limit and DMR loadings below.

(1) NPDES Permit Loading

| Permit Limit | Months | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|--------------|-----------|---|------------------|---------------------------------|------------------|
| | April-Oct | 15.0 | 20.0 | 1.0 | Report |
| | Nov-March | 20.8 | 20.0 | 1.7 | Report |

(2) DMR Loading

| Qtr | Month | BOD ₅ (CBOD ₅) (lbs/day) | TSS (lbs/day) | NH ₃ -N (lbs/day) | TKN (lbs/day) |
|--------------------|-----------|---|------------------|---------------------------------|------------------|
| 1 | January | 1.2 | 2.9 | 0.003 | n/a |
| | February | 0.90 | 4.2 | 0.01 | n/a |
| | March | 0.91 | 0.50 | 0.0 | n/a |
| 2 | April | 1.7 | 0.96 | 0.03 | 0.19 |
| | May | 1.9 | 2.5 | 0.0 | 0.59 |
| | June | 0.94 | 2.2 | 0.02 | 1.0 |
| 3 | July | 1.2 | 3.4 | 0.02 | 0.25 |
| | August | 1.9 | 3.4 | 0.0 | 1.2 |
| | September | 1.3 | 1.9 | 0.0 | 0.28 |
| 4 | October | 0.27 | 0.56 | 0.0 | 0.46 |
| | November | 0.47 | 1.1 | 0.03 | n/a |
| | December | 1.6 | 1.9 | 0.04 | n/a |
| Annual Avg. | | 1.2 | 2.1 | 0.01 | 0.57 |

C. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any consecutive quarters? (Check the appropriate point total.)

No = 0 points

Yes = 121 points

D. During the past year did the BOD₅ concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

E. During the past year did the effluent TSS concentration (mg/l) or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

F. During the past year did the TSS concentration (mg/l) and/or loading (lbs/day) exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

G. During the past year did the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day) exceed the product of 1.4 times the monthly average permit limit during two months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

H. During the past year did either the NH₃-N or TKN concentration (mg/l) and/or loading (lbs/day), exceed the monthly average permit limit during four months of any two consecutive quarters? (Check the appropriate point total.)

No = 0 points Yes = 121 points

I. Enter each point value checked for C through H in the blanks below.

C Points = 0

D Points = 0

E Points = 0

F Points = 0

G Points = 0

H Points = 0

HIGHEST INDIVIDUAL POINT VALUE FOR PART 2 (C-H) 0 (HIGHEST POINT = 121)
Enter this value on Part 11: Summary Sheet.

Facility Name: Warrior WWTP

Part 3: Age of the Wastewater Treatment Facility

A. What year was the wastewater treatment plant constructed or last reconstructed? _____

Subtract the above answer from the report year to determine age:

$$\text{Age} = (\text{Last Calendar year}) - (\text{Answer to A})$$

$$\text{Age } 7 = (2013) - (2006)$$

Enter Age in Part C below.

B. Check the type of treatment facility employed.

| | Factor |
|---------------------------------------|--------|
| <u>2.0</u> Mechanical Treatment Plant | 2.0 |
| _____ Aerated Lagoon | 1.5 |
| _____ Stabilization Pond | 1.0 |
| _____ Other (Specify: _____) | 1.0 |

C. Multiply the factor listed next to the type of the facility your community employs by the age of your facility to determine the total point value for Part 3:

$$\frac{2.0}{\text{(Factor)}} \times \frac{7.0}{\text{(Age)}} = 14 \text{ TOTAL POINT VALUE FOR PART 3}$$

Enter the above value on Part 11: Summary Sheet. If the total point value exceeds 40, enter 40 on Part 11: Summary Sheet.

Facility Name: Warrior WWTP

Part 4: Bypassing and Overflows

- A. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to heavy rain? ⁰ _____
- B. How many bypass or overflow events of untreated wastewater occurred in the last year prior to the headworks of the WWTP due to heavy rain? ⁰ _____
- C. How many of the bypass or overflow events listed in Parts A and B have been corrected such that future bypass or overflow events at the same location due to heavy rain are not anticipated? ⁰ _____
- D. Add together Answers A and B and subtract Answer C from that total.
A + B - C = _____ (Check the appropriate point total.)
- | | | | | | | | |
|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 0 = 0 points | 1 = 5 points | 2 = 10 points | 3 = 15 points | 4 = 20 points | 5 = 25 points | 6 = 30 points | |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| 7 = 35 points | 8 = 40 points | 9 = 45 points | 10 = 50 points | 11 or more = 100 points | | | |
- E. How many bypass or overflow events of untreated wastewater occurred in the last year at the WWTP due to equipment failure? (This includes clogged/broken lines or manholes.) ⁰ _____
- F. How many bypass or overflow events of untreated wastewater occurred in the last year due to equipment failure prior to the headworks of the WWTP? (This includes clogged/broken lines or manholes.) ⁰ _____
- G. How many of the bypass or overflow events listed in Parts E and F have been corrected such that future bypass or overflow events at the same location due to the same equipment failure are not anticipated? ⁰ _____
- H. Add together Answers E and F and subtract Answer G from that total.
E + F - G = _____ (Check the appropriate point total.)
- | | | | | | | | |
|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 0 = 0 points | 1 = 5 points | 2 = 10 points | 3 = 15 points | 4 = 20 points | 5 = 25 points | 6 = 30 points | |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| 7 = 35 points | 8 = 40 points | 9 = 45 points | 10 = 50 points | 11 or more = 100 points | | | |
- I. Add point values circled in D and H and enter the total in the blank below.

TOTAL POINT VALUE FOR PART 4 ⁰ _____

Enter this value on Part 11: Summary Sheet.

All bypass or overflow events that have occurred in the last year (for any reason) must be individually reported with this MWPP report.

Facility Name: Warrior WWTP

Part 5: Sludge Quantity and Storage

- A. Please provide information concerning sludge quantity, characteristics, and storage practices based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months of sludge storage capacity does the wastewater treatment facility have available, either on-site or off-site? (i.e., How many months can the facility operate without land spreading or disposing of sludge?) 4

(Check the appropriate point total.)

- Greater than or equal to 4 months = 0 points
- Less than 4 months, but greater than or equal to 3 months = 10 points
- Less than 3 months, but greater than or equal to 2 months = 20 points
- Less than 2 months, but greater than or equal to 1 month = 30 points
- Less than one month = 50 points

TOTAL POINT VALUE FOR PART 5 0
Enter this value on Part 11: Summary Sheet.

Part 6: Sludge Disposal Practices and Sites

- A. Please provide the sludge disposal practices and site information based on available data as requested on the *MWPP Sewage Sludge Survey*, ADEM Form 419.
- B. How many months or years does the facility have access to and approval for sufficient land disposal sites to provide proper land disposal? (Check the appropriate point total.)

- 36 or more months = 0 points
- 24 - 35 months = 10 points
- 12 - 23 months = 20 points
- 6 - 11 months = 30 points
- Less than 6 months = 50 points

TOTAL POINT VALUE FOR PART 6 20
Enter this value on Part 11: Summary Sheet.

Facility Name: Warrior WWTP

Part 7: New Development

Are there any major new developments (industrial, commercial, or residential) in the last calendar year or anticipated in the next 2-3 years such that either flow or BOD₅ loadings to the sewage system could significantly increase? Estimate additional loadings below.

Design
Population: _____
Equivalent (PE)

Design
Flow: _____ MGD

Design
BOD₅: _____ lbs/day

List industrial and/or residential developments.

No major new developments are planned.

Will the additional loading overload the plant? (Check the appropriate point total.)

No = 0 points

Yes = 121 points

Enter the point total in the blank below.

TOTAL POINT VALUE FOR PART 7 ⁰ _____ (highest point total = 121)

Enter this value on Part 11: Summary Sheet.

Part 8: Operator Certification

Complete the *Plant and Collection System Personnel Inventory*, ADEM Form 441.

Do both the plant operator and collection system staffing comply with ADEM Administrative Code; Division 10, Operator Certification Program? (Check the appropriate point total.)

Yes = 0 points

No = 121 points

TOTAL POINT VALUE FOR PART 8 ⁰ _____ (highest point total = 121)

Enter this value on Part 11: Summary Sheet.

Facility Name: Warrior WWTP

Part 9: Financial Status

- A. Are User-Charge Revenues sufficient to cover operation and maintenance expenses? If no, how are O&M costs being financed? **Include user charge rates.**

Revenues are sufficient. The below values are based on a 5/8" meter and 6000 gallons of water use.

Jefferson County has a three tier block rate structure for residential users for 0-3, 4-6, and 7+ccf water use.

Residential Minimum 15.00 Plus rate 6.02, 9.36, 10.69 /1,000 gal.

Industrial Minimum 15.00 Plus rate 10.51 /1,000 gal.

Monthly residential rate based on 6,000 gallons usage \$ 56.04 (includes 15% credit for residential)

***Please complete the above information based on your user charge rates for the report year. You may attach a sample water and sewer bill for clarity.**

- B. What financial resources are available to pay for the wastewater improvements and/or reconstruction needs?

In 2013, Jefferson County issued Series 2013 Sewer Warrants that fund capital improvements

through 2023 at an annual average rate of \$71.9 million over the 10-year period.

Part 10: Subjective Evaluation

- A. Describe briefly the physical and structural conditions of the wastewater treatment facility.

The WWTP was newly constructed in 2006 and is in excellent condition.

- B. Describe the general condition of the sewer system (sewer lines, manholes, lift stations).

The Warrior system includes roughly 50,000' of pipe and 2 pump stations. The system's historical rate of

SSO's/100 miles of sewer is exceptional. There are no known capacity deficiencies.

The general condition of the system is good.

C. What sewage system improvements does the community have planned for construction in the next 5 years?

None

D. What is the theoretical design life of the plant, and what is the estimated remaining useful life of the wastewater treatment facility?

Calculated remaining useful life of the structures is 42 years (50 years - 8 years age of facility).

Calculated remaining useful life of the equipment is 17 years (25 years - 8 years of equipment).

Based on EPA's 2002 Clean Water and Drinking Water Infrastructure Gap Analysis Report.

E. What problems, if any, over the last year have threatened treatment or conveyance within the system?

None

F. Is the community presently involved in formal planning for treatment facility upgrading?

No

G. How many days in the last year were there residential backups at any point in the collection system for any reason other than clogging of the lateral connection? 1

H. Does the plant have a written plan for preventive maintenance on major equipment items? If yes, describe.

Yes, O&M manuals for all equipment are on site. We record lubrication and repairs on all equipment in a computer

program (Infor) for future reference and to keep a log on all repairs.

- I. Does this preventive maintenance program depict frequency of intervals, types of lubrication, and other preventive maintenance tasks necessary for each piece of equipment? (Check the appropriate response.) Yes No
- J. Are these preventive maintenance tasks, as well as equipment problems, being recorded and filed so future maintenance problems can be assessed properly? (Check the appropriate response.) Yes No
- K. Describe any major repairs or mechanical equipment replacement made in the last year and include the approximate cost for those repairs. Do not include major treatment plant construction or upgrading programs.

None

- L. List any additional comments. (Attach additional sheets if necessary.)

Facility Name: Warrior WWTP

Part 11: Summary Sheet

1. Enter in the values from Parts 1 through 8 in the left column below. Add the numbers in the left column to determine the MWPP Report point total the wastewater system generated for the previous calendar year.

| <u>Actual Values</u> | <u>Maximum Possible</u> |
|---------------------------|-------------------------|
| Part 1 <u>0</u> points | 80 points |
| Part 2 <u>0</u> points | 121 points |
| Part 3 <u>14</u> points | 40 points |
| Part 4 <u> </u> points | 200 points |
| Part 5 <u>0</u> points | 50 points |
| Part 6 <u>20</u> points | 50 points |
| Part 7 <u>0</u> points | 121 points |
| Part 8 <u>0</u> points | 121 points |
| Total <u>34</u> points | 783 points |

2. Check the facility type that best describes the plant's treatment and disposal of wastewater.

- Mechanical plant with surface water discharge
 Aerated Lagoon or stabilization pond with surface water discharge
 Mechanical plant using land disposal of liquid wastes
 Aerated Lagoon or stabilization pond using land disposal of liquid wastes

3. Check the range that describes the action needed to address problems identified in the report.

- 0 - 70 pts. Actions as Appropriate*
 71 - 120 pts. Departmental Recommendation Range*
 121 - 783 Municipality Action Range*

***Other actions may be required by NPDES outside the scope of this report.**

4. Complete the *Municipal Water Pollution Prevention Resolution Form*, ADEM Form 418.


5. In Question 1, do any of the actual point values in the left column equal the maximum possible points in the right column? (Check the appropriate response) Yes No

If yes, provide a written explanation for this situation in the space below.

Warrior Wastewater Treatment Plant
ATTACHMENT 2 – Raw Sewage Bypass and
SUMMARY



WARRIOR BASIN 2013 DISCHARGES



NOTE: OVERFLOWS SHOWN ARE OVER 10,000 GALLONS
NONE REPORTED FOR WARRIOR BASIN.

JEFFERSON COUNTY
ENVIRONMENTAL SERVICES
PLOTTED: 2-11-14



Summary of Unpermitted Discharges - Warrior

January 01, 2013 through December 31, 2013

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| <i>Event No.</i> | <i>Date Reported</i> | <i>Location</i> | <i>Collection System</i> | <i>Ultimate Destination</i> | <i>Est. Vol. (gal)</i> | <i>Source</i> | <i>Cause</i> | <i>Weather</i> | <i>Action Taken</i> | <i>Person Reporting</i> | <i>Title</i> |
|------------------|----------------------|-----------------|--------------------------|-----------------------------|------------------------|---------------|--------------|----------------|---------------------|-------------------------|--------------|
|------------------|----------------------|-----------------|--------------------------|-----------------------------|------------------------|---------------|--------------|----------------|---------------------|-------------------------|--------------|

Notes:

No Unpermitted Discharges for 2013

Warrior Wastewater Treatment Plant
ATTACHMENT 3 – MWPP Sewage Sludge

SURVEY



MWPP SEWAGE SLUDGE SURVEY

Facility Background Information:

1. Facility Information

Permit Number: AL005081

Name: Warrior WWTP
Street Address: 700 Blackburn Drive
County: Jefferson

2. Facility Contact

Name: Chad Quick
Title: Plant Supervisor
Telephone: (205) 681-7971
Permittee Name: Jefferson County Commission- Warrior WWTP
Mailing Address: Suite A-300, 716 Richard Arrington JR. Blvd. N.
Birmingham AL 35203

Facility Flow Information

1. Facility Wastewater Treatment Capacity

Avg. Daily Flow for 2013: 0.105 MGD
Facility Design Capacity: 0.2 MGD

2. Estimated Septage Quantity Handled (Residuals Removed from Septic Tank Systems)

Average Domestic Septage: N/A gallons per month
Average Commercial Septage: N/A gallons per month

3. Method of Septage Processing

- Mixed with Influent Wastewater for Treatment
 Mixed with Sewage Sludge

N/A

4. Estimated Percentage Contributing Wastewater Flow

Residential: 95 %
Industrial: 0 %
Other: 5 % Describe: Commercial

5. List type of wastewater treatment process(es) utilized at this facility:

Bar Screening, Grit Removal, Extended Aeration with Activated Sludge,
Clarification, Traveling Bridge Sand Filtration, UV Disinfection, Step Aeration

6. Estimated sewage sludge wasting rate at this facility: _____ lb/day dry weight
or 1858 gallons per day

7. Estimated untreated sludge received from off site: N/A lb/day dry weight
or _____ gallons per day

8. Estimated percent solids of combined sewage sludge prior to treatment: 2 %

9. List the sewage sludge treatment processes used in preparing sludge for final use or disposal:

| Aerobic Digestion, Drying Beds (Air Drying) | Sludge Quantity (untreated pounds per day) |
|---|---|
| _____ | _____ |
| _____ | _____ |
| _____ | _____ |

10. Estimate the total volume of sludge generated:

25
(dry U.S. tons per year)

Sludge Disposal Methods

1. Which of the following describes the current method of sewage sludge disposal for this facility:

| | Current Practices | | Quantity (dry U.S. tons/year) | Proposed Practices Approved by ADEM | |
|--|--------------------------|--------------------------|----------------------------------|--|--------------------------|
| | Approved by ADEM Yes | No | | Yes | No |
| a. <input checked="" type="checkbox"/> Land Application, Bulk Shipped | | | <u>25</u> | | |
| <input checked="" type="checkbox"/> Agriculture | X | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Forest | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Public Contact | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Lawn/Home Garden | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| b. <input type="checkbox"/> Land Application, Bagged/Other Container | | | | | |
| <input type="checkbox"/> Agriculture | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Forest | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Public Contact | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Lawn/Home Garden | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| c. <input type="checkbox"/> Incineration | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| d. <input type="checkbox"/> Subtitle D Landfill (Disposal Only) | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| e. <input type="checkbox"/> Lined Treatment Lagoon or Stabilization Pond | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| f. <input type="checkbox"/> Unlined Lagoon or Stabilization Pond | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| g. <input type="checkbox"/> Other (Please Describe) | <input type="checkbox"/> | <input type="checkbox"/> | | <input type="checkbox"/> | <input type="checkbox"/> |
| _____ | | | | | |
| _____ | | | | | |
| _____ | | | | | |

2. If "f" was selected above and sludge is stored for 2 or more years, enter the distance between the surface disposal site and the property line: N/A feet

Pollutant Concentrations

1. Enter the total concentrations of the following analytes using existing data. Do not enter TCLP results.

| Analyte | Concentration (mg/kg or ppm) | Sample Type | Sample Date | Detection Level of Analysis |
|-------------------------|------------------------------|-------------|-------------|-----------------------------|
| Arsenic | <PQL | Grab | * | 11.0 |
| Cadmium | <PQL | Grab | * | 5.0 |
| Chromium | 36 | Grab | * | 6.0 |
| Copper | 170 | Grab | * | 5.0 |
| Lead | 19 | Grab | * | 12.0 |
| Mercury | 8 | Grab | * | 0.0 |
| Molybdenum | <PQL | Grab | * | 6.0 |
| Nickel | 23 | Grab | * | 6.0 |
| Selenium | <PQL | Grab | * | 12.0 |
| Zinc | 653 | Grab | * | 8.0 |
| Ammonium-Nitrogen | | N/A | N/A | N/A |
| Nitrate-Nitrogen | | N/A | N/A | N/A |
| Total Kjeldahl Nitrogen | 37,000 | Grab | * | 0.09 |

PQL=Practical Quantitative Limit

*= Yearly Average

2. Enter the estimated or determined percent solids of the sewage sludge when sampled for the above analysis: 86 %

Treatment Provided for Sewage Sludge at the Facility

1. Which class of pathogen reduction does the sewage sludge meet at the facility? (As defined in 40 CFR Part 503)

Class A

Alternative A1 - Time and Temperature

Alternative A2 - Alkaline Treatment

Alternative A3 - Analysis and Operation

Alternative A4 - Analysis Only

Alternative A5 - Processes to Further Reduce Pathogens (PFRP)

Heat Drying

Thermophilic Aerobic Digestion

Heat Treatment

Pasteurization

Gamma Ray Irradiation

Beta Ray Irradiation

Composting

Alternative A6 - PFRP Equivalent

Class B

Alternative B1 - Fecal Coliform Count

Alternative B2 - Process to Significantly Reduce Pathogens (PSRP)

Aerobic Digestion

Air Drying

Anaerobic Digestion

Composting

Lime Stabilization

Alternative B3 - PSRP Equivalent

Neither or Unknown

Vector Attraction Control

- Option 1 - Minimum 38% Reduction in Volatile Solids
- Option 2 - Anaerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 3 - Aerobic Processes, with Bench-Scale Demonstration of Volatile Solids Reduction
- Option 4 - Specific Oxygen Uptake Rate (SOUR) for Aerobically Digested Sludge
- Option 5 - Aerobic Processes plus Elevated Temperature
- Option 6 - Raised pH to 12 and Retained at 11.5
- Option 7 - 75% Solids with no Unstabilized Solids
- Option 8 - 90% Solids with Unstabilized Solids
- Option 9 - Injection Below Land Surface
- Option 10 - Incorporation into Soil within 6 or 8 Hours
- Option 11 - Covering Active Sewage Sludge Unit Daily
- None of the Above

Groundwater Monitoring

1. If disposal practice is surface disposal or land application, is groundwater monitoring required or performed at the site?

- Yes (If yes, please submit a copy of the groundwater monitoring reports along with this survey. Also please provide the approximate depth to groundwater and the groundwater monitoring procedures used to obtain the data.)
- No

Land Application of Sewage Sludge

Answer the following questions if sewage sludge is applied to land.

1. If sewage sludge is land applied in bulk form, what type of crop or other vegetation is grown on this site?

Tifton Bermuda Grass, Ryegrass

2. If sewage sludge is land applied in bulk form, what is the nitrogen requirement for this crop or vegetation?
600lb/acre/year (Reclamation Site)

3. If sewage sludge is land applied in bulk form, briefly describe the nature of any complaints filed from neighbors?

No complaints have been received.

Note: Permittees that submitted the "Annual Report Review Form" for sludge to the EPA may submit a copy with the MWPP in lieu of this Attachment.

Warrior Wastewater Treatment Plant
ATTACHMENT 4 – Plant and Collection System
Personnel Inventory



PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Warrior WWTP

PLANT GRADE: II

PERMIT NUMBER: AL 0050881

PLANT SUPERINTENDENT: Chad Quick

TEL. # (205)681-7971

SYSTEM MANAGER: David Denard

TEL. # (205)326-8232

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|--------------------|----------------------------|----------------|------------------|
| 1. | Eric Pond | IV | C003706 | 2/28/2016 |
| 2. | Mark Lee | IV | C000389 | 8/31/2016 |
| 3. | Chad Quick | IV | C003616 | 2/28/2015 |
| 4. | Pat McCarty | IV | C003224 | 8/31/2014 |
| 5. | Adam Moore | IV | C006513 | 11/1/2014 |
| 6. | | | | |
| 7. | | | | |
| 8. | | | | |
| 9. | | | | |
| 10. | | | | |

COLLECTION SYSTEM OPERATORS:

| | | | | |
|----|--|--|--|--|
| 1. | | | | |
| 2. | | | | |
| 3. | | | | |
| 4. | | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|----------|
| MANAGEMENT/SUPERVISOR | 120 | 3 |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | 80 | 2 |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | | |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

| | |
|-----|----------|
| 1ST | 1 |
| 2ND | |
| 3RD | |

| | |
|------------|----------------|
| START TIME | 7:00 AM |
| | |
| | |

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|----------|----------|----------|----------|----------|----------|----------|
| 1ST | X | X | X | X | X | X | X |
| 2ND | | | | | | | |
| 3RD | | | | | | | |

ADEM USE ONLY

1. DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
2. DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|----------|----|
| X | |
| | |

PLANT AND COLLECTION SYSTEM PERSONNEL INVENTORY

FACILITY NAME: Sewer Line Maintenance

PLANT GRADE: IV

PERMIT NUMBER: _____

PLANT SUPERINTENDENT: _____

TEL. # (205) 540-7585

SYSTEM MANAGER: David Denard

TEL. # (205) 325-5979

PLANT OPERATORS:

| | NAME | GRADE OR TRAINEE STATUS | OPERATOR NO. | EXP. DATE |
|-----|----------------|----------------------------|--------------|------------|
| 1. | Brian Champion | I (c) | C002094 | 6/30/2015 |
| 2. | Don Goodwin | I (c) | C005423 | 6/30/2015 |
| 3. | Lavon Evans | I (c) | C004631 | 12/31/2014 |
| 4. | Brian Rohling | I (c) | C005418 | 6/30/2015 |
| 5. | | | | |
| 6. | | | | |
| 7. | | | | |
| 8. | | | | |
| 9. | | | | |
| 10. | | | | |

COLLECTION SYSTEM OPERATORS:

| | | | | |
|----|--|--|--|--|
| 1. | | | | |
| 2. | | | | |
| 3. | | | | |
| 4. | | | | |

| | MAN HRS./WK | NUMBER |
|-----------------------|-------------|--------|
| MANAGEMENT/SUPERVISOR | | |
| OPERATOR(S): | | |
| GRADE I-C | | |
| GRADE I | | |
| GRADE II | | |
| GRADE III | | |
| GRADE IV | | |
| DESIGNATED TRAINEE(S) | | |
| LABORATORY | | |
| MAINTENANCE | | |
| OTHER PLANT WORKERS | | |

AVERAGE NUMBER OF EMPLOYEES PER SHIFT:

1ST

2ND

3RD

START TIME

OPERATOR SHIFTS NORMALLY WORKED EACH DAY:

| | SUN | MON | TUES | WED | THURS | FRI | SAT |
|-----|-----|-----|------|-----|-------|-----|-----|
| 1ST | | | | | | | |
| 2ND | | | | | | | |
| 3RD | | | | | | | |

ADEM USE ONLY

- DOES PLANT OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?
- DOES COLLECTION SYSTEM OPERATOR STAFFING COMPLY WITH DIVISION 10 OF ADEM ADMINISTRATIVE CODE?

| YES | NO |
|--------------------------|--------------------------|
| <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> |

JEFFERSON COUNTY COMMISSION



DAVID CARRINGTON - PRESIDENT
GEORGE BOWMAN
SANDRA LITTLE BROWN
JOE KNIGHT
JIMMIE STEPHENS

Daniel White, P.E. – Deputy Director
ENVIRONMENTAL SERVICES

Environmental Services Department
Suite A300
716 Richard Arrington, Jr. Blvd. N.
Birmingham, Alabama 35203
Telephone (205) 325-5496
Fax (205) 325-5981

February 18, 2014

Certified Mail 7010 1870 0003 1330 9443
Return Receipt Requested

EPA Region 7
ATTN: BIOSOLIDS CENTER
WWPD/WENF
11201 Renner Boulevard
Lenexa, Kansas 66219

RE: Jefferson County Commission - 2013 Annual Biosolids Report

Please find enclosed the 2013 Annual Biosolids Monitoring Report for the Jefferson County Environmental Services Department Biosolids Land Reclamation Program. This report is respectfully submitted in accordance with the requirements of 40 CFR Part 503.

Sincerely,

Daniel A. White, P.E.
Deputy Director
Environmental Services Dept.

cc: File

**JEFFERSON COUNTY COMMISSION
ENVIRONMENTAL SERVICES DEPARTMENT**

JEFFERSON COUNTY, ALABAMA



BIOSOLIDS MANAGEMENT PROGRAM

Jefferson County Land Reclamation Program



REPORT PREPARED BY:

JEFFERSON COUNTY ENVIRONMENTAL SERVICES DEPARTMENT



2013 Annual Biosolids Report

Certification Statement

Executive Summary

Project Information

Jefferson County WWTPs
Flat Top/Bessie Mines Land
Reclamation Site
Beltona Land Reclamation Site

Biosolids Analysis

Test Methodology
Analysis Results
Sample Specimen Collection Sheets

Agronomic Rate Calculations

Design Considerations
Calculations

Appendix A

Agronomic Rate Justification Letter
“Worksheet for Calculating Biosolids
Application Rates in Agriculture”

Appendix B

Flat Top/Bessie Mine VAR Summary
Beltona VAR Summary

Appendix C

1 – Jefferson County Map
2 – Flat Top/Bessie Mines Land
Reclamation Site
3 – Beltona Land Reclamation Site

2013 EPA ANNUAL BIOSOLIDS REPORT

JEFFERSON COUNTY ENVIRONMENTAL SERVICES DEPARTMENT BIRMINGHAM, ALABAMA

Enclosed is the 2013 Annual Biosolids Monitoring Report for the Jefferson County Environmental Services' **Biosolids Land Reclamation Program**. This report is respectfully submitted to the Environmental Protection Agency (EPA) Region IV in accordance with the requirements of 40 CFR Part 503.


Information provided in this report includes:

1. Certification Statement for management practices, site restrictions, pathogen requirement, and vector attraction reduction requirements.
2. Executive Summary.
3. Project information for the Biosolids Management Program, including Jefferson County Wastewater Treatment Facility information and land application site data.
4. Biosolids testing methodology and analysis results, including sample collection forms.
5. Agronomic calculations, rate justification letter and sample worksheet for calculating agronomic rates.
6. Vector Attraction Reduction Statistics.
7. Land application site maps.

SECTION 1
CERTIFICATION STATEMENT

**CERTIFICATION STATEMENT FOR THE *PREPARER*
and *APPLIER* OF BULK SEWAGE BIOSOLIDS**

I certify, under penalty of law, that the information that will be used to determine compliance with the management practices in §503.14, the site restrictions in §503.32 (b)(5), the Class B pathogen requirements in §503.32(b), and the vector attraction reduction requirements in §503.33(b)(6) or (10)(i) was prepared for each site on which bulk sewage sludge is applied under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate this information. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.



Signature

2/18/14

Date

David Denard – Director, Jefferson County Environmental Services Department
Printed Name and Position

SECTION 2

EXECUTIVE SUMMARY

EXECUTIVE SUMMARY

The Jefferson County Environmental Services Department utilizes land application as the method of disposal for the biosolids currently produced by its wastewater treatment facilities. There are currently nine (9) wastewater treatment facilities operated by the Environmental Services Department. During 2013, these facilities treated an average daily flow of 124 MGD of wastewater and produced 10,956 dry tons of biosolids that were sent for land application. Seven (7) of the County's wastewater treatment facilities are Class I Publicly-Owned Treatment Works (POTWs), and therefore subject to the 40 CFR Part 503 reporting regulations.

Throughout 2013, the biosolids produced by Jefferson County's wastewater treatment facilities were land applied at two (2) former strip mine sites. Jefferson County is assisting the property owner, the United Land Corporation, in the reclamation of both sites through the land application of biosolids.

The Flat Top/Bessie Mines Land Reclamation Site (Flat Top) is located in northwestern Jefferson County and is approximately 4,670 acres total in size, with approximately 2,700 acres being disturbed through previous mining activities. Biosolids from nine (9) wastewater treatment facilities were applied at this site during 2013.

The Beltona Land Reclamation Site, located in northern Jefferson County, is approximately 1,000 acres in size, with about one-third of the site being previously disturbed through mining activities. Biosolids from two (2) wastewater treatment facilities were applied at Beltona during 2013.

Applicable site restrictions, general requirements, and management practices have been met at both Land Reclamation Sites. Biosolids were applied to both sites using the "Pollutant Concentration" (PC) option. Pathogen and vector attraction reduction requirements and all required site restrictions for Class "B" biosolids were also met.

SECTION 3
PROJECT INFORMATION

JEFFERSON COUNTY
WASTEWATER TREATMENT FACILITIES

System: Jefferson County Commission/Environmental Services Department
716 Richard Arrington, Jr. Boulevard North
Birmingham, AL 35203

Summary:

The Jefferson County Environmental Services Department currently operates nine wastewater treatment facilities. During 2013, these facilities treated an average daily flow of 124 MGD of wastewater and produced 10,956 dry (English) tons of biosolids that were land applied. Seven of the County's wastewater treatment facilities are Class I POTWs, and therefore subject to the 40 CFR Part 503 reporting regulations.

| <u>Class I POTWs:</u> | <u>Dry Tons of Biosolids Land Applied</u> |
|---|--|
| 1. Cahaba River Wastewater Treatment Plant NPDES Permit No. AL0023027 | 1,207 |
| 2. Five Mile Creek Wastewater Treatment Plant NPDES Permit No. AL0026913 | 1,021 |
| 3. Leeds Wastewater Treatment Plant NPDES Permit No. AL0022297 | 373 |
| 4. Trussville Wastewater Treatment Plant NPDES Permit No. AL0022934 | 614 |
| 5. Turkey Creek Wastewater Treatment Plant NPDES Permit No. AL0022936 | 251 |
| 6. Valley Creek Wastewater Treatment Plant NPDES Permit No. AL0023655 | 4,111 |
| 7. Village Creek Wastewater Treatment Plant NPDES Permit No. AL0023647 | 3,231 |
| | |
| <u>Non-Class I POTWs (<1.0 MGD):</u> | |
| 1. Prudes Creek Wastewater Treatment Plant NPDES Permit No. AL0056120 | 123 |
| 2. Warrior Wastewater Treatment Plant NPDES Permit No. AL0050881 | 25 |

TOTAL: 10,956 Dry Tons

Reporting Requirements:

Based on the quantity of biosolids land applied during 2013, the required frequency of monitoring was six times per year. However, Jefferson County typically performs biosolids monitoring on a monthly basis (twelve times per year).

Pathogen Requirements:

Class "B" pathogen requirements were met through Alternative 1: The Monitoring of Fecal Coliform [503.32(b)(2)]. The geometric mean fecal coliform density per gram of dry biosolids was less than 2 million colony-forming units for each sampling event (see Biosolids Analysis Results).

Vector Attraction Reduction Summary:

The Valley Creek and Village Creek wastewater treatment facilities primarily utilized Option 6: Addition of Alkaline Material [503.33(b)(6)] for vector attraction reduction of their biosolids. The lime stabilized biosolids from the Valley Creek and Village Creek WWTPs account for approximately 49% of the County's total land applied biosolids. Only the alkaline stabilized biosolids from the Valley Creek and Village Creek WWTPs were land applied at the Beltona Land Reclamation Site in 2013 (21% of the total from these facilities). The remaining biosolids from these two sites and the seven other WWTPs were land applied at the Flat Top/Bessie Mines application site and were incorporated into the soil within six hours of application as described in Option 10: Incorporation of Biosolids into the Soil [503.33(b)(10)(i)]. This Option 10 method of vector attraction reduction applied to approximately 86% of the County's total biosolids land applied during 2013. The Valley Creek WWTP also met vector attraction reduction requirements through Option 1: Volatile Solids Reduction by a minimum of 38 percent [503.33(b)(1)] after July 25, 2013 as a secondary method.

FLAT TOP/BESSIE MINES
LAND RECLAMATION SITE

System: Jefferson County Commission/Environmental Services Department
716 Richard Arrington, Jr. Boulevard North
Birmingham, AL 35203

Reporting Period:
January 1, 2013 to December 31, 2013

Site Address:
5201 Flat Top Road, Graysville, AL 35073

Site Description:

The Flat Top Land Reclamation Site is a former strip mine site, 4,670 acres total in size, with approximately 2,700 acres being previously disturbed through mining activities. Jefferson County is assisting the property owner in the reclamation of this site through the land application of biosolids. Biosolids were land applied on roughly 423 acres at the site in 2013.

There is currently marginal soil mass present at this site for growing vegetation and, in order to build adequate soil mass, biosolids are recommended to be applied at a rate of 600 lb Nitrogen/Ac/year. When soil mass becomes adequate to sustain crop growth, Tifton Bermuda and Rye grass will be planted for nitrogen uptake.

Source of Biosolids:

During 2013, biosolids from nine wastewater treatment facilities were land applied at this site.

Quantity:

A total of 9,391 dry (English) tons of biosolids were applied at the Flat Top Land Reclamation Site during 2013. Biosolids were applied to Plot 3 of the site (see Figure 2). Of the total dry tons applied, 3,834 tons were lime stabilized and 5,557 tons were not lime stabilized.

Pollutant Limits:

Biosolids were applied to this site using the "Pollutant Concentration" (PC) option (see 2013 Biosolids Analysis Results). In order to be representative of in-situ conditions, monthly biosolids samples were taken from each treatment facility and then blended according to each facility's disposal ratio. Biosolids testing was then performed on this "blended" sample.

Pathogen Requirements:

Class "B" pathogen requirements were met through Alternative 1: The Monitoring of Fecal Coliform [503.32(b)(2)]. The geometric mean fecal coliform density per gram of dry biosolids was less than 2 million colony-forming units for each sampling event (see 2012 Biosolids Analysis Results).

Vector Attraction Reduction Requirements:

The Valley Creek and Village Creek wastewater treatment facilities primarily utilized lime stabilization for vector attraction reduction in the majority of their biosolids in accordance with Option 6: Addition of Alkaline Material [503.33(b)(6)]. To satisfy the requirements of Option 6, sufficient lime was added to the biosolids to raise the pH to at least 12 for 2 hours and at least 11.5 for an additional 22 hours, without the addition of more lime. Beginning in June and continuing into July, the Valley Creek WWTP intermittently tested whether the vector attraction reduction and pathogen requirements could be met through Option 1: Volatile Solids Reduction by a minimum of 38 percent [503.33(b)(1)]. The tests were successful, and the facility ceased using lime on July 25th. When biosolids from these treatment facilities are land applied at the Flat Top/Bessie Mines Reclamation Site, they are incorporated into the soil within six hours of application as well.

For biosolids received at the Flat Top Land Reclamation Site from the remaining treatment plants and the portion of biosolids from Valley and Village wastewater treatment facilities that did not receive lime stabilization, the method of vector attraction reduction used was Option 10: Incorporation of Biosolids into the Soil [503.33(b)(10)(i)]. These biosolids were land applied and incorporated into the soil within six hours of application on the land.

Management Practices and Site Restrictions:

All applicable management practices stated in 503.14 were met at the site, including a minimum 100 ft. buffer zone around waters of the United States.

All applicable site restrictions stated in 503.32(b)(5) for Class "B" biosolids were also met. The Flat Top/Bessie Mines Land Reclamation site is in a remote area of Jefferson County and is located on private property; therefore there is no public access to the site.

BELTONA LAND RECLAMATION SITE

System: Jefferson County Commission/Environmental Services Department
716 Richard Arrington, Jr. Boulevard North
Birmingham, AL 35203

Reporting Period:
January 1, 2013 to December 31, 2013

Site Address:
401-B Beltona Road, Warrior, AL 35180

Site Description:
The Beltona Land Reclamation Site, which is approximately 1,000 acres in size, is a former strip mine site located in northern Jefferson County. About one-third of the site has been utilized for biosolids land application, with plot sizes ranging from 3.0 acres to 20 acres. Jefferson County is assisting the property owner in the reclamation of this site through the land application of biosolids. Biosolids were land applied on roughly 143 acres at the site in 2013. Presently, Tifton Bermuda and Winter Rye grasses are grown at Beltona and are harvested several times a year as hay.

Source of Biosolids:
During January, February, and March 2013, biosolids from the Valley Creek and Village Creek wastewater treatment facilities were land applied at this site.

Quantity:
1,565 dry (English) tons of biosolids were land applied at the Beltona Land Reclamation Site during 2013.

Pollutant Limits:
Biosolids from two of the County's wastewater treatment facilities were applied to this site using the "Pollutant Concentration" (PC) option. Biosolids testing was performed on samples from these facilities at a frequency that meets or exceeds the minimum monitoring frequency requirement for each facility (see 2013 Biosolids Analysis Results).

Pathogen Requirements:
Class "B" pathogen requirements were met through Alternative 1: The Monitoring of Fecal Coliform [503.32(b)(2)]. The geometric mean fecal coliform density per gram of dry biosolids was less than 2 million colony-forming units for each sampling event (see 2012 Biosolids Analysis Results).

Vector Attraction Reduction Requirements:

For the biosolids land applied at the Beltona site, the Valley Creek and Village Creek wastewater treatment facilities utilized lime stabilization for vector attraction reduction of their biosolids, as described in Option 6: Addition of Alkaline Material [503.33(b)(6)]. To satisfy the requirements of Option 6, sufficient lime was added to the biosolids to raise the pH to at least 12 for 2 hours and at least 11.5 for an additional 22 hours, without the addition of more lime. Lime stabilized biosolids were then surface-applied at the Beltona Land Reclamation Site.

Management Practices and Site Restrictions:

All applicable management practices stated in 503.14 were met at the site, including a minimum 100 ft. buffer zone around waters of the United States.

All applicable site restrictions stated in 503.32(b)(5) for Class "B" biosolids were also met. The Beltona Land Reclamation Site is in a remote area of Jefferson County and is located on private property; therefore there is no public access to the site.

SECTION 4
BIOSOLIDS ANALYSIS

TEST METHODS FOR BIOSOLIDS ANALYSIS

Based on the quantity of biosolids land applied at the Flat Top/Bessie Mine Land Reclamation Site during 2013, the required frequency of monitoring was six (6) times per year; however, Jefferson County typically performs biosolids monitoring on a monthly basis (see 2013 Biosolids Analysis Results). Each month, samples were collected from each treatment facility and blended according to each facility's disposal ratio in order to be representative of in-situ conditions. Biosolids testing was then performed on this "blended" sample.

For the Beltona Land Reclamation Site, biosolids samples from the two (2) contributing treatment facilities were collected at a frequency that meets or exceeds the minimum monitoring frequency requirement for each facility (see 2013 Biosolids Analysis Results).

METALS ANALYSIS:

Following is a list of the biosolids sample preparation and test methods used when performing metals testing:

METHODS FOR EVALUATING SOLID WASTE, SW846 METHODS:

| | |
|------------|--------------|
| Arsenic | 3050B, 7060A |
| Cadmium | 3050B, 7130 |
| Chromium | 3050B, 7190 |
| Copper | 3050B, 7210 |
| Lead | 3050B, 7420 |
| Mercury | 7471B |
| Molybdenum | 3050B, 7481 |
| Nickel | 3050B, 7520 |
| Selenium | 3050B, 7740 |
| Zinc | 3050B, 7950 |

FECAL COLIFORM TESTING:

For each sampling event, seven (7) samples were collected and tested according to the procedure outlined in Part 9222D, *Standard Methods for the Examination of Water and Wastewater*, and Appendix F of EPA's *Environmental Regulations and Technology, Control of Pathogens and Vector Attraction in Sewage Sludge*. The geometric mean fecal coliform density per gram of dry biosolids was less than 2 million colony-forming units for each sampling event (see 2012 Biosolids Analysis Results). Serial dilutions were prepared in the range of 10^1 through 10^6 , and on some occasions 10^7 , thus enabling coliform colony counts of greater than 20 million.

**2013 BIOSOLIDS ANALYSIS RESULTS
FLAT TOP/BESSIE MINES LAND RECLAMATION SITE
(Blended sample from all facilities)**

| Date | As mg/kg | Cd mg/kg | Cr mg/kg | Cu mg/kg | Pb mg/kg | Hg mg/kg | Mo mg/kg | Ni mg/kg | Se mg/kg | Zn mg/kg | % Moisture mg/kg | Fecal Coliform CFU/g* |
|----------------------------|-------------|-------------|-------------|--------------|-------------|-------------|-------------|-------------|-------------|--------------|---------------------|--------------------------|
| 1/15/2013 | <PQL | <PQL | 98 | 1,400 | 76 | 2.3 | 18 | 73 | 13 | 3,700 | 73% | 3 |
| 2/5/2013 | <PQL | <PQL | 74 | 960 | 54 | 2.0 | 12 | 57 | <PQL | 3,100 | 64% | 7,400 |
| 3/5/2013 | <PQL | <PQL | 110 | 1,500 | 73 | <PQL | 18 | 72 | <PQL | 3,700 | 58% | 1,400 |
| 4/9/2013 | <PQL | <PQL | 110 | 1,300 | 70 | 1.8 | 16 | 76 | 14 | 3,500 | 54% | 1,900 |
| 5/7/2013 | <PQL | <PQL | 110 | 1,600 | 68 | 2.1 | 19 | 65 | 12 | 2,900 | 65% | 3,700 |
| 6/4/2013 | <PQL | <PQL | 67 | 660 | 51 | 2.0 | 11 | 55 | <PQL | 2,300 | 58% | 1,300 |
| 7/16/2013 | <PQL | <PQL | 86 | 1,400 | 63 | 2.0 | 19 | 58 | 20 | 1,800 | 64% | 0 |
| 8/6/2013 | <PQL | <PQL | 130 | 1,400 | 82 | <PQL | 21 | 100 | 23 | 3,700 | 63% | 0 |
| 9/10/2013 | <PQL | <PQL | 120 | 1,500 | 77 | 2.2 | 17 | 83 | <PQL | 4,500 | 55% | 5,900 |
| 10/1/2013 | <PQL | <PQL | 130 | 1,200 | 83 | 1.9 | 21 | 79 | 13 | 3,800 | 61% | 8,100 |
| 11/12/2013 | <PQL | <PQL | 110 | 1,700 | 67 | <PQL | 19 | 73 | 13 | 4,500 | 59% | 23,000 |
| 12/3/2013 | <PQL | 5.1 | 140 | 2,000 | 100 | 2.2 | 34 | 100 | 29 | 3,500 | 71% | 2,900 |
| Average | <PQL | <PQL | 107 | 1385 | 72 | 1.5 | 19 | 74 | <PQL | 3,400 | | |
| Maximum | <PQL | 5.1 | 140 | 2,000 | 100 | 2.3 | 34 | 100 | 29 | 4,500 | | |
| PQL | 11 | 5.0 | 6.0 | 5.0 | 12 | 0.03 | 6.0 | 6.0 | 12 | 8 | | |
| EQ/PC Limit ¹ | 41 | 39 | - | 1,500 | 300 | 17 | - | 420 | 100 | 2,800 | - | - |
| Ceiling Limit ² | 75 | 85 | - | 4,300 | 840 | 57 | 75 | 420 | 100 | 7,500 | - | - |

All pollutant concentrations given on a dry-weight basis

PQL = Practical Quantitation Limit

¹ Pollutant Concentration Limits taken from Table 3, Part 503.13

² Ceiling Concentration Limits taken from Table 1, Part 503

* Geometric mean fecal coliform density

**2013 BIOSOLIDS ANALYSIS RESULTS
BELTONA LAND RECLAMATION SITE
(Valley Creek WWTP)**

| Date | As mg/kg | Cd mg/kg | Cr mg/kg | Cu mg/kg | Pb mg/kg | Hg mg/kg | Mo mg/kg | Ni mg/kg | Se mg/kg | Zn mg/kg | % Moisture mg/kg | Fecal Coliform CFU/g* |
|----------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|---------------------|--------------------------|
| 1/15/2013 | <PQL | <PQL | 36 | 470 | 36 | 1.5 | 10 | 31 | <PQL | 1,200 | 80% | 0 |
| 2/5/2013 | <PQL | <PQL | 46 | 520 | 48 | 1.3 | 11 | 38 | <PQL | 1,300 | 80% | 0 |
| 3/5/2013 | <PQL | <PQL | 36 | 320 | 32 | <PQL | <PQL | 25 | <PQL | 830 | 77% | 0 |
| 4/9/2013 | <PQL | <PQL | 49 | 440 | 47 | 1.7 | 7.8 | 43 | <PQL | 1,200 | 83% | 14,000 |
| 5/7/2013 | <PQL | <PQL | 39 | 380 | 43 | 1.4 | 9.1 | 38 | <PQL | 970 | 84% | 21 |
| 6/4/2013 | <PQL | <PQL | 33 | 270 | 29 | 1.4 | <PQL | 32 | <PQL | 710 | 71% | 0 |
| 7/16/2013 | <PQL | <PQL | 37 | 280 | 24 | 1.0 | 8.6 | 30 | <PQL | 860 | 75% | 0 |
| 8/6/2013 | <PQL | <PQL | 52 | 490 | 41 | <PQL | 13 | 44 | <PQL | 1,400 | 83% | 23,000 |
| 9/10/2013 | <PQL | <PQL | 45 | 510 | 43 | 2.4 | 12 | 36 | <PQL | 1,500 | 86% | 170,000 |
| 10/1/2013 | <PQL | <PQL | 72 | 530 | 55 | 1.8 | 20 | 37 | <PQL | 1,600 | 82% | 130,000 |
| 11/2/2013 | <PQL | <PQL | 68 | 590 | 40 | 1.9 | 19 | 45 | <PQL | 1,900 | 83% | 140,000 |
| 12/3/2013 | <PQL | <PQL | 65 | 610 | 39 | 1.7 | 22 | 50 | 19 | 1,900 | 84% | 130,000 |
| Average | <PQL | <PQL | 48 | 450 | 40 | 1.3 | 11 | 37 | <PQL | 1280 | | |
| Maximum | <PQL | <PQL | 72 | 610 | 55 | 2.4 | 19 | 50 | 19 | 1,900 | | |
| PQL | 11 | 5.0 | 6.0 | 5.0 | 12 | 0.03 | 6.0 | 6.0 | 12 | 8 | | |
| EQ/PC Limit ¹ | 41 | 39 | - | 1,500 | 300 | 17 | - | 420 | 100 | 2,800 | - | - |
| Ceiling Limit ² | 75 | 85 | - | 4,300 | 840 | 57 | 75 | 420 | 100 | 7,500 | - | - |

All pollutant concentrations given on a dry-weight basis

PQL = Practical Quantitation Limit

¹ Pollutant Concentration Limits taken from Table 3, Part 503.13

² Ceiling Concentration Limits taken from Table 1, Part 503

* Geometric mean fecal coliform density

**2013 BIOSOLIDS ANALYSIS RESULTS
BELTONA LAND RECLAMATION SITE
(Village Creek WWTP)**

| Date | As mg/kg | Cd mg/kg | Cr mg/kg | Cu mg/kg | Pb mg/kg | Hg mg/kg | Mo mg/kg | Ni mg/kg | Se mg/kg | Zn mg/kg | % Moisture mg/kg | Fecal Coliform CFU/g* |
|----------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|---------------------|--------------------------|
| 1/15/2013 | <PQL | <PQL | 41 | 430 | 61 | 2.9 | 10 | 44 | <PQL | 1,100 | 71% | 0 |
| 2/5/2013 | <PQL | <PQL | 41 | 460 | 67 | 2.5 | 9.8 | 46 | <PQL | 1,100 | 70% | 0 |
| 3/5/2013 | <PQL | <PQL | 41 | 430 | 61 | <PQL | 11 | 41 | <PQL | 1,000 | 70% | 0 |
| 4/9/2013 | <PQL | <PQL | 45 | 480 | 66 | 2.1 | 7.9 | 42 | <PQL | 1,100 | 72% | 0 |
| 5/7/2013 | <PQL | <PQL | 44 | 470 | 70 | 3.5 | 11 | 41 | <PQL | 1,100 | 73% | 81 |
| 6/4/2013 | <PQL | <PQL | 38 | 380 | 56 | 2.0 | 7.1 | 35 | <PQL | 970 | 71% | 4 |
| 7/16/2013 | <PQL | <PQL | 36 | 350 | 43 | 1.6 | 6.2 | 35 | <PQL | 890 | 65% | 0 |
| 8/6/2013 | <PQL | <PQL | 44 | 360 | 51 | <PQL | 6.5 | 35 | 12 | 970 | 68% | 0 |
| 9/10/2013 | <PQL | <PQL | 38 | 370 | 49 | 4.2 | 7.2 | 36 | <PQL | 1,000 | 68% | 0 |
| 10/1/2013 | <PQL | <PQL | 31 | 330 | 42 | 1.5 | 6.6 | 30 | <PQL | 830 | 68% | 0 |
| 11/2/2013 | <PQL | <PQL | 38 | 390 | 51 | 0.46 | 8.2 | 37 | <PQL | 1,100 | 71% | 0 |
| 12/3/2013 | <PQL | <PQL | 34 | 360 | 44 | 1.7 | 8.6 | 37 | 18 | 1,000 | 67% | 0 |
| Average | <PQL | <PQL | 39 | 400 | 55 | 1.9 | 8.3 | 38 | <PQL | 1,013 | | |
| Maximum | <PQL | <PQL | 45 | 480 | 70 | 4.2 | 11 | 46 | 18 | 1,100 | | |
| PQL | 11 | 5.0 | 6.0 | 5.0 | 12 | 0.03 | 6.0 | 6.0 | 12 | 8 | | |
| EQ/PC Limit ¹ | 41 | 39 | - | 1,500 | 300 | 17 | - | 420 | 100 | 2,800 | - | - |
| Ceiling Limit ² | 75 | 85 | - | 4,300 | 840 | 57 | 75 | 420 | 100 | 7,500 | - | - |

All pollutant concentrations given on a dry-weight basis

PQL = Practical Quantitation Limit

¹ Pollutant Concentration Limits taken from Table 3, Part 503.13

² Ceiling Concentration Limits taken from Table 1, Part 503

* Geometric mean fecal coliform density

Jefferson County Commission Environmental Service Department
Chain Of Custody / Sample Collection / Request For Analysis

Sample ID: CAHABA RIVER WWTP-BIO-SOLIDS

Sample Set-up Date: _____ Time: _____ Primary Measuring Device: _____
 First Sample Date: _____ Time: _____ Sampler Type: _____
 Last Sample Date: _____ Time: _____ Flow Meter Type: _____
 Collection Date: 12-17-13 Time: 0730 Sample Interval: _____
 Sample Split? Yes No Sample Type: Grab Composite
 [TVVC/TCVC/TCVV]

PRESERVATION METHODS:
 A--Iced, 4° C.
 B--Sulfuric Acid to pH < 2
 C--Nitric Acid to pH < 2
 D--NaOH to pH > 11

MUST BE COMPLETED!! → Preservation Method A by: WWTP by Barton Lab Time: 0730
 Sample Collected by [Signature] Date 12-17-13 Time 0730 Relinquished by [Signature] Date 12-17-13 Time 0845
 Received by [Signature] Date 12-17-13 Time 0908 Relinquished by [Signature] Date 12-17-13 Time 0908
 Received by [Signature] Date 12/17/13 Time 1030 Relinquished by [Signature] Date 12/17/13 Time 1030

12-17-13 0730

201312170301

| Check | Analyte | RESULTS | Units | METHOD Number | Ref |
|-------------------------------------|------------------------|------------------------------|--------------|--------------------------------------|-------------------|
| <input checked="" type="checkbox"/> | BOD ₅ | | | 5210 B | SM |
| <input checked="" type="checkbox"/> | CBOD ₅ | | | 5210 B | SM |
| <input checked="" type="checkbox"/> | TSS | | | 2540 D | SM |
| <input checked="" type="checkbox"/> | pH | | | 4500-H B | SM |
| <input checked="" type="checkbox"/> | COD | | | 5220 D | SM |
| <input checked="" type="checkbox"/> | TKN | | | 351.2 | R2 |
| <input checked="" type="checkbox"/> | NH ₃ -N | | | 4500-NH ₃ G | SM |
| <input checked="" type="checkbox"/> | Fecal Coliform | <u>2.33 x 10⁵</u> | <u>col/g</u> | 9222 D | SM |
| <input checked="" type="checkbox"/> | Total Phosphorus | | | 4500-P F | SM |
| <input checked="" type="checkbox"/> | Residual Chlorine | | | 4500-Cl G | SM |
| <input checked="" type="checkbox"/> | Ortho-Phosphorus | | | 4500-P F | SM |
| <input checked="" type="checkbox"/> | TOC | | | 5310 B | SM |
| <input checked="" type="checkbox"/> | DO | | | 4500-O C | SM |
| <input checked="" type="checkbox"/> | NO ₃ -N | | | 4500-NO ₃ H | SM |
| <input checked="" type="checkbox"/> | NO ₂ -N | | | 4500-NO ₃ H | SM |
| <input checked="" type="checkbox"/> | Turbidity | | | 2130 B | SM |
| <input checked="" type="checkbox"/> | Hardness | | | 2340 C | SM |
| <input checked="" type="checkbox"/> | Oil & Grease | | | 1664 | R3 |
| <input checked="" type="checkbox"/> | Arsenic | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7060 A |
| <input checked="" type="checkbox"/> | Cadmium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7130 |
| <input checked="" type="checkbox"/> | Chromium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7190 |
| <input checked="" type="checkbox"/> | Copper | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7210 |
| <input checked="" type="checkbox"/> | Lead | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7420 |
| <input checked="" type="checkbox"/> | Mercury | | | 3112 B | SM 7471 B |
| <input checked="" type="checkbox"/> | Molybdenum | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7481 |
| <input checked="" type="checkbox"/> | Nickel | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7520 |
| <input checked="" type="checkbox"/> | Selenium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7740 |
| <input checked="" type="checkbox"/> | Silver | | | 3030 F, 3111B, 3113 B | SM |
| <input checked="" type="checkbox"/> | Zinc | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7950 |
| <input checked="" type="checkbox"/> | Cyanide | | | 4500-CN E | SM |
| <input checked="" type="checkbox"/> | Volatile Organics | | | 6210 D | SM |
| <input checked="" type="checkbox"/> | Semi-Volatile Organics | | | 6410 B | SM |
| <input checked="" type="checkbox"/> | Sulfate | | | 4500-SO ₄ ²⁻ E | SM |
| <input checked="" type="checkbox"/> | 503 METALS | | | | |

SM = Standard Methods, 19th Ed.

R2 = EPA-600/4-79-020

R3 = EPA Method 1664

R4 = EPA SW846

| Biosolids Method | Ref |
|------------------|-----|
| 3050 B, 7060 A | R4 |
| 3050 B, 7130 | R4 |
| 3050 B, 7190 | R4 |
| 3050 B, 7210 | R4 |
| 3050 B, 7420 | R4 |
| 7471 B | R4 |
| 3050 B, 7481 | R4 |
| 3050 B, 7520 | R4 |
| 3050 B, 7740 | R4 |
| 3050 B, 7950 | R4 |

Chain Of Custody / Sample Collection / Request For Analysis

2

Sample ID: **CABABA RIVER WWTP-BIO-SOLIDS**

Primary Measuring Device:

Sample Set-up Date:

Time:

Sampler Type:

First Sample Date:

Time:

Flow Meter Type:

Last Sample Date:

Time:

Sample Interval:

Collection Date: **12-17-13**

Time: **0730**

Sample Type: Grab | Composite

PRESERVATION METHODS:

- A--Iced, 4° C.
- B--Sulfuric Acid to pH < 2
- C--Nitric Acid to pH < 2
- D--NaOH to pH > 11

MUST BE COMPLETED!!

Preservation Method **A**

by: **WWTP**

by **Barton Lab**

Time:

0730

Sample Collected by

Date

Time

Relinquished by

Date

Time

Received by

Date

Time

Relinquished by

Date

Time

Received by

Date

Time

Relinquished by

Date

Time

Received by

Date

Time

Relinquished by

Date

Time

2013121703-01

| Check | Analyte | RESULTS | Units | METHOD Number | Ref |
|-------------------------------------|------------------------|------------------------------|--------------|--------------------------------------|----------------------|
| <input checked="" type="checkbox"/> | BOD ₅ | | | 5210 B | SM |
| <input checked="" type="checkbox"/> | CBOD ₅ | | | 5210 B | SM |
| <input checked="" type="checkbox"/> | TSS | | | 2540 D | SM |
| <input checked="" type="checkbox"/> | pH | | | 4500-H' B | SM |
| <input checked="" type="checkbox"/> | COD | | | 5220 D | SM |
| <input checked="" type="checkbox"/> | TKN | | | 351.2 | R2 |
| <input checked="" type="checkbox"/> | NH ₃ -N | | | 4500-NH ₃ G | SM |
| <input checked="" type="checkbox"/> | Fecal Coliform | 5.38 x 10⁵ | col/g | 9222 D | SM |
| <input checked="" type="checkbox"/> | Total Phosphorus | | | 4500-P F | SM |
| <input checked="" type="checkbox"/> | Residual Chlorine | | | 4500-Cl' G | SM |
| <input checked="" type="checkbox"/> | Ortho-Phosphorus | | | 4500-P F | SM |
| <input checked="" type="checkbox"/> | TOC | | | 5310 B | SM |
| <input checked="" type="checkbox"/> | DO | | | 4500-O C | SM |
| <input checked="" type="checkbox"/> | NO ₃ -N | | | 4500-NO ₃ H | SM |
| <input checked="" type="checkbox"/> | NO ₂ -N | | | 4500-NO ₃ H | SM |
| <input checked="" type="checkbox"/> | Turbidity | | | 2130 B | SM |
| <input checked="" type="checkbox"/> | Hardness | | | 2340 C | SM |
| <input checked="" type="checkbox"/> | Oil & Grease | | | 1664 | R3 |
| <input checked="" type="checkbox"/> | Arsenic | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7060 A R4 |
| <input checked="" type="checkbox"/> | Cadmium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7130 R4 |
| <input checked="" type="checkbox"/> | Chromium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7190 R4 |
| <input checked="" type="checkbox"/> | Copper | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7210 R4 |
| <input checked="" type="checkbox"/> | Lead | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7420 R4 |
| <input checked="" type="checkbox"/> | Mercury | | | 3112 B | SM 7471 B R4 |
| <input checked="" type="checkbox"/> | Molybdenum | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7481 R4 |
| <input checked="" type="checkbox"/> | Nickel | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7520 R4 |
| <input checked="" type="checkbox"/> | Selenium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7740 R4 |
| <input checked="" type="checkbox"/> | Silver | | | 3030 F, 3111B, 3113 B | SM : |
| <input checked="" type="checkbox"/> | Zinc | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7950 R4 |
| <input checked="" type="checkbox"/> | Cyanide | | | 4500-CN E | SM |
| <input checked="" type="checkbox"/> | Volatile Organics | | | 6210 D | SM |
| <input checked="" type="checkbox"/> | Semi-Volatile Organics | | | 6410 B | SM |
| <input checked="" type="checkbox"/> | Sulfate | | | 4500-SO ₄ ²⁻ E | SM |
| <input checked="" type="checkbox"/> | 503 METALS | | | | |

SM = Standard Methods, 19th Ed.

R2 = EPA-600/4-79-020

R3 = EPA Method 1664

R4 = EPA SW846

| Biosolids Method | Ref |
|------------------|-----|
| 3050 B, 7060 A | R4 |
| 3050 B, 7130 | R4 |
| 3050 B, 7190 | R4 |
| 3050 B, 7210 | R4 |
| 3050 B, 7420 | R4 |
| 7471 B | R4 |
| 3050 B, 7481 | R4 |
| 3050 B, 7520 | R4 |
| 3050 B, 7740 | R4 |
| 3050 B, 7950 | R4 |

2013121703-01

Alabam... County Commission Environmental Service Department
 Chain Of Custody / Sample Collection / Request For Analysis

3

Sample ID: CAHABA RIVER WWTP-BIO-SOLIDS

Primary Measuring Device:

Sample Set-up Date:

Time:

Sampler Type:

First Sample Date:

Time:

Flow Meter Type:

Last Sample Date:

Time:

Sample Interval:

Collection Date: 12-17-13

Time: 0730

Sample Type: Grab | Composite

PRESERVATION METHODS:

- A--Iced, 4° C.
- B--Sulfuric Acid to pH < 2
- C--Nitric Acid to pH < 2
- D--NaOH to pH > 11

MUST BE COMPLETED!!

Preservation Method A

by: WWTP

by Berton Lab

Time:

0730

Sample Collected by

Date: 12-17-13

Time: 0730

Relinquished by

Date: 12-17-13

Time: 0845

Received by

Date: 12-17-13

Time: 0845

Relinquished by

Date: 12-17-13

Time: 0901

Received by

Date: 12/17/13

Time: 0908

Relinquished by

Date: 12/17/13

Time: 1010

Received by

Date: 12/17/13

Time: 1010

Relinquished by

Date: 12/17/13

Time: 1010

2013121703-0

2013121703-01

SM =
Standard Methods,
19th Ed.

R2 =
EPA-600/4-79-020

R3 =
EPA Method 1664

R4 =
EPA SW846

| Check | Analyte | RESULTS | Units | METHOD Number | Ref |
|-------------------------------------|------------------------|------------------------|-------|--------------------------------------|-------------------|
| <input checked="" type="checkbox"/> | BOD ₅ | | | 5210 B | SM |
| <input checked="" type="checkbox"/> | CBOD ₅ | | | 5210 B | SM |
| <input checked="" type="checkbox"/> | TSS | | | 2540 D | SM |
| <input checked="" type="checkbox"/> | pH | | | 4500-H ⁺ B | SM |
| <input checked="" type="checkbox"/> | COD | | | 5220 D | SM |
| <input checked="" type="checkbox"/> | TKN | | | 351.2 | R2 |
| <input checked="" type="checkbox"/> | NH ₃ -N | | | 4500-NH ₃ G | SM |
| <input checked="" type="checkbox"/> | Fecal Coliform | 3.25 x 10 ⁵ | col/g | 9222 D | SM |
| <input checked="" type="checkbox"/> | Total Phosphorus | | | 4500-PF | SM |
| <input checked="" type="checkbox"/> | Residual Chlorine | | | 4500-Cl ⁻ G | SM |
| <input checked="" type="checkbox"/> | Ortho-Phosphorus | | | 4500-P F | SM |
| <input checked="" type="checkbox"/> | TOC | | | 5310 B | SM |
| <input checked="" type="checkbox"/> | DO | | | 4500-O C | SM |
| <input checked="" type="checkbox"/> | NO ₃ -N | | | 4500-NO ₃ H | SM |
| <input checked="" type="checkbox"/> | NO ₂ -N | | | 4500-NO ₃ H | SM |
| <input checked="" type="checkbox"/> | Turbidity | | | 2130 B | SM |
| <input checked="" type="checkbox"/> | Hardness | | | 2340 C | SM |
| <input checked="" type="checkbox"/> | Oil & Grease | | | 1664 | R3 |
| <input checked="" type="checkbox"/> | Arsenic | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7060 A |
| <input checked="" type="checkbox"/> | Cadmium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7130 |
| <input checked="" type="checkbox"/> | Chromium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7190 |
| <input checked="" type="checkbox"/> | Copper | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7210 |
| <input checked="" type="checkbox"/> | Lead | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7420 |
| <input checked="" type="checkbox"/> | Mercury | | | 3112 B | SM 7471 B |
| <input checked="" type="checkbox"/> | Molybdenum | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7481 |
| <input checked="" type="checkbox"/> | Nickel | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7520 |
| <input checked="" type="checkbox"/> | Selenium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7740 |
| <input checked="" type="checkbox"/> | Silver | | | 3030 F, 3111B, 3113 B | SM ; |
| <input checked="" type="checkbox"/> | Zinc | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7950 |
| <input checked="" type="checkbox"/> | Cyanide | | | 4500-CN E | SM |
| <input checked="" type="checkbox"/> | Volatile Organics | | | 6210 D | SM |
| <input checked="" type="checkbox"/> | Semi-Volatile Organics | | | 6410 B | SM |
| <input checked="" type="checkbox"/> | Sulfate | | | 4500-SO ₄ ²⁻ E | SM |
| <input checked="" type="checkbox"/> | 503 METALS | | | | |

County Commission Environmental Service Department
Chain Of Custody / Sample Collection / Request For Analysis

Sample ID: CAHABA RIVER WWTP-BIO-SOLIDS

Sample Set-up Date: _____ Time: _____ Primary Measuring Device: _____
 First Sample Date: _____ Time: _____ Sampler Type: _____
 Last Sample Date: _____ Time: _____ Flow Meter Type: _____
 Collection Date: 12-17-13 Time: 0730 Sample Interval: _____
 Sample Split? Yes No Sample Type: Grab Composite
 [TVVC/TCVC/TCVV]

PRESERVATION METHODS:
 A--Iced, 4° C.
 B--Sulfuric Acid to pH < 2
 C--Nitric Acid to pH < 2
 D--NaOH to pH > 11

MUST BE COMPLETED!! → Preservation Method A by: WWTP by Barton Lab Time: 0730

Sample Collected by: [Signature] Date: 12-17-13 Time: 0845 Relinquished by: [Signature] Date: 12-17-13 Time: 0845

Received by: [Signature] Date: 12/17/13 Time: 0908 Relinquished by: [Signature] Date: 12/17/13 Time: 0908

Received by: [Signature] Date: 12/17/13 Time: 1022 Relinquished by: [Signature] Date: 12/17/13 Time: 1052

2013121701

201312170301

| Check | Analyte | RESULTS | Units | METHOD Number | Ref |
|-------------------------------------|---------------------------------|------------------------|-------|--------------------------------------|----------------------|
| <input checked="" type="checkbox"/> | BOD ₅ | | | 5210 B | SM |
| <input checked="" type="checkbox"/> | CBOD ₅ | | | 5210 B | SM |
| <input checked="" type="checkbox"/> | TSS | | | 2540 D | SM |
| <input checked="" type="checkbox"/> | pH | | | 4500-H ⁺ B | SM |
| <input checked="" type="checkbox"/> | COD | | | 5220 D | SM |
| <input checked="" type="checkbox"/> | TKN | | | 351.2 | R2 |
| <input checked="" type="checkbox"/> | NH ₃ -N | | | 4500-NH ₃ G | SM |
| <input checked="" type="checkbox"/> | Fecal Coliform | 3.00 x 10 ⁵ | col/g | 9222 D | SM |
| <input checked="" type="checkbox"/> | Total Phosphorus | | | 4500-P F | SM |
| <input checked="" type="checkbox"/> | Residual Chlorine | | | 4500-Cl ⁻ G | SM |
| <input checked="" type="checkbox"/> | Ortho-Phosphorus | | | 4500-P F | SM |
| <input checked="" type="checkbox"/> | TOC | | | 5310 B | SM |
| <input checked="" type="checkbox"/> | DO | | | 4500-O C | SM |
| <input checked="" type="checkbox"/> | NO ₃ ⁻ -N | | | 4500-NO ₃ ⁻ H | SM |
| <input checked="" type="checkbox"/> | NO ₂ ⁻ -N | | | 4500-NO ₃ ⁻ H | SM |
| <input checked="" type="checkbox"/> | Turbidity | | | 2130 B | SM |
| <input checked="" type="checkbox"/> | Hardness | | | 2340 C | SM |
| <input checked="" type="checkbox"/> | Oil & Grease | | | 1664 | R3 |
| <input checked="" type="checkbox"/> | Arsenic | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7060 A R4 |
| <input checked="" type="checkbox"/> | Cadmium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7130 R4 |
| <input checked="" type="checkbox"/> | Chromium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7190 R4 |
| <input checked="" type="checkbox"/> | Copper | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7210 R4 |
| <input checked="" type="checkbox"/> | Lead | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7420 R4 |
| <input checked="" type="checkbox"/> | Mercury | | | 3112 B | SM 7471 B R4 |
| <input checked="" type="checkbox"/> | Molybdenum | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7481 R4 |
| <input checked="" type="checkbox"/> | Nickel | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7520 R4 |
| <input checked="" type="checkbox"/> | Selenium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7740 R4 |
| <input checked="" type="checkbox"/> | Silver | | | 3030 F, 3111B, 3113 B | SM : |
| <input checked="" type="checkbox"/> | Zinc | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7950 R4 |
| <input checked="" type="checkbox"/> | Cyanide | | | 4500-CN E | SM |
| <input checked="" type="checkbox"/> | Volatile Organics | | | 6210 D | SM |
| <input checked="" type="checkbox"/> | Semi-Volatile Organics | | | 6410 B | SM |
| <input checked="" type="checkbox"/> | Sulfate | | | 4500-SO ₄ ²⁻ E | SM |
| <input checked="" type="checkbox"/> | 503 METALS | | | | |

SM = Standard Methods, 19th Ed.

R2 = EPA-600/4-79-020

R3 = EPA Method 1664

R4 = EPA SW846

| Biosolids Method | Ref |
|------------------|-----|
| 3050 B, 7060 A | R4 |
| 3050 B, 7130 | R4 |
| 3050 B, 7190 | R4 |
| 3050 B, 7210 | R4 |
| 3050 B, 7420 | R4 |
| 7471 B | R4 |
| 3050 B, 7481 | R4 |
| 3050 B, 7520 | R4 |
| 3050 B, 7740 | R4 |
| 3050 B, 7950 | R4 |

Anderson County Commission Environmental Service Department
Chain Of Custody / Sample Collection / Request For Analysis

5

Sample ID: CAHABA RIVER WWTP-BIO-SOLIDS

Primary Measuring Device:

Sample Set-up Date:

Time:

Sampler Type:

First Sample Date:

Time:

Flow Meter Type:

Last Sample Date:

Time:

Sample Interval:

Collection Date: 12-17-13

Time: 0730

Sample Type: Grab Composite

PRESERVATION METHODS:

- A--Iced, 4° C.
- B--Sulfuric Acid to pH < 2
- C--Nitric Acid to pH < 2
- D--NaOH to pH > 11

Sample Split? Yes No

[TVC / TCVC / TCVV]

MUST BE COMPLETED!! → Preservation Method A by: WWTP by Barton Lab Time: 0730

Sample Collected by: [Signature] Date: 12-17-13 Time: 0730

Relinquished by: [Signature] Date: 12-17-13 Time: 0845

Received by: [Signature] Date: 12-17-13 Time: 0845

Relinquished by: [Signature] Date: 12-17-13 Time: 0908

Received by: [Signature] Date: 12/17/13 Time: 0908

Relinquished by: [Signature] Date: 12/17/13 Time: 1000

Received by: [Signature] Date: 12/17/13 Time: 1000

Relinquished by: [Signature] Date: 12/17/13 Time: 1000

2013121703-0

2013121703-01

| Check | Analyte | RESULTS | Units | METHOD Number | Ref |
|-------------------------------------|------------------------|------------------------|-------|--------------------------------------|-------------------|
| <input checked="" type="checkbox"/> | BOD ₅ | | | 5210 B | SM |
| <input checked="" type="checkbox"/> | CBOD ₅ | | | 5210 B | SM |
| <input checked="" type="checkbox"/> | TSS | | | 2540 D | SM |
| <input checked="" type="checkbox"/> | pH | | | 4500-H B | SM |
| <input checked="" type="checkbox"/> | COD | | | 5220 D | SM |
| <input checked="" type="checkbox"/> | TKN | | | 351.2 | R2 |
| <input checked="" type="checkbox"/> | NH ₃ -N | | | 4500-NH ₃ G | SM |
| <input checked="" type="checkbox"/> | Fecal Coliform | 4.00 x 10 ⁵ | col/g | 9222 D | SM |
| <input checked="" type="checkbox"/> | Total Phosphorus | | | 4500-P F | SM |
| <input checked="" type="checkbox"/> | Residual Chlorine | | | 4500-Cl G | SM |
| <input checked="" type="checkbox"/> | Ortho-Phosphorus | | | 4500-P F | SM |
| <input checked="" type="checkbox"/> | TOC | | | 5310 B | SM |
| <input checked="" type="checkbox"/> | DO | | | 4500-O C | SM |
| <input checked="" type="checkbox"/> | NO ₃ -N | | | 4500-NO ₃ H | SM |
| <input checked="" type="checkbox"/> | NO ₂ -N | | | 4500-NO ₃ H | SM |
| <input checked="" type="checkbox"/> | Turbidity | | | 2130 B | SM |
| <input checked="" type="checkbox"/> | Hardness | | | 2340 C | SM |
| <input checked="" type="checkbox"/> | Oil & Grease | | | 1664 | R3 |
| <input checked="" type="checkbox"/> | Arsenic | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7060 A |
| <input checked="" type="checkbox"/> | Cadmium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7130 |
| <input checked="" type="checkbox"/> | Chromium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7190 |
| <input checked="" type="checkbox"/> | Copper | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7210 |
| <input checked="" type="checkbox"/> | Lead | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7420 |
| <input checked="" type="checkbox"/> | Mercury | | | 3030 E, 3111B, 3113 B | SM 7471 B |
| <input checked="" type="checkbox"/> | Molybdenum | | | 3112 B | SM 3050 B, 7481 |
| <input checked="" type="checkbox"/> | Nickel | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7520 |
| <input checked="" type="checkbox"/> | Selenium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7740 |
| <input checked="" type="checkbox"/> | Silver | | | 3030 F, 3111B, 3113 B | SM : |
| <input checked="" type="checkbox"/> | Zinc | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7950 |
| <input checked="" type="checkbox"/> | Cyanide | | | 4500-CN E | SM |
| <input checked="" type="checkbox"/> | Volatile Organics | | | 6210 D | SM |
| <input checked="" type="checkbox"/> | Semi-Volatile Organics | | | 6410 B | SM |
| <input checked="" type="checkbox"/> | Sulfate | | | 4500-SO ₄ ²⁻ E | SM |
| <input checked="" type="checkbox"/> | 503 METALS | | | | |

SM = Standard Methods, 19th Ed.

R2 = EPA-600/4-79-020

R3 = EPA Method 1664

R4 = EPA SW846

| Biosolids Method | Ref |
|------------------|-----|
| 3050 B, 7060 A | R4 |
| 3050 B, 7130 | R4 |
| 3050 B, 7190 | R4 |
| 3050 B, 7210 | R4 |
| 3050 B, 7420 | R4 |
| 7471 B | R4 |
| 3050 B, 7481 | R4 |
| 3050 B, 7520 | R4 |
| 3050 B, 7740 | R4 |
| 3050 B, 7950 | R4 |

Marion County Commission Environmental Service Department
Chain Of Custody / Sample Collection / Request For Analysis

6

Sample ID: CAHABA RIVER WWTP-BIO-SOLIDS

Primary Measuring Device:

Sample Set-up Date:

Time:

Sampler Type:

First Sample Date:

Time:

Flow Meter Type:

Last Sample Date:

Time:

Sample Interval:

Collection Date: 12-17-13

Time: 0730

Sample Type: Grab Composite
[TVVC/TCVC/TCVV]

PRESERVATION METHODS:
A--Iced, 4° C.
B--Sulfuric Acid to pH < 2
C--Nitric Acid to pH < 2
D--NaOH to pH > 11

MUST BE COMPLETED!! → Preservation Method A by: WWTP by Barton Lab Time: 0730

2013 121705-01

Sample Collected by: *[Signature]* Date: 12-17-13 Time: 0730

Relinquished by: *[Signature]* Date: 12-17-13 Time: 0845

Received by: *[Signature]* Date: 12-17-13 Time: 0845

Relinquished by: *[Signature]* Date: 12-17-13 Time: 0908

Received by: *[Signature]* Date: 12/17/13 Time: 0908

Relinquished by: *[Signature]* Date: 12/17/13 Time: 1012

Received by: *[Signature]* Date: 12/17/13 Time: 1012

| Check | Analyte | RESULTS | Units | METHOD Number | Ref |
|-------------------------------------|---------------------------------|------------------------|-------|--------------------------------------|-------------------|
| <input checked="" type="checkbox"/> | BOD ₅ | | | 5210 B | SM |
| <input checked="" type="checkbox"/> | CBOD ₅ | | | 5210 B | SM |
| <input checked="" type="checkbox"/> | TSS | | | 2540 D | SM |
| <input checked="" type="checkbox"/> | pH | | | 4500-H B | SM |
| <input checked="" type="checkbox"/> | COD | | | 5220 D | SM |
| <input checked="" type="checkbox"/> | TKN | | | 351.2 | R2 |
| <input checked="" type="checkbox"/> | NH ₃ -N | | | 4500-NH ₃ G | SM |
| <input checked="" type="checkbox"/> | Fecal Coliform | 6.14 x 10 ⁵ | col/g | 9222 D | SM |
| <input checked="" type="checkbox"/> | Total Phosphorus | | | 4500-P F | SM |
| <input checked="" type="checkbox"/> | Residual Chlorine | | | 4500-Cl G | SM |
| <input checked="" type="checkbox"/> | Ortho-Phosphorus | | | 4500-P F | SM |
| <input checked="" type="checkbox"/> | TOC | | | 5310 B | SM |
| <input checked="" type="checkbox"/> | DO | | | 4500-O C | SM |
| <input checked="" type="checkbox"/> | NO ₃ ⁻ -N | | | 4500-NO ₃ ⁻ H | SM |
| <input checked="" type="checkbox"/> | NO ₂ ⁻ -N | | | 4500-NO ₃ ⁻ H | SM |
| <input checked="" type="checkbox"/> | Turbidity | | | 2130 B | SM |
| <input checked="" type="checkbox"/> | Hardness | | | 2340 C | SM |
| <input checked="" type="checkbox"/> | Oil & Grease | | | 1664 | R3 |
| <input checked="" type="checkbox"/> | Arsenic | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7060 A |
| <input checked="" type="checkbox"/> | Cadmium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7130 |
| <input checked="" type="checkbox"/> | Chromium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7190 |
| <input checked="" type="checkbox"/> | Copper | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7210 |
| <input checked="" type="checkbox"/> | Lead | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7420 |
| <input checked="" type="checkbox"/> | Mercury | | | 3112 B | SM 7471 B |
| <input checked="" type="checkbox"/> | Molybdenum | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7481 |
| <input checked="" type="checkbox"/> | Nickel | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7520 |
| <input checked="" type="checkbox"/> | Selenium | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7740 |
| <input checked="" type="checkbox"/> | Silver | | | 3030 F, 3111B, 3113 B | SM |
| <input checked="" type="checkbox"/> | Zinc | | | 3030 E, 3111B, 3113 B | SM 3050 B, 7950 |
| <input checked="" type="checkbox"/> | Cyanide | | | 4500-CN E | SM |
| <input checked="" type="checkbox"/> | Volatile Organics | | | 6210 D | SM |
| <input checked="" type="checkbox"/> | Semi-Volatile Organics | | | 6410 B | SM |
| <input checked="" type="checkbox"/> | Sulfate | | | 4500-SO ₄ ²⁻ E | SM |
| <input checked="" type="checkbox"/> | 503 METALS | | | | |

SM = Standard Methods, 19th Ed.

R2 = EPA-600/4-79-020

R3 = EPA Method 1664

R4 = EPA SW846

| Biosolids Method | Ref |
|------------------|-----|
| | R4 |
| | R4 |
| | R4 |
| | R4 |
| | R4 |
| | R4 |
| | R4 |
| | R4 |
| | R4 |
| | R4 |

2013 121705-01

Johnson County Commission Environmental Service Department
 Chain Of Custody / Sample Collection / Request For Analysis

Sample ID: CAHABA RIVER WWTP-BIO-SOLIDS

Sample Set-up Date: _____ Time: _____ Primary Measuring Device: _____

First Sample Date: _____ Time: _____ Sampler Type: _____

Last Sample Date: _____ Time: _____ Flow Meter Type: _____

Collection Date: 12-17-13 Time: 0730 Sample Interval: _____

Sample Split? Yes No Sample Type: Grab Composite [TVVC / TCVC / TCVV]

MUST BE COMPLETED!! → Preservation Method A by: WWTP by Barton Lab Time: 0730

PRESERVATION METHODS:
 A--Iced, 4° C.
 B--Sulfuric Acid to pH < 2
 C--Nitric Acid to pH < 2
 D--NaOH to pH > 11

2013121705-01

Sample Collected by: *[Signature]* Date: 12-17-13 Time: 0730 Relinquished by: *[Signature]* Date: 12-17-13 Time: 0845

Received by: *[Signature]* Date: 12-17-13 Time: 0908 Relinquished by: *[Signature]* Date: 12-17-13 Time: 0908

Received by: *[Signature]* Date: 12/17/13 Time: 1050 Relinquished by: *[Signature]* Date: 12/18/13 Time: 1050

| Check | Analyte | RESULTS | Units | METHOD Number | Ref |
|-------------------------------------|---------------------------------|---------|-------|--------------------------------------|-----|
| <input checked="" type="checkbox"/> | moisture | 88 | % | 5210 B | SM |
| <input checked="" type="checkbox"/> | CBOD ₅ | | | 5210 B | SM |
| | TSS | | | 2540 D | SM |
| | pH | | | 4500-H ⁺ B | SM |
| | COD | | | 5220 D | SM |
| | TKN | | | 351.2 | R2 |
| | NH ₃ -N | | | 4500-NH ₃ G | SM |
| <input checked="" type="checkbox"/> | Fecal Coliform | 390,000 | col/g | 9222 D | SM |
| | Total Phosphorus | | | 4500-P F | SM |
| | Residual Chlorine | | | 4500-Cl G | SM |
| | Ortho-Phosphorus | | | 4500-P F | SM |
| | TOC | | | 5310 B | SM |
| | DO | | | 4500-O C | SM |
| | NO ₃ ⁻ -N | | | 4500-NO ₃ ⁻ H | SM |
| | NO ₂ ⁻ -N | | | 4500-NO ₂ ⁻ H | SM |
| | Turbidity | | | 2130 B | SM |
| | Hardness | | | 2340 C | SM |
| | Oil & Grease | | | 1664 | R3 |
| | Arsenic | | | 3030 E, 3111B, 3113 B | SM |
| | Cadmium | | | 3030 E, 3111B, 3113 B | SM |
| | Chromium | | | 3030 E, 3111B, 3113 B | SM |
| | Copper | | | 3030 E, 3111B, 3113 B | SM |
| | Lead | | | 3030 E, 3111B, 3113 B | SM |
| <input checked="" type="checkbox"/> | Mercury | | | 3030 E, 3111B, 3113 B | SM |
| | Molybdenum | | | 3112 B | SM |
| | Nickel | | | 3030 E, 3111B, 3113 B | SM |
| | Selenium | | | 3030 E, 3111B, 3113 B | SM |
| | Silver | | | 3030 E, 3111B, 3113 B | SM |
| | Zinc | | | 3030 F, 3111B, 3113 B | SM |
| | Cyanide | | | 3030 E, 3111B, 3113 B | SM |
| | Volatile Organics | | | 4500-CN E | SM |
| | Semi-Volatile Organics | | | 6210 D | SM |
| | Sulfate | | | 6410 B | SM |
| <input checked="" type="checkbox"/> | 503 METALS | | | 4500-SO ₄ ²⁻ E | SM |

SM = Standard Methods, 19th Ed.

R2 = EPA-600/4-79-020

R3 = EPA Method 1664

R4 = EPA SW846

| Biosolids Method | Ref |
|------------------|-----|
| 3050 B, 7060 A | R4 |
| 3050 B, 7130 | R4 |
| 3050 B, 7190 | R4 |
| 3050 B, 7210 | R4 |
| 3050 B, 7420 | R4 |
| 7471 B | R4 |
| 3050 B, 7481 | R4 |
| 3050 B, 7520 | R4 |
| 3050 B, 7740 | R4 |
| 3050 B, 7950 | R4 |

2013121705-01

Barton Laboratory
BIOSOLIDS BACTERIAL ANALYSIS

Analysis Date: 12/17/13
 Date / Time In: 12/17 1 1230
 Date / Time Read: 12/18 1 1230

Sample ID: Cahaba
 Sample Date / Time: 12/17/13 1 0730
 Lab Analyst: TR

TEST(S) PERFORMED:

- Fecal Coliform
 Total Coliform
 Fecal Strep
 Other

Summary of Geometric Mean Calculations:
 G.M. = 390,000 colonies per gram of dry solids.

| | Dilution Used or mL of Sample | Colonies Counted | % Dry Solids | pH | Colonies Counted X 100 mL Sample X % Dry Solid | of log Geometric Mean |
|-------|-------------------------------|------------------|--------------|----|---|--------------------------------|
| | | | | | | $\sqrt[N]{(X_1)(X_2)...(X_N)}$ |
| ① | .001 | 28 | 12 | | $\frac{2800}{.001 \times 12} = 2.33 \times 10^5$ | 5.37 |
| ② | .0011 | 71 | 12 | | $\frac{7100}{.0011 \times 12} = 5.38 \times 10^5$ | 5.73 |
| ③ | .001 | 39 | 12 | | $\frac{3900}{.001 \times 12} = 3.25 \times 10^5$ | 5.51 |
| ④ | .001 | 36 | 12 | | $\frac{3600}{.001 \times 12} = 3.00 \times 10^5$ | 5.48 |
| ⑤ | .001 | 48 | 12 | | $\frac{4800}{.001 \times 12} = 4.00 \times 10^5$ | 5.60 |
| ⑥ | .0011 | 81 | 12 | | $\frac{8100}{.0011 \times 12} = 6.14 \times 10^5$ | 5.79 |
| ⑦ | .001 | 58 | 12 | | $\frac{5800}{.001 \times 12} = 4.83 \times 10^5$ | 5.68 |
| 8 | | | | | | |
| 9 | Avg % Solids | 12% | | | | $\bar{X} = 5.59$ |
| 10 | Avg % Moisture | 88% | | | | |
| Blank | .01 | 0 | | | | |

G.M. = 390,000 colonies per gram of dry solids.

Barton Laboratory
BIOSOLIDS
Coliform Colonies Counted

Sample ID: Calhade

Sample

Date / Time: 12/17/13 , 12:30 0730

Date / Time

Counted: 12/18/13 , 1230

Lab Analyst: T. Riley

COLIFORM COLONIES COUNTED

| % Solids | Sample Number | 0.01 | 0.001 | 0.0001 | 0.00001 | 0.000001 |
|----------|---------------|---------------|---------------|---------------|---------------|---------------|
| | | mL Filtration | mL Filtration | mL Filtration | mL Filtration | mL Filtration |
| | 1 | TNTC | 6028 | 2 | | |
| | 2 | | 64 | 7 | | |
| | 3 | | 39 | 7 | | |
| | 4 | | 36 | 4 | | |
| | 5 | | 48 | 3 | | |
| | 6 | | 72 | 9 | | |
| | 7 | ↓ | 58 | 7 | | |
| | 8 | | | | | |
| | 9 | | | | | |
| | 10 | | | | | |
| | Blank | 0 | 0 | 0 | | |

SECTION 5
AGRONOMIC RATE INFORMATION
AND CALCULATIONS

AGRONOMIC RATE BELTONA LAND RECLAMATION SITE

Summary:

The Beltona Land Reclamation Site is a former strip mine site located in northwestern Jefferson County. The Environmental Services Department is assisting the property owner in the reclamation of this site through the land application of biosolids. In the areas that have not received any biosolids applications, no vegetation other than "scrub" vegetation is present and growing. In the areas that have received biosolids applications, Tifton Bermuda and Rye grass has been planted for nitrogen uptake.

The local Agricultural Cooperative Extension Service has recommended a fertilizer rate of 600 lb Nitrogen/Ac/year for the mine reclamation site. These calculations are based on six cuttings of hay each year (four harvests of Bermuda grass and two harvests of Rye grass each year), with 100 lb Nitrogen per acre needed for each cutting.

Agronomic Rate Considerations:

- 1) The Agronomic Calculations presented in this report are based on an extension bulletin worksheet entitled "Calculating Biosolids Application Rates in Agriculture" (1998), developed by Craig Cogger and Dan Sullivan for the Pacific Northwest. This bulletin uses widely accepted procedures for nitrogen budgeting which are applicable across the United States.
- 2) During analysis, NH_4^+ -N is often converted to NH_3 -N and analytical results are then reported as NH_3 -N. Both forms are plant available and this combined analysis does not diminish the quality of the result.
- 3) There is no additional nitrogen applied to the reclamation site by Jefferson County (no fertilizer or irrigation water).
- 4) Biosolids from the Valley and Village WWTP's are applied to each plot on an annual basis throughout the winter months. These biosolids are anaerobically digested, mechanically dewatered, and lime stabilized, and are not incorporated into the soil following land application.
- 5) Biosolids were applied at a rate of 11 dry tons/acre.

AGRONOMIC RATE CALCULATIONS – BELTONA LAND RECLAMATION SITE

FORMULA:

Plant Available Nitrogen (PAN) = Available Organic Nitrogen + Inorganic Nitrogen
= [(Organic Nitrogen)(Organic Mineralization Rate)] + [(NH₄)(%NH₄ Retained) + Nitrate]

GIVEN:

- During analysis, NH₄⁺ -N is converted to NH₃-N and analytical results are then reported as NH₃-N. This combined analysis does not diminish the quality of the result.
- The TKN, NH₃ and NO₃ results are averages of data available during 2013. All results are reported on a dry-weight basis.

TKN_(average) = 37,000 mg/Kg x 0.002 (converts mg/Kg to lb/dry ton) = 74.0 lb/dry ton

NH₃_(average) = 1,183 mg/Kg x 0.002 = 2.4 lb/dry ton

NO₃_(average) = 271 mg/Kg x 0.002 = 0.5 lb/dry ton

Organic Nitrogen = TKN - NH₃ - NO₃ = 74.0 – 2.4 – 0.5 = 71.1 lb N/dry ton

- Calculations for the Beltona site are performed considering anaerobically digested, dewatered, and lime stabilized biosolids.

NITROGEN CREDITS FOR PREVIOUS BIOSOLIDS APPLICATIONS:

- Biosolids that were applied from 2009 through 2012 had an average Organic Nitrogen content of 31,463 mg/kg. These biosolids were applied at an average rate of 21 dry tons per acre. Using Table 1 of the Worksheet:

Nitrogen Credit for 31,463 mg/kg:

= 8.1 lb PAN per dry ton (years 2-5) x 21 dry tons per acre

= 170 lb PAN per acre Nitrogen credit

- Tifton Bermuda/Rye grass nitrogen requirements = 600 lb N/Ac/Yr (based on Agricultural Cooperative Extension Service recommendation of six cuttings of hay each year with 100 lb N/Ac needed for each cutting). **With a Nitrogen Credit of 170 lb/acre, approximately 430 lb N/Ac/year is needed from the current applications of biosolids.**

AGRONOMIC RATE CALCULATIONS – BELTONA LAND RECLAMATION SITE

CALCULATIONS:

Anaerobically Digested, Dewatered, Lime Stabilized, Not Incorporated

$$\text{TKN}_{(\text{average})} = 37,000 \text{ mg/Kg} \times 0.002 \text{ (converts mg/Kg to lb/dry ton)} = 74.0 \text{ lb/dry ton}$$

$$\text{NH}_3_{(\text{average})} = 1,183 \text{ mg/Kg} \times 0.002 = 2.4 \text{ lb/dry ton}$$

$$\text{NO}_3_{(\text{average})} = 271 \text{ mg/Kg} \times 0.002 = 0.5 \text{ lb/dry ton}$$

$$\text{Organic Nitrogen} = \text{TKN} - \text{NH}_3 - \text{NO}_3 = 74.0 - 2.4 - 0.5 = 71.1 \text{ lb N/dry ton}$$

Organic Nitrogen:

Mineralization Rate (Worksheet, Table 3): Anaerobic Digestion, Dewatered = 20% – 40%

Percent of Organic N available in the first year = 30% (average)

Total Organic Nitrogen available in the first year = $71.1 \times 30\% = \underline{21.3 \text{ lb/dry ton}}$

Ammonium Nitrogen:

% NH₄ Retained (Worksheet, Table 2): Not Incorporated, Lime Stabilized = 10%

Percent of Ammonia retained after application = 10%

Ammonium Nitrogen retained after application = $2.4 \text{ lb/dry ton} \times 10\% = \underline{0.2 \text{ lb/dry ton}}$

Estimated Plant Available Nitrogen (PAN):

PAN = Available Organic Nitrogen + Inorganic Nitrogen = $21.3 + 0.2 + 0.5 = \underline{22 \text{ lb N/dt}}$

Agronomic Rate:

$430 \text{ lb N/Ac/year} \div 22 \text{ lb N/dry ton} = \underline{20 \text{ dry tons/Acre/year}}$

Biosolids were applied at the Beltona site throughout 2013 at a rate of 11 dry tons per acre. As can be seen from the above calculations, and as required by the 40 CFR Part 503 regulations, the anaerobically digested biosolids are being applied at a rate equal to or less than the agronomic rate for the crops grown.

AGRONOMIC RATE FLAT TOP/BESSIE MINES LAND RECLAMATION SITE

Summary:

The Flat Top/Bessie Mines Land Reclamation Site is also a former strip mine site located in northwestern Jefferson County. The Environmental Services Department is assisting the property owner in the reclamation of this site through the land application of biosolids. At this site there is currently no soil mass present for growing vegetation, and in order to build soil mass, biosolids are recommended to be applied at a rate of 600 lb Nitrogen/Ac/year. When soil mass becomes adequate to sustain crop growth, Tifton Bermuda and Rye grass will be planted for nitrogen uptake.

Agronomic Rate Considerations:

- 1) There is no additional nitrogen applied to the reclamation site by Jefferson County (no fertilizer or irrigation water) and there is very little to no plant available nitrogen currently present at the site.
- 2) Approximately 62% of the land applied biosolids were anaerobically digested, followed by either mechanical dewatering or drying beds. The remaining biosolids were aerobically digested, followed by either mechanical dewatering or drying beds. Calculations were performed considering the three biosolids treatment and dewatering scenarios.
- 3) Typically, the anaerobically digested biosolids are lime stabilized.
- 4) Biosolids from all plants are incorporated into the soil within six (6) hours of application.
- 5) Biosolids applications currently occur on a year-round basis at a rate of 22 dry tons/acre.

AGRONOMIC RATE CALCULATIONS – FLAT TOP/BESSIE MINES LAND RECLAMATION SITE

FORMULA:

Plant Available Nitrogen (PAN) = Available Organic Nitrogen + Inorganic Nitrogen
= [(Organic Nitrogen)(Organic Mineralization Rate)] + [(NH₄)(%NH₄ Retained) + Nitrate]

GIVEN:

- During analysis, NH₄⁺ -N is converted to NH₃-N and analytical results are then reported as NH₃-N. This combined analysis does not diminish the quality of the result.
- The TKN, NH₃ and NO₃ results are averages of data available during 2013. All results are reported on a dry-weight basis.

TKN_(average) = 37,000 mg/Kg x 0.002 (converts mg/Kg to lb/dry ton) = 74.0 lb/dry ton

NH_{3(average)} = 1,183 mg/Kg x 0.002 = 2.4 lb/dry ton

NO_{3(average)} = 271 mg/Kg x 0.002 = 0.5 lb/dry ton

Organic Nitrogen = TKN - NH₃ - NO₃ = 74.0 – 2.4 – 0.5 = 71.1 lb N/dry ton

- Being a reclamation site, biosolids are applied at a rate of 600 lb N/Ac/Yr to build soil mass. When soil mass becomes adequate to sustain crop growth, Tifton Bermuda and Rye grass will be planted for nitrogen uptake.
- Calculations will be performed considering both biosolids scenarios: (1) anaerobically digested, dewatered, and lime stabilized, and (2) aerobically digested, mechanically dewatered or drying beds, and incorporated into the soil within six hours of application.

**AGRONOMIC RATE CALCULATIONS –
FLAT TOP/BESSIE MINES LAND RECLAMATION SITE**

CALCULATIONS:

Anaerobically Digested, Dewatered, Lime Stabilized, Incorporated within Six Hours

-and-

Aerobically Digested, Mechanically Dewatered or Drying Beds, Incorporated within Six Hours

$TKN_{(average)} = 37,000 \text{ mg/Kg} \times 0.002 \text{ (converts mg/Kg to lb/dry ton)} = 74.0 \text{ lb/dry ton}$

$NH_{3(average)} = 1,183 \text{ mg/Kg} \times 0.002 = 2.4 \text{ lb/dry ton}$

$NO_{3(average)} = 271 \text{ mg/Kg} \times 0.002 = 0.5 \text{ lb/dry ton}$

Organic Nitrogen = $TKN - NH_3 - NO_3 = 74.0 - 2.4 - 0.5 = 71.1 \text{ lb N/dry ton}$

Organic Nitrogen:

Mineralization Rate (Worksheet, Table 3): Anaerobic Digestion, Dewatered = 20%-40%
Aerobic Digestion = 30% – 45%
Drying Beds = 15%-30%

Percent of Organic N available in the first year = 29% (weighted average)

Total Organic Nitrogen available in the first year = $71.1 \times 29\% = \underline{20.6 \text{ lb/dry ton}}$

Ammonium Nitrogen:

% NH_4 Retained (Worksheet, Table 2): Incorporated (0-2 Days), Dewatered = 60%,
Incorporated (0-2 Days), Drying Bed = 100%
Incorporated (0-2 Days), Alkaline Stabilized = 10%

Percent of Ammonia retained after application = 52% (weighted average)

Ammonium Nitrogen retained after application = $2.4 \text{ lb/dry ton} \times 52\% = \underline{1.25 \text{ lb /dry ton}}$

Estimated Plant Available Nitrogen (PAN):

$PAN = \text{Available Organic Nitrogen} + \text{Inorganic Nitrogen} = 20.6 + 1.25 + 0.5 = \underline{22.35 \text{ lb N/dt}}$

Agronomic Rate:

$600 \text{ lb N/Ac/year} \div 22.35 \text{ lb N/dry ton} = \underline{27 \text{ dry tons/Acre/year}}$

As can be seen from the above calculations, **the current biosolids application rate of 22 dry tons per acre is equal or below the calculated Agronomic Rate for the anaerobically digested biosolids.** Therefore, as required by the 40 CFR Part 503 regulations, the anaerobically digested biosolids are being applied at a rate equal to or less than the agronomic rate for the crops grown.

APPENDIX A
AGRONOMIC RATE
SUPPORTING DOCUMENTATION

ALABAMA
COOPERATIVE

Extension

S Y S T E M

Your Experts for Life

Jefferson County Extension Office
2121 Building, Suite 1700
2121 8th Avenue North
Birmingham, AL 35203-2387
Telephone: (205) 325-5342
FAX: (205) 325-5690

November 19, 2003

Mr. David Denard
A-300 Courthouse Annex
716 Richard Arrington Jr. Blvd.
Birmingham, Al 35203

David:


Enclosed is a fact sheet that we based our 6001b/N/ACRE recommendation related to the county's hay production/Bio-solid project.

The reasoning behind the high rate of nitrogen is to maximize forage tonnage which in turn will increase sludge uptake and breakdown.

The yearly fertilization schedule is based on six cuttings using 100lb/N/ac/cutting. The extra cuttings comes from over seeding the Bermudagrass with ryegrass in the fall. The ryegrass can be cut twice, while Bermudagrass is normally cut four times each year.

If you have questions or comments related to this schedule, feel free to give me a call.

Sincerely,



David Hubbard
County Extension Agent

DH/fb

ALABAMA A&M AND AUBURN UNIVERSITIES, AND TUSKEGEE UNIVERSITY, COUNTY GOVERNING BODIES AND USDA COOPERATING

The Alabama Cooperative Extension System offers educational programs, materials, and equal opportunity employment to all people without regard to race, color, national origin, religion, sex, age, veteran status, or disability.

Worksheet for Calculating Biosolids Application Rates in Agriculture

By Craig Cogger, Extension Soil Scientist, WSU-Puyallup
and Dan Sullivan, Extension Soil Scientist, Oregon State University

Overview

This bulletin will walk you through the calculations that yield the biosolids agronomic rate. This rate is based on biosolids quality (determined by analytical results), site and crop nitrogen requirements, and regulatory limits for trace element application. In almost all cases, nitrogen controls the biosolids application rate. By calculating the agronomic rate, managers can match the plant-available N supplied by biosolids to crop N needs.

The calculations consist of 6 steps:

1. Collect information on the site and crop, including crop N requirement.
2. Estimate the plant-available N needed from the biosolids application.
3. Collect biosolids nutrient data.
4. Estimate plant-available N per dry ton of biosolids.
5. Calculate the agronomic biosolids application rate on a dry ton basis.
6. Convert the application rate to an "as is" basis.

This bulletin consists of:

- A worksheet with instructions for completing the application rate calculations.
- The same calculations in equation form for those who prefer using equations.
- Tables for calculating trace element loading.

To learn more about the use and management of biosolids as a fertilizer, refer to *Fertilizing with Biosolids*, PNW508, which is the companion to this bulletin.

Worksheet

Step 1. Collect Site Information.

Soil and crop information:

| Line No. | Your Information | Example |
|----------|--|---------------------|
| 1.1 | Soil series and texture (NRCS soil survey) | Puyallup sandy loam |
| 1.2 | Yield goal (grower, agronomist) (units/acre*) | 5 tons/acre/yr |
| 1.3 | Crop rotation (grower; e.g., wheat/fallow/wheat) | perennial grass |
| 1.4 | Plant-available N needed to produce yield goal (fertilizer guide; agronomist) (lb N/acre/yr) | 200 |

Plant-available N provided by other sources:

| Line No. | Your Calculation | Example | Units |
|--|--|---------|-----------|
| Pre-application testing | | | |
| 1.5 | Nitrate-N applied in irrigation water | 10 | lb N/acre |
| 1.6 | Preplant nitrate-N in root zone (east of Cascades)** | — | lb N/acre |
| Adjustments to typical soil N mineralization | | | |
| 1.7 | Plowdown of cover or green manure crop** | — | lb N/acre |
| 1.8 | Previous biosolids applications (Table 1) | 30 | lb N/acre |
| 1.9 | Previous manure applications | — | lb N/acre |
| Grower information | | | |
| 1.10 | N applied at seeding (starter fertilizer) | — | lb N/acre |
| 1.11 | Total plant-available N from other sources (sum of lines 1.5 through 1.10) | 40 | lb N/acre |

*Yield goals may be expressed as a weight (tons, lb, etc.) or as a volume (bushels).

**Do not list here if these N sources were accounted for in the nitrogen fertilizer recommendation from a university fertilizer guide.

Step 2. Estimate the Amount of Plant-Available N Needed from Biosolids.

| Line No. | | Your Calculation | Example | Units |
|----------|---|------------------|---------|-----------|
| 2.1 | Plant-available N needed to produce yield goal (from line 1.4) | | 200 | lb N/acre |
| 2.2 | Plant-available N from other sources (from line 1.11) | | 40 | lb N/acre |
| 2.3 | Amount of plant-available N needed from biosolids (line 2.1 - line 2.2) | | 160 | lb N/acre |

Step 3. Collect Biosolids Data.

Application Information:

| Line No. | | Your Information | Example |
|----------|---|------------------|------------------|
| 3.1 | Moisture content of biosolids (liquid or solid; see Table 3, pg. 8) | | liquid |
| 3.2 | Biosolids processing method (see Table 3, pg. 8) | | anaerobic |
| 3.3 | Method of application (surface or injected) | | surface |
| 3.4 | Number of days to incorporation of biosolids | | no incorporation |
| 3.5 | Expected application season | | Mar.-Sept. |

Laboratory Biosolids Analysis (dry weight basis):

If your biosolids analysis is on an "as is" or wet weight basis, you will need to divide your analysis by the percent solids (line 3.10) and multiply the result by 100 to convert to a dry weight basis.

| Line No. | | Your Calculation | Example | Units |
|----------|------------------------------------|------------------|--------------|---------|
| 3.6 | Total Kjeldahl N (TKN)* | | 50,000 | mg/kg |
| 3.7 | Ammonium N* | | 10,000 | mg/kg |
| 3.8 | Nitrate N *, ** | | not analyzed | mg/kg |
| 3.9 | Organic N*** (line 3.6 - line 3.7) | | 40,000 | mg/kg |
| 3.10 | Total solids | | 2.5 | percent |

*If your analysis is in percent, multiply by 10,000 to convert to mg/kg.

**Nitrate-N analysis required for composted or aerobically-digested biosolids, but not for anaerobically-digested biosolids.

***Organic N = total Kjeldahl N - ammonium N.

Step 4. Estimate Plant-Available N Per Dry Ton of Biosolids.

Convert biosolids N analysis to lb per dry ton:

| Line No. | | Your Calculation | Example | Units |
|----------|---|------------------|--------------|--------------|
| 4.1 | Total Kjeldahl N (TKN) (line 3.6 x 0.002) | | 100 | lb N/dry ton |
| 4.2 | Ammonium N (line 3.7 x 0.002) | | 20 | lb N/dry ton |
| 4.3 | Nitrate N (line 3.8 x 0.002) | | not analyzed | lb N/dry ton |
| 4.4 | Organic N (line 4.1 - 4.2) | | 80 | lb N/dry ton |

Estimate Inorganic N Retained:

| | | | | |
|-----|---|--|----|--------------|
| 4.5 | Percent of ammonium-N retained after application (Table 2, pg. 7) | | 60 | percent |
| 4.6 | Ammonium-N retained after application (line 4.2 x line 4.5/100) | | 12 | lb N/dry ton |
| 4.7 | Calculate biosolids inorganic N retained (line 4.3 + line 4.6) | | 12 | lb N/dry ton |

Estimate Organic N Mineralized:

| | | | | |
|-----|---|--|----|--------------|
| 4.8 | Percent of organic N that is plant-available in Year 1 (Table 3, pg. 8) | | 30 | percent |
| 4.9 | First year plant-available organic N (line 4.4 x line 4.8/100) | | 24 | lb N/dry ton |

Plant-available N:

| | | | | |
|------|---|--|----|--------------|
| 4.10 | Estimated plant-available N Add available inorganic N and available organic N (line 4.7 + line 4.9) | | 36 | lb N/dry ton |
|------|---|--|----|--------------|

Step 5. Calculate the Agronomic Biosolids Application Rate.

| Line No. | | Your Calculation | Example | Units |
|----------|---|------------------|---------|--------------|
| 5.1 | Amount of plant-available N needed from biosolids (from line 2.3) | | 160 | lb N/acre |
| 5.2 | Estimated plant-available N in biosolids (from line 4.10) | | 36 | lb N/dry ton |
| 5.3 | Agronomic biosolids application rate (line 5.1/line 5.2) | | 4.4 | dry ton/acre |

Step 6. Convert to "As Is" Biosolids Basis.

| Desired Units | | Your Calculation | Example |
|------------------------|-------------------------------|------------------|---------|
| Gallons per acre = | (line 5.3/line 3.10) x 24,000 | | 42,240 |
| Acre inches per acre = | (line 5.3/line 3.10) x 0.88 | | 1.55 |
| Wet tons per acre = | (line 5.3/line 3.10) x 100 | | 176 |

How to Use the Worksheet

Step 1. Collect Site Information.

Soil Series and Surface Soil Texture (Line 1.1)

Find the location on the county NRCS soil survey. Record the series name and surface texture of the predominant soil.

Crop Yield Goal (Line 1.2)

Field records are the best source for crop yield estimates. You can find proven yields for most grain farms from the local Farm Service Agency office. For most other cropping systems, grower records are the only source available. Be sure to note whether the yield records are on an "as is" or dry matter basis. Where field records are not available, you can make first-year estimates for a project using NRCS soil surveys, county production averages, or other local data sources.

A site used repeatedly for biosolids application should have yield data collected each year. Use this accumulated data for determining crop nitrogen requirement. If crop yield data is not kept, you may need to conduct additional monitoring (e.g., post-harvest soil nitrate testing) to be sure biosolids are applied at an agronomic rate.

Yield data is typically not available for grazed pastures because grazing animals consume the crop directly in the field. In these cases omit the yield goal, and go directly to Line 1.4. Estimate plant nitrogen needs from the appropriate pasture fertilizer guide recommendation, based on the level of pasture management.

Crop Rotation (Line 1.3)

Consult with the grower and discuss the range of possible crop rotations. Rotations that include root crops or other crops with a long post-application waiting period are not suitable for Class B biosolids applications.

Plant-Available N Needed to Produce Yield Goal (Line 1.4)

You can estimate plant-available-N needs by referring to university fertilizer guides or consulting a qualified agronomist.

University Fertilizer Guides

Land grant universities (Washington State University, Oregon State University, University of Idaho) publish fertilizer guides that estimate crop nitrogen requirements. Use the fertilizer guide most appropriate for the site and crop. For major crops, guides may cover irrigated or rainfed (dryland) cropping and different geographic areas. Don't use guides produced for irrigated sites when evalu-

ating dryland sites. When appropriate guides do not exist, consult the local Cooperative Extension or Natural Resources Conservation Service office, or a qualified agronomist for assistance.

Nitrogen fertilizer application rates listed in the fertilizer guides are based on field growth trials under the specified climate and cultural conditions. Growth trial results are averaged over a variety of soil types and years. Note that fertilizer guide recommendations are not the same as crop uptake. This is because the fertilizer guides account for N available from mineralization of soil organic matter and the efficiency of N removal by the crop.

The N rate recommended in fertilizer guides assumes average yields, good management practices, and removal of N from the field through crop harvest or grazing. In terms of satisfying crop N needs, plant-available N from biosolids application is considered equal to fertilizer N.

Agronomist Calculations

Because of the general nature of university fertilizer guides, it may be worthwhile to have a qualified agronomist calculate how much plant-available N is needed for a specific field. Always use the same method to calculate the N requirements. You will need to document your reasons for using agronomist calculations instead of the university fertilizer guide.

Plant-available N provided by other sources (Lines 1.5-1.11)

To make sure there isn't too much nitrogen applied to a crop, you must determine how much nitrogen comes from sources other than biosolids and soil organic matter. These sources of N are grouped into three categories in the worksheet:

- Plant-available N estimated by pre-application testing
- Adjustments to typical soil organic N mineralization (usually obtained from an agronomist)
- Information supplied by the grower

N estimated by pre-application testing (Lines 1.5-1.6)

Irrigation Water

Since the amount of nitrate-N in irrigation water varies, it should be determined by water testing. Irrigation water containing 5 mg nitrate-N per liter will contribute 1.1 pounds of nitrogen per acre inch applied; irrigation water containing 10 mg nitrate-N per liter will contribute 2.3 pounds of N per acre inch.

Preplant Nitrate-N in the Root Zone (east of Cascades)

You can estimate the preplant nitrate-N in the root zone by testing the soil in early spring. Sample in one-foot increments to a depth of at least two feet. University of Idaho Cooperative Extension Service Bulletin No. 704, *Soil Sampling*, is a good reference for soil sampling procedures.

Some fertilizer guides use preplant soil nitrate-N when calculating N fertilizer application rates. If you use these guides, don't count soil test nitrate-N in our worksheet. It has already been accounted for in the recommended fertilizer N rate prescribed in the guide.

Adjustments to typical soil N mineralization (Lines 1.7-1.9)

Nitrogen mineralization is the release of nitrogen from organic forms to plant-available inorganic forms (ammonium and nitrate). Soil organic matter supplies plant-available N through mineralization, but this is accounted for in the fertilizer guides. Sites with a history of cover crops, biosolids applications, or manure applications supply more plant-available N than do sites without a history of these inputs, and biosolids recommendations must be adjusted based on this additional supply of N.

Plowdown of Cover or Green Manure Crops

Green manures and cover crops are not removed from the field, but are recycled back into the soil by tillage. You can get an estimate of the N contributed from this plowdown by referring to the university fertilizer guides, or by estimating the yield and nitrogen concentration of the cover crop. Recovery of green manure N by the next crop ranges from 10-50% of the total N added to the soil by the cover crop. Estimates of plant-available N contributed by green manure crops should be made by a qualified agronomist.

Previous Biosolids Applications

Previous biosolids applications contribute to plant-available nitrogen in the years after the initial application. In the worksheet, they are considered as "N from other sources." We estimate that 8, 3, 1 and 1 percent of the organic N originally applied mineralizes in Years 2, 3, 4 and 5 after application. After Year 5, biosolids N is considered part of stable soil organic matter and is not included in calculations.

Table 1. Estimated nitrogen credits for previous biosolids applications at a site.

| | Years After Biosolids Application | | | Cumulative Years 2, 3, 4 and 5 |
|--------------------------------|--|--------|---------------|--------------------------------------|
| | Year 2 | Year 3 | Years 4 and 5 | |
| Biosolids Organic N as applied | Percent of Organic N Applied First Year | | | |
| | 8 | 3 | 1 | 13 |
| mg/kg (dry wt basis) | Plant-available N released, lb N per dry ton | | | |
| 10000 | 1.6 | 0.6 | 0.2 | 2.6 |
| 20000 | 3.2 | 1.2 | 0.4 | 5.2 |
| 30000 | 4.8 | 1.8 | 0.6 | 7.8 |
| 40000 | 6.4 | 2.4 | 0.8 | 10.4 |
| 50000 | 8.0 | 3.0 | 1.0 | 13.0 |
| 60000 | 9.6 | 3.6 | 1.2 | 15.6 |

In using Table 1, consider the following example. Suppose:

- You applied biosolids with an average organic N content of 30,000 mg/kg
- Applications were made the previous 2 years
- The application rate was 4 dry tons per acre

Table 1 gives estimates of nitrogen credits *in terms of the organic N originally applied*. Look up 30,000 mg/kg under Year 2 and Year 3 columns in the table. The table estimates 4.8 lb plant-available N per dry ton for year 2, and 1.8 lb plant-available N for year 3 (two-year credit of 6.6 lb N per dry ton). To calculate the N credit in units of lb/acre, multiply your application rate (4 dry ton/acre) by the N credit per ton (6.6 lb N/dry ton). The N credit is 26.4 lb plant-available N per acre.

Previous Manure Applications

Previous manure applications contribute to plant-available nitrogen in a similar manner to previous biosolids applications. To estimate this contribution, consult an agronomist.

Information supplied by the grower (Line 1.10)

N Applied at Seeding

For best growth, some crops depend on starter fertilizers (N applied at seeding). These fertilizers usually supply N, P and S. Examples are 16-20-0, 10-34-0. Starters are usually applied at rates that supply 10-30 lb N per acre. Enter all of the N supplied by starter fertilizer on line 1.10 in the worksheet.

Step 2. Estimate Plant-Available N Needed from Biosolids.

Next you will estimate the amount of plant-available N the biosolids must provide. This is the difference between the total plant-available N needed to produce the yield goal (line 1.4) and the plant-available N from other sources (line 1.11).

Step 3. Collect Biosolids Data.

To make the calculation, managers will need the following analyses:

- Total Kjeldahl N (TKN)
- Ammonium-N ($\text{NH}_4\text{-N}$)
- Nitrate-N ($\text{NO}_3\text{-N}$; composted or aerobically digested biosolids only)
- Percent total solids

If your laboratory results are on an “as is” or wet weight basis, you must convert them to a dry weight basis. To convert from an “as-is” to a dry weight basis, divide your analysis by the percent solids in the biosolids and multiply the result by 100.

Total Kjeldahl N includes over 95% of the total nitrogen in biosolids. In using the worksheet, we will assume that total Kjeldahl N equals total N.

Ammonium-N usually makes up over 95% of the total inorganic N in most biosolids. Ammonium-N includes both ammonia (NH_3) and ammonium (NH_4^+). Depending on your laboratory, results for ammonium-N may be expressed as either ammonia-N or ammonium-N.

Nitrate-N analyses also include small amounts of nitrite. Nitrite concentrations are negligible in biosolids. There may be significant amounts of nitrate in aerobically-digested biosolids or in composts. There is little nitrate in anaerobically-digested biosolids; therefore, nitrate analysis is not needed for these materials.

Determine biosolids organic N by subtracting ammonium-N from total Kjeldahl N (line 3.6 - line 3.7). Percent total solids analyses are used to calculate application rates. Biosolids applications are calculated as the dry weight of solids applied per acre (e.g., dry tons per acre).

Step 4. Estimate Plant-Available N Per Dry Ton of Biosolids.

The estimate of plant-available N per dry ton of biosolids includes:

- Some of the ammonium-N
- All of the nitrate-N
- Some of the organic N

Inorganic N Retained (Lines 4.5-4.7)

Ammonium-N (Lines 4.5-4.6)

Under some conditions, ammonium is readily transformed to ammonia and lost as a gas. This gaseous ammonia loss reduces the amount of plant-available N supplied by biosolids. The following section explains the factors used to estimate ammonia-N retained in plant-available form after application.

Biosolids processing

Some types of biosolids processing cause most of the ammonia-N to be lost as ammonia gas or converted to organic forms before application:

- Drying beds
- Alkaline stabilization at pH 12
- Composting

Application method

Ammonia loss occurs only with surface application. Injecting liquid biosolids eliminates ammonia loss, since the injected liquid is not exposed to the air. Surface applications of liquid biosolids lose less ammonia than do dewatered biosolids. For liquid biosolids, the ammonia is less concentrated and is held as NH_4^+ on negatively-charged soil surfaces after the liquid contacts the soil.

Ammonia loss is fastest just after application to the field. As ammonia is lost, the remaining biosolids are acidified—that is, each molecule of NH_3 loss generates one molecule of H^+ (acidity). Acidification gradually slows ammonia loss. Biosolids that remain on the soil surface will eventu-

ally reach a pH near 7, and further ammonia losses will be small. Losses of ammonia after six days on the soil surface are very close to zero.

Days to soil incorporation

Tillage to cover biosolids can reduce ammonia loss by adsorption of ammonium-N onto soil particles.

Table 2 estimates the amount of ammonium-N retained after field application. To use this table, you will need information on biosolids stabilization processes, method of application (surface or injected), and the number of days to soil incorporation.

Table 2. Estimates of ammonium-N retained after biosolids application.

| Days to incorporation by tillage | Surface-applied | | | | Injected |
|----------------------------------|---|---------------------|--------------------------------|-----------------------------------|---------------|
| | Liquid Biosolids | Dewatered Biosolids | Alkaline-stabilized Biosolids* | Composted or Drying Bed Biosolids | All Biosolids |
| | Ammonium-N retained, percent of applied | | | | |
| 0 to 2 | 80 | 60 | 10 | 100 | 100 |
| 3 to 6 | 70 | 50 | 10 | 100 | 100 |
| over 6† | 60 | 40 | 10 | 100 | 100 |

*For alkaline-stabilized biosolids analyzed for ammonium-N before lime addition.

†If biosolids will not be incorporated by tillage, use over 6 days to incorporation.

Nitrate-N (Line 4.3)

We assume 100% availability of biosolids nitrate-N.

Organic N Mineralized (Lines 4.8-4.9)

Biosolids organic N, which includes proteins, amino acids and other organic N compounds, is not available to plants at the time of application. Plant-available N is released from organic N through microbial activity in soil—called mineralization. Mineralization is more rapid in soils that are warm and moist, and is slower in soils that are cold or dry. Biosolids organic N mineralization rates in soil also depend on the treatment plant processes that produced the biosolids.

Use Table 3 to estimate biosolids mineralization rates based on processing. Use the middle of the range presented, unless you have information specific to the site or biosolids that justifies using higher or lower values within the range.

Table 3. First-year mineralization estimates for organic N in biosolids.

| Processing | Moisture Content | First-year organic-N mineralization rate |
|---|------------------|--|
| Anaerobic digestion | liquid | percent of organic N 20-40 |
| Aerobic digestion | liquid | 30-45 |
| Aerobic or anaerobic digestion and storage in lagoon > 6 months | liquid | 15-30 |
| Anaerobic digestion and dewatering | semi-solid | 20-40 |
| Drying bed | solid | 15-30 |
| Heat-drying | solid | 20-40 |
| Composting | solid | 0-20 |

Step 5. Calculate the Agronomic Biosolids Application Rate.

Perform this calculation using the results of the previous sections, as shown in lines 5.1 through 5.3.

Step 6. Convert Agronomic Biosolids Application Rate to "As Is" Basis.

Use the appropriate conversion factors (given in Table 6) to convert to gallons, acre-inches, or wet tons per acre.

Other considerations for calculations

- **Small acreage sites without a reliable yield history.** Some communities apply biosolids to small acreages managed by "hobby farmers." In many of these cases, there is no reliable yield history for the site, and the goal of management is not to make the highest economic returns. You can be sure of maintaining agronomic use of biosolids nitrogen on these sites by applying at a rate substantially below that estimated for maximum yield.
- **Equipment limitations at low application rates.** At some low-rainfall dryland cropping locations east of the Cascades, the agronomic rate calculated with the worksheet will be lower than can be spread with manure spreaders (usually about 3 dry tons per acre). At these locations, you may be able to apply the dewatered biosolids at the equipment limit, but check with your permitting agency for local requirements.

-
- **Unavailable soil nitrate (dryland cropping, east of Cascades).** Not all of the nitrate-N determined by testing dryland soils (line 1.6) is available to the crop because chemical extraction of nitrate is more efficient than plant root extraction. This difference becomes significant when soil nitrate concentrations are low (less than 10 mg nitrate N/kg soil) and sampling is done to greater than two feet.

Recent research has shown that the amount of “unavailable nitrate-N” increases with soil clay content. Use the following formula if you estimate “unavailable nitrate-N” based on soil clay content.

$$\text{Unavailable nitrate-N (mg/kg)} = \text{percent clay} \times 0.1$$

- **Denitrification and immobilization.** Denitrification (the loss of nitrate as gaseous N_2 or N_2O) and immobilization (the loss of nitrate or ammonium by incorporation into organic compounds) can occur following biosolids application. At agricultural sites these losses usually are not included in biosolids loading rate calculations because university fertilizer guides account for average losses due to these processes. Check with your local permitting agency before including denitrification or immobilization losses in the loading rate calculations.
- **Site Specific Inputs.** Biosolids application rates can also be calculated using a more detailed N budget method found in Washington State Department of Ecology publication, “*Managing Nitrogen from Biosolids*.” The N budget method allows for more site-specific inputs into the calculation. It will be most valuable when budget components are based on actual site monitoring data. If you do not have detailed site nitrogen data, use the worksheet presented above.

Cumulative Loading of Trace Elements

Under EPA regulations (40 CFR Part 503.13), managers must maintain records on cumulative loading of trace elements *only* when bulk biosolids do not meet EPA Exceptional Quality Standards for trace elements (Table 4).

When required, the steps in tracking trace metals are:

- Obtain biosolids trace element analyses from the wastewater treatment plant database.
- Compute pounds of element per dry ton of biosolids. Multiply mg/kg (dry weight basis) by 0.002.
- Keep records of the amount of biosolids applied to the site each year (in dry tons per acre).
- Compute pounds of element applied per acre. Multiply pounds of element per dry ton by dry tons applied.
- Compare cumulative pounds of element applied with the cumulative loading rate limit (Table 5).

Table 4. Biosolids concentration limits for land application. Source: EPA 40 CFR Part 503.

| Element | Symbol | Concentration Limit | |
|------------|--------|---|---|
| | | Exceptional Quality Standard (EPA Table 3)* <i>mg/kg</i> | Ceiling Limit (EPA Table 1) <i>mg/kg</i> |
| Arsenic | As | 41 | 75 |
| Cadmium | Cd | 39 | 85 |
| Copper | Cu | 1500 | 4300 |
| Lead | Pb | 300 | 840 |
| Mercury | Hg | 17 | 57 |
| Molybdenum | Mo | ** | 75 |
| Nickel | Ni | 420 | 420 |
| Selenium | Se | 100 | 100 |
| Zinc | Zn | 2800 | 7500 |

*EPA Table 3 and Table 1 refer to tables in EPA biosolids rule (40 CFR Part 503).

**Molybdenum Table 3 level is under review by the EPA.

Table 5. Cumulative loading rate limits for bulk biosolids that do not meet EPA-Table 3 criteria and are applied to agricultural land. Source: EPA 40 CFR Part 503.13.

| Element | Cumulative Limit (lb/acre) |
|------------|----------------------------|
| Arsenic | 37 |
| Cadmium | 35 |
| Copper | 1340 |
| Lead | 268 |
| Mercury | 15 |
| Molybdenum | * |
| Nickel | 375 |
| Selenium | 89 |
| Zinc | 2500 |

*Molybdenum limit is under review by the EPA.

Table 6. Conversion Factors

| | | |
|-------------|---|-------------------------------------|
| 1% | = | 10,000 mg/kg or ppm |
| | = | 20 lb/ton |
| 1 mg/kg | = | 1 ppm |
| | | .0001% |
| | | .002 lb/ton |
| 1 wet ton | = | 1 dry ton / (percent solids x 0.01) |
| 1 dry ton | = | 1 wet ton x (percent solids x 0.01) |
| 1 acre-inch | = | 27,000 gallons |

The following equations summarize the calculations in the worksheet. You can use them in place of the worksheet. These equations do the same calculation as the worksheet, so you do not have to use both. These equations will give results in dry tons of biosolids per acre. You will still need an additional calculation (Step 6 in the worksheet) to convert to an "as is" basis.

Equations for Calculating Application Rates

$$B_{app} = (N_{need} - N_{other})/B_{pan} \quad [1]$$

$$B_{pan} = [(TN - AN) * M/100 + AN * R/100 + NN] * C \quad [2]$$

$$N_{other} = (0.225N_w * W) + \sum(N_{ppi} * 2.8 * D_i) + N_{gm} + N_{bs} + N_{man} + N_{start} \quad [3]$$

Where:

B_{app} is the biosolids application rate in dry tons/acre

N_{need} is the plant-available N needed to produce the crop yield goal in lb/acre

N_{other} is the plant-available N provided by other sources in lb/acre

B_{pan} is plant-available N in the biosolids in lb/dry ton

TN is biosolids total N in mg/kg or percent

AN is biosolids ammonium N in mg/kg or percent

NN is biosolids nitrate N in mg/kg or percent

M is the biosolids organic N mineralization rate in percent (Table 3)

R is the proportion of ammonium N retained in available form in percent (Table 2)

C is the conversion to lb/dry ton for biosolids N. For analyses in mg/kg, $C = 0.002$; for analyses in percent, $C = 20$.

N_w is the nitrogen content of irrigation water in mg/kg

W is the irrigation water applied in inches

N_{ppt} is preplant nitrogen in layer i in mg/kg. (Layers must be sampled in 12-inch increments)

D_i is soil bulk density in layer i in g/cm³

N_{gm} is nitrogen from the plowdown of a green manure or cover crop in lb/acre

N_{bs} is nitrogen released from previous biosolids applications in lb/acre (Table 1)

N_{man} is nitrogen released from previous manure applications in lb/acre

N_{start} is nitrogen supplied by starter fertilizer in lb/acre

Pacific Northwest Cooperative Extension Publications are jointly produced by the three Pacific Northwest states—Washington, Oregon, and Idaho. Similar crops, climate, and topography create a natural geographic unit that crosses state lines. Since 1949, the PNW program has published more than 450 titles. Joint writing, editing, and production have prevented duplication of effort, broadened the availability of faculty specialists, and substantially reduced costs for the participating states.

Pacific Northwest Extension Publications contain material written and produced for public distribution. You may reprint written material, provided you do not use it to endorse a commercial product. Please reference by title and credit Pacific Northwest Extension Publications. To reproduce material used with permission in this publication, please contact the original source.

The three participating Extension Services offer educational programs, activities, and materials—without regard to race, color, national origin, sex, age, or disability—as required by the Title VI of the Civil Rights Act of 1964, Title IX of the Educational Amendments of 1972, and Section 504 of the Rehabilitation Act of 1973. Washington State University Cooperative Extension, the University of Idaho Cooperative Extension System, and the Oregon State University Extension Service are Equal Opportunity Employers.

Issued by Washington State University Cooperative Extension, Oregon State University Extension Service, University of Idaho Cooperative Extension System, and the U.S. Department of Agriculture in furtherance of the Acts of May 8 and June 30, 1914. Cooperative Extension programs and policies comply with federal and state laws and regulations on nondiscrimination regarding race, color, gender, national origin, religion, age, disability, and sexual orientation. Trade names have been used to simplify information; no endorsement is intended. Published April 1999. \$1.00

APPENDIX B
VECTOR ATTRACTION REDUCTION STATISTICS

VECTOR ATTRACTION REDUCTION STATISTICS

A summary of the total amount of biosolids land applied from each wastewater treatment plant (WWTP) and the vector attraction reduction methods used for those biosolids is provided in Tables 1 and 2 below.

Table 1


Flat Top/Bessie Mines Land Reclamation Site Summary of 2013 Vector Attraction Reduction (VAR) Methods

| Jefferson County WWTP | Amount of Biosolids Land Applied (dry tons) | Vector Attraction Reduction Method |
|--|---|---|
| Cahaba River | 1,207 | Option 10: Incorporation of Biosolids into the Soil [503.33(b)(10)(i)] |
| Five Mile Creek | 1,021 | Option 10: Incorporation of Biosolids into the Soil [503.33(b)(10)(i)] |
| Leeds | 373 | Option 10: Incorporation of Biosolids into the Soil [503.33(b)(10)(i)] |
| Trussville | 614 | Option 10: Incorporation of Biosolids into the Soil [503.33(b)(10)(i)] |
| Turkey Creek | 251 | Option 10: Incorporation of Biosolids into the Soil [503.33(b)(10)(i)] |
| Valley Creek | 3,138 | Option 1: Volatile Solids Reduction by a minimum of 38 percent [503.33(b)(1)] Option 6: Addition of Alkaline Material [503.33(b)(6)] Option 10: Incorporation of Biosolids into the Soil [503.33(b)(10)(i)] |
| Village Creek | 2,639 | Option 6: Addition of Alkaline Material [503.33(b)(6)] Option 10: Incorporation of Biosolids into the Soil [503.33(b)(10)(i)] |
| Prudes Creek | 123 | Option 10: Incorporation of Biosolids into the Soil [503.33(b)(10)(i)] |
| Warrior | 25 | Option 10: Incorporation of Biosolids into the Soil [503.33(b)(10)(i)] |
| Total Amount of Biosolids Applied at Flat Top: | 9,391 dry tons | |

Table 2
Beltona Land Reclamation Site
Summary of 2013 Vector Attraction Reduction (VAR) Methods

| Jefferson County WWTP | Amount of Biosolids Land Applied (dry tons) | Vector Attraction Reduction Method |
|---|--|---|
| Valley Creek | 973 | Option 6: Addition of Alkaline Material [503.33(b)(6)] |
| Village Creek | 592 | Option 6: Addition of Alkaline Material [503.33(b)(6)] |
| Total Amount of Biosolids Applied at Beltona: | 1,565 dry tons | 100% = Option 6, Lime Addition |

APPENDIX C
SITE MAPS




LEGEND

- ★ JEFFERSON COUNTY WWTP
- LAND APPLICATION SITE



ENVIRONMENTAL SERVICES DEPARTMENT
JEFFERSON COUNTY, ALABAMA
BIOSOLIDS LAND RECLAMATION PROGRAM

FIGURE 1



Located in: T16S, R4W, Sec. 7, 17, 18, 19 and 20
T16S, R5W, Sec. 11, 12, 13, 14, 22 and 23


ENGINEERING SERVICE
ASSOCIATES, INC.



**FLAT TOP BIOSOLIDS LAND
RECLAMATION FACILITY**
JEFFERSON COUNTY, ALABAMA

| LEGEND | |
|---|---------------------------|
|  | Project Area |
| Plot 1 = 568 Acres | Plot 4 = 289 Acres |
| Plot 2 = 777 Acres | Plot 5 = 444 Acres |
| Plot 3 = 753 Acres | |

FIGURE 2



Located in: T14S, R3W
 Sections 21, 22, 27, 28 and 33

LEGEND

 Project Area

ENGINEERING SERVICE
 ASSOCIATES, INC.



**BELTONA BIOSOLIDS LAND
 RECLAMATION FACILITY**
 JEFFERSON COUNTY, ALABAMA

FIGURE 3